

ATTACHMENT 1

SUPPLEMENT 2

to

LICENSE AMENDMENT REQUEST DATED December 14, 1995

Conformance of Administrative Controls Section 6
to the Guidance of Standard Technical Specifications

Appendix A, Technical Specification Pages
Marked Up Pages as proposed in this Supplement

TS.6.0-3 (from November 25, 1996 supplement, Attachment 2)

TS.6.0-5 (from December 14, 1995 submittal, Exhibit C)

3. Shift crew composition may be less than the minimum requirement of 10CFR50.54(m)(2)(i) and 6.2.B.1 and 6.2.B.7 for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on-duty shift crew members provided immediate action is taken to restore the shift crew composition to within the minimum requirements.
4. An individual qualified in radiation protection procedures shall be on site when fuel is in a reactor. The position may be vacant for not more than 2 hours, in order to provide for unexpected absence, provided immediate action is taken to fill the required position.
5. Administrative procedures shall be developed and implemented to limit the working hours of plant staff who perform safety related functions (e.g., licensed SROs, licensed ROs, health physicists, auxiliary operators, and key maintenance personnel).

Deviations from these procedures shall be authorized by the Plant Manager or designee, or higher levels of management, in accordance with established procedures and with documentation of the basis for granting the deviation. Controls shall be included in the procedures such that individual overtime shall be reviewed monthly to ensure that excessive hours have not been assigned.

6. The operations manager or assistant operations manager shall hold an SRO license.
7. The shift technical advisor (STA) shall provide advisory technical support to the shift supervisor in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operation of the unit. Personnel performing the function of the STA shall be assigned to the shift crew when a unit is in MODE 1, 2, 3, or 4.

6.4 Procedures

Written procedures shall be established, implemented, and maintained covering the following activities:

- A. The applicable procedures recommended in Regulatory Guide 1.33, Revision 2, Appendix A, February 1978;
- B. The emergency operating procedures required to implement the requirements of NUREG-0737 and to NUREG-0737, Supplement 1, as stated in Generic Letter 82-33;
- C. Quality control for effluent and environmental monitoring;
- D. Fire protection program implementation; and
- E. All programs specified in Specification 6.5.

ATTACHMENT 2

SUPPLEMENT 2
to

LICENSE AMENDMENT REQUEST DATED December 14, 1995
Conformance of Administrative Controls Section 6
to the Guidance of Standard Technical Specifications

Appendix A, Technical Specification Pages
Revised Pages as proposed in this Supplement

TS.6.0-3
TS.6.0-5

3. Shift crew composition may be less than the minimum requirement of 10CFR50.54(m)(2)(i) and 6.2.B.1 and 6.2.B.7 for a period of time not to exceed 2 hours in order to accommodate unexpected absence of on-duty shift crew members provided immediate action is taken to restore the shift crew composition to within the minimum requirements.
4. An individual qualified in radiation protection procedures shall be on site when fuel is in a reactor. The position may be vacant for not more than 2 hours, in order to provide for unexpected absence, provided immediate action is taken to fill the required position.
5. Administrative procedures shall be developed and implemented to limit the working hours of plant staff who perform safety related functions (e.g., licensed SROs, licensed ROs, health physicists, auxiliary operators, and key maintenance personnel).

Deviations from these procedures shall be authorized by the Plant Manager or designee, or higher levels of management, in accordance with established procedures and with documentation of the basis for granting the deviation. Controls shall be included in the procedures such that individual overtime shall be reviewed monthly to ensure that excessive hours have not been assigned.

6. The operations manager or assistant operations manager shall hold an SRO license.
7. The shift technical advisor (STA) shall provide advisory technical support to the shift supervisor in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operation of the unit. Personnel performing the function of the STA shall be assigned to the shift crew when a unit is in MODE 1, 2, 3, or 4.

6.4 Procedures

Written procedures shall be established, implemented, and maintained covering the following activities:

- A. The applicable procedures recommended in Regulatory Guide 1.33, Revision 2, Appendix A, February 1978;
- B. The emergency operating procedures required to implement the requirements of NUREG-0737 and to NUREG-0737, Supplement 1, as stated in Generic Letter 82-33;
- C. Quality control for effluent and environmental monitoring;
- D. Fire protection program implementation; and
- E. All programs specified in Specification 6.5.