

DRAFT 2  
07/20/84

SSER

Task: Allegation A-43

Reference No.: 4-83-A-87/4

Characterization: Improperly performed calibrations including improper humidity and temperature control in test lab (office trailer).

Initial Assessment of Significance: Improperly calibrated instruments could invalidate the acceptability of safety-related systems.

This issue was addressed by a review of the response to this item provided by LP&L.

The NRC staff review determined that calibrations were correctly performed in accordance with approved procedure. When procedures were violated, nonconformances were documented.

The OI investigation of allegations in this area has indicated that the allegor overstated his concerns to get NRC attention. This allegation falls in that category, since the scope of the work of this allegation (Diesel Generator Installation) did not require the calibrations to be accomplished in a controlled atmosphere laboratory.

In conclusion, this allegation has neither safety significance nor generic implications.

[Potential Violation: None.] 4

Action Required: None.

References:

1. LP&L response to allegation.
2. A-36.

Statement Prepared By:

R. Westberg

Date

Reviewed By:

Team Leader

Date

Allegation A-43

- 2 -

Reviewed By:

\_\_\_\_\_  
Site Team Leader(s)

\_\_\_\_\_  
Date

Approved By:

\_\_\_\_\_  
Task Management

\_\_\_\_\_  
Date

Document Name:

SSER A-43

Requestor's ID:

JOHNNIE

Author's Name:

RWestberg/jkh

Document Comments:

SSER - Allegation A-43

DRAFT 1  
07/19/84

*SSEER*  
WATERFORD OPEN ISSUE

Task: Allegation A-43

Reference No.: 4-83-A-87/4

Characterization: Improperly performed calibrations including improper humidity and temperature control in test lab (office trailer).

Initial Assessment of Significance: Improperly calibrated instruments could invalidate the acceptability of safety-related systems.

This issue was addressed by a review of the response to this item provided by LP&L.

The NRC staff review determined that calibrations were correctly performed in accordance with approved procedure. When procedures were violated, nonconformances were documented.

The OI investigation of allegations in this area has indicated that the allegor overstated his concerns to get NRC attention. This allegation falls in that category, since the scope of the work of this allegation (Diesel Generator Installation) did not require the calibrations to be accomplished in a controlled atmosphere laboratory.

In conclusion, this allegation has neither safety significance nor generic implications.

[Potential Violation: None.] 4

Action Required: None.

References:

1. LP&L response to allegation.
2. A-36.

Statement Prepared By:

R. Westberg

Date

Reviewed By:

Team Leader

Date