

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

December 2, 1985


Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: McGuire Nuclear Station - Units 1 & 2
Docket Nos. 50-369 and 50-370

Gentlemen:

On November 2, 1985 McGuire Nuclear Station, Units 1 and 2 underwent Reactor Trips as a result of the loss of instrument air for both units, with a safety injection on Unit 1. The Licensee Event Report for this incident will be delayed until December 9, 1985.

Very truly yours,



Hal B. Tucker

JBD/jgm

Attachment

cc: Dr. J. Nelson Grace, Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30339

M&M Nuclear Consultants
1221 Avenue of the Americas
New York, New York 10020

Mr. W. T. Orders
NRC Resident Inspector
McGuire Nuclear Station

American Nuclear Insurers
c/o Dottie Sherman, ANI Library
The Exchange, Suite 245
270 Farmington Avenue
Farmington, CT 06032

8512060448 851202
PDR ADOCK 05000369
S PDR

IE22
1/1