

WATERFORD OPEN ISSUE

Task: Allegation A-61a

Reference Number: 4-83-A-88/13a

Characterization: It is alleged that EBASCO's Nonconformance Report (NCR) W3-4504 should be reviewed by the NRC.

Initial Assessment of Significance: Nonconforming conditions may still exist.

Source: Allegor["A"]

Approach to Resolution:

1. Assess NCR W3-4505(M-810) and revisions for adequacy.
2. Evaluate welding of thermowell welding in regard to ASME Code requirements.
3. Use-as-is dispositions should have engineering/committee type approval.
4. Repair type dispositions should have reinspection to original attributes.
5. Determine if NCR is assessed for 50.55(e) potential.
6. See LP&L response to Item No. 13 dated March 1, 1984, and March 9, 1984, and evaluate (in RI's file/safe).

7. RI's file/safe contains information and copies of some of the NCRs referenced above. (4-83-A-88)
8. Evaluate for generic/safety implications.
9. Report results of review/evaluation of allegation.

Status: In progress - R. W. Hubbard

Review Lead: Shao

Support: QA

Estimated Resources: 10 man days (total)

Estimated Completion: May 3, 1984

CLOSURE:

Document Name:  
ALLEGATION A-61A

Requestor's ID:  
JOYCE

Author's Name:  
SHAO/jkh

Document Comments:  
Waterford Open Issue - Allegation A-61a