

~~DRAFT 4~~ Revision 0
6/28/84

SSER

Task: Allegation A-273

Reference No.: 4-84-A-06/155

Characterization: It is alleged that there was incomplete quality control (QC) field verification of corrective action prior to closure of EBASCO Nonconformance Report (NCR) W32333, that is, not all hanger supports were reviewed for seismic qualification.

Assessment of Allegation: The alleged supplied to the NRC staff a conversation record between himself and a former Mercury employee. From this document, the staff learned that the employee had told the alleged that, as of the time he left Mercury and the Waterford 3 site, only about 95% of the required QC field verifications pertaining to NCR W32333 had been accomplished. In view of this information, the alleged's concern was whether the other 5% of the field verifications had been performed prior to closure of the NCR.

The NRC staff contacted the former Mercury employee in order to determine which hanger supports had not been reviewed. He stated that all but eight of the supports requiring rework had been completed, inspected, and documented.

The NRC staff reviewed EBASCO NCR W32333 and found these eight supports documented in the closed NCR package. The staff reviewed the documentation and the remainder of NCR W32333 for adequate closure. The staff found that the NCR adequately addressed field verification of hanger supports and had been dispositioned and closed out properly.

This allegation has neither safety significance nor generic implications.

Potential Violations: None.

Actions Required: None.

References

1. NCR W32333
2. Allegor "C" Transcript, Exhibit 44
3. Conversation Record between W. Marini and a former Mercury employee.

Statement Prepared By: _____
William S. Marini Date

Reviewed By: _____
Team Leader Date

Reviewed By: _____
Site Team Leader(s) Date

Approved By: _____
Task Management Date

Document Name:
SSER A-273 *file*

Requestor's ID:
JOYCE

Author's Name:

Document Comments:
comm from displaywriter 5/29/84

Document Name:
SSER A-273

Requestor's ID:
JOYCE

Author's Name:

Document Comments:
comm from displaywriter 5/29/84

A-273, REV. 0, 6/28/84

RETYPE REV. 1 (FINAL)

DO NOT REROUTE

wal
6/29

~~DRAFT 4~~ REVISION 0
6/28/84

SSER

Task: Allegation A-273

Reference No.: 4-84-A-06/155

Characterization: It is alleged that there was incomplete quality control (QC) field verification of corrective action prior to closure of EBASCO Nonconformance Report (NCR) W32333, that is, not all hanger supports were rechecked for seismic qualification.

Assessment of Allegation: The alleged supplied to the NRC staff a conversation record between himself and a former Mercury employee. From this document, the staff learned that the employee had told the alleged that, as of the time he left Mercury and the Waterford 3 site, only about 95% of the required QC field verifications pertaining to NCR W32333 had been accomplished. In view of this information, the alleged's concern was whether the other 5% of the field verifications had been performed prior to closure of the NCR.

The NRC staff contacted the former Mercury employee in order to determine which hanger supports had not been reviewed. He stated that all but eight of the supports requiring rework had been completed, inspected, and documented.

The NRC staff reviewed EBASCO NCR W32333 and found these eight supports documented in the closed NCR package. The staff reviewed the documentation and the remainder of NCR W32333 for adequate closure. The staff found that the NCR adequately addressed field verification of hanger supports and had been dispositioned and closed out properly.

This allegation has neither safety significance nor generic implications.

[Potential Violations: None.]

Actions Required: None.

References

1. NCR W32333
2. Allegor ["C"] Transcript, Exhibit 44
3. Conversation Record between W. Marini and a former Mercury employee.

Statement Prepared By: _____
William S. Marini Date

Reviewed By: _____
Team Leader Date

Reviewed By: _____
Site Team Leader(s) Date

Approved By: _____
Task Management Date