

ENCLOSURE 2

NOTICE OF DEVIATION

Florida Power Corporation  
Crystal River Unit 3

Docket No. 50-302  
License No. DPR-72

The following deviation was identified during an inspection conducted on November 26, 1985 - January 17, 1986.

A letter to the Nuclear Regulatory Commission from Florida Power Corporation dated June 6, 1985, responded to the violation identified in NRC Inspection Report 50-302/84-33. This letter stated that a temporary nitrogen source would be connected to an instrument tap of the affected Waste Gas Decay Tank (WGDT) so that the direct addition of nitrogen to the tank could be accomplished. The letter further stated that this action would be completed by June 20, 1985.

Contrary to the above, as of January 5, 1986, the temporary nitrogen source was not connected nor was the equipment available for the direct addition of nitrogen to the WGDTs.

Please provide, in writing within 30 days of the date of this Notice, a description of corrective actions regarding this deviation, actions taken to avoid further deviations, and the dates when these actions were or will be completed.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: FEB 12 1986

B602190104 B60212  
PDR ADOCK 05000302  
Q PDR