

YANKEE ATOMIC ELECTRIC COMPANY

Telephone (617) 872-8100
TWX 710-380-7619

2.C.2.1
FYR 85-130

1671 Worcester Road, Framingham, Massachusetts 01701

November 14, 1985

United States Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Attention: Dr. Thomas E. Murley, Regional Administrator

References: (a) License No. DPR-3 (Docket No. 50-29)

Subject: Steam Generator Inspection Results

Dear Sir:

In accordance with Technical Specifications 4.4.10.5.a, this letter provides notification on the number of tubes plugged following the inservice inspection of steam generator tubes.


As a result of the October 1985 inservice inspection of Steam Generator #1, one tube (L-23) was plugged.

Complete results of the steam generator inservice inspection will follow within twelve months in accordance with Technical Specification 4.4.10.5.b.

If you have any questions, please contact us.

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY



George Papanic, Jr.
Senior Project Engineer - Licensing
Yankee Project

GP/ba

8512090279 851114
PDR ADOCK 05000029
G PDR

1/0 1E01