

OPERATING DATA REPORT

DOCKET NO. 50-133
 DATE DECEMBER 4, 1985
 COMPLETED BY CKWOK
 TELEPHONE 707/443-2787

OPERATING STATUS

1. Unit Name: HUMBOLDT BAY POWER PLANT-UNIT 3
2. Reporting Period: NOVEMBER 1985
3. Licensed Thermal Power (MWt): 220
4. Nameplate Rating (Gross MWe): 65
5. Design Electrical Rating (Net MWe): 65
6. Maximum Dependable Capacity (Gross MWe): 65
7. Maximum Dependable Capacity (Net MWe): 63

Notes

8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A

10. Reasons For Restrictions, If Any: N/A

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>720</u>	<u>8016</u>	<u>195791</u>
12. Number Of Hours Reactor Was Critical	<u>0</u>	<u>0</u>	<u>98171</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>0</u>	<u>0</u>	<u>97252</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>15,618,456</u>
17. Gross Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>4,739,732</u>
18. Net Electrical Energy Generated (MWH)	<u>0</u>	<u>0</u>	<u>4532736</u>
19. Unit Service Factor	<u>0</u>	<u>0</u>	<u>49.7%</u>
20. Unit Availability Factor	<u>0</u>	<u>0</u>	<u>49.7%</u>
21. Unit Capacity Factor (Using MDC Net)	<u>0</u>	<u>0</u>	<u>36.1%</u>
22. Unit Capacity Factor (Using DER Net)	<u>0</u>	<u>0</u>	<u>35.6%</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>0</u>	<u>1.91%</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

N/A

25. If Shut Down At End Of Report Period, Estimated Date of Startup: DECOMMISSIONING

26. Units In Test Status (Prior to Commercial Operation):

Forecast

Achieved

INITIAL CRITICALITY

INITIAL ELECTRICITY

COMMERCIAL OPERATION

B602190154 B51130
 PDR ADDCK 05000133
 R PDR

(9/77)

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH NOVEMBER, 1985

DOCKET NO. 50-133
 UNIT NAME HBPP #3
 DATE DECEMBER 4, 1985
 COMPLETED BY CEK/KOK
 TELEPHONE 202/443-2787

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
76-6	760702	S	720	C,H	1	N/A	—	—	SEISMIC MODIFICATIONS

1 F: Forced
S: Scheduled

2 Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Retueling
D-Regulatory Restriction
E-Operator Training & License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

3 Method:
1-Manual
2-Manual Scram.
3-Automatic Scram.
4-Other (Explain)

4 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

5 Exhibit I - Same Source

(9/77)

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-133

UNIT HBPP #3

DATE DECEMBER 4, 1985

COMPLETED BY CKKWK

TELEPHONE 707/443-2787

MONTH NOVEMBER, 1985

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	0
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

PACIFIC GAS AND ELECTRIC COMPANY

PG&E

1034 SIXTH STREET • EUREKA, CALIFORNIA 95501 • (707) 443-2787

E. D. WEEKS

PLANT MANAGER

NUCLEAR PLANT OPERATIONS - HUMBOLDT

December 10, 1985


Office of Management Information
and Program Control
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Re: Docket No. 50-133
License No. DPR-7

Gentlemen:

Enclosed are the completed monthly report forms and the narrative of operating and major maintenance experience for Humboldt Bay Power Plant Unit No. 3 (HBPP-Unit 3) for November, 1985. These forms and the narrative are submitted in accordance with Section IX I.l.c of our Technical Specifications.

Sincerely,



E. D. Weeks
Plant Manager
Humboldt Bay Power Plant
1034 Sixth Street
Eureka, California 95501
(707-443-2787)

Enclosure

cc: Mr. J. C. Carroll
Mr. B. S. Lew
Mr. J. D. Shiffer

Mr. John B. Martin
Regional Administrator
U. S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

EDWeeks:ss

JE24
||

MONTHLY NARRATIVE REPORT
OF OPERATING
AND MAJOR MAINTENANCE EXPERIENCE

This report describes the operating and major maintenance experience for the month of November, 1985. This report was prepared by the Plant Staff and is submitted in accordance with Section IX:I.1.c. of the Technical Specifications.

During the report period, the reactor has been in the cold shutdown mode with the core unloaded and the reactor vessel drained. During the month the following items were conducted:

1. Construction of the radwaste enclosure.
2. Completed processing the suppression chamber water.
3. Commenced vacuuming the spent fuel pool.

IE 24
11,