

Docket Nos.: 50-445  
and 50-446

SEP 30 1985

Mr. W.G. Council  
Executive Vice President  
Texas Utilities Generating Company  
400 North Olive Street, L.B. 81  
Dallas, Texas 75201

Dear Mr. Council:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION PERTAINING  
TO COMANCHE PEAK FSAR ADMENDMENTS 54 AND 55,  
CHAPTER 17.

The Quality Assurance Branch has recently completed its review of Amendment 55 to the Comanche Peak FSAR. The staff finds that the FSAR acceptably responds to our earlier request for additional information concerning Chapter 17 which was enclosed with our letter dated January 7, 1985. However, the Quality Assurance Branch requests additional information concerning revisions made to the FSAR by Amendments 54 and 55. See the enclosed request for additional information.

Please advise my staff when we may expect a response and/or a conforming amendment to the FSAR. My staff will also arrange a conference call with the Quality Assurance Branch reviewer upon request.

Sincerely,

Vincent S. Noonan, Director  
for Comanche Peak Project  
Division of Licensing  
Office of Nuclear Reactor Regulation

Enclosure:  
Request for Additional Information  
CPSES FSAR Amendments 54 and 55

cc: See next page

Distribution

<u>Docket File</u>	B. Grimes
NRC PDR	A. Vietti
L PDR	J. Calvo
NSIC	L. Shao
PRC System	S. Burwell
LB# 1 Reading File	V. Noonan
Project Manager	C. Trammell
M. Rushbrook	B. Belke IE
Attorney, OELD	B.J. Youngblood
ACRS (16)	J. Stefano
J. Partlow	
E. Jordan	

8510030234 850930  
PDR ADOCK 05000445  
A PDR

OFC : CPP	: CPP	: CPP	:	:	:	:
NAME : SBBurwell	: CTrammell	: VSNoonan	:	:	:	:
DATE : 9/19/85	: 9/27/85	: 9/19/85	:	:	:	:

OFFICIAL RECORD COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SEP 30 1985

Docket Nos.: 50-445  
and 50-446

Mr. W.G. Council  
Executive Vice President  
Texas Utilities Generating Company  
400 North Olive Street, L.B. 81  
Dallas, Texas 75201


Dear Mr. Council:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION PERTAINING  
TO COMANCHE PEAK FSAR ADMENDMENTS 54 AND 55,  
CHAPTER 17.

The Quality Assurance Branch has recently completed its review of Amendment 55 to the Comanche Peak FSAR. The staff finds that the FSAR acceptably responds to our earlier request for additional information concerning Chapter 17 which was enclosed with our letter dated January 7, 1985. However, the Quality Assurance Branch requests additional information concerning revisions made to the FSAR by Amendments 54 and 55. See the enclosed request for additional information.

Please advise my staff when we may expect a response and/or a conforming amendment to the FSAR. My staff will also arrange a conference call with the Quality Assurance Branch reviewer upon request.

Sincerely,

  
Vincent E. Noonan, Director  
for Comanche Peak Project  
Division of Licensing  
Office of Nuclear Reactor Regulation

Enclosure:  
Request for Additional Information  
CPSES FSAR Amendments 54 and 55

cc: See next page

W. G. Council  
Texas Utilities Generating Company

Comanche Peak Steam Electric Station  
Units 1 and 2

cc:  
Nicholas S. Reynolds, Esq.  
Bishop, Liberman, Cook,  
Purcell & Reynolds  
1200 Seventeenth Street, NW  
Washington, D.C. 20036

Resident Inspector/Comanche Peak  
Nuclear Power Station  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 38  
Glen Rose, Texas 76043

Robert A. Wooldridge, Esq.  
Worsham, Forsythe, Sampels &  
Wooldridge  
2001 Bryan Tower, Suite 2500  
Dallas, Texas 75201

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Mr. Homer C. Schmidt  
Manager - Nuclear Services  
Texas Utilities Generating Company  
Skyway Tower  
400 North Olive Street, L.B. 81  
Dallas, Texas 75201

Larry A. Sinkin  
3022 Porter Street, NW #304  
Washington, D.C. 20008

Mr. Robert E. Ballard, Jr.  
Director of Projects  
Gibbs and Hill, Inc.  
11 Pen Plaza  
New York, New York 10001

Ms. Billie Pirner Garde  
Citizens Clinic Director  
Government Accountability Project  
1901 Que Street, NW  
Washington, D.C. 20009

Mr. A. T. Parker  
Westinghouse Electric Corporation  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

David R. Pigott, Esq.  
Orrick, Herrington & Sutcliffe  
600 Montgomery Street  
San Francisco, California 94111

Renea Hicks, Esq.  
Assistant Attorney General  
Environmental Protection Division  
P. O. Box 12548, Capitol Station  
Austin, Texas 78711

Anthony Z. Roisman, Esq.  
Trial Lawyers for Public Justice  
2000 P. Street, NW  
Suite 611  
Washington, D.C. 20036

Mrs. Juanita Ellis, President  
Citizens Association for Sound Energy  
1426 South Polk  
Dallas, Texas 75224

Nancy E. Wieggers  
Spiegel & McDiarmed  
1350 New York Avenue, NW  
Washington, D.C. 20005-4798

Ms. Nancy H. Williams  
CYGNA  
101 California Street  
San Francisco, California 94111

Texas Utilities Electric Company    - 2 -    Comanche Peak Electric Station  
Units 1 and 2

cc:  
Resident Inspector - Comanche Peak  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 1029  
Granbury, Texas 76048

Mr. John W. Beck  
Manager - Licensing  
Texas Utilities Electric Company  
Skyway Tower  
400 N. Olive Street, LB#81  
Dallas, Texas 75201

Mr. Jack Redding  
Licensing  
Texas Utilities Generating Company  
4901 Fairmont Avenue  
Bethesda, Maryland 20814

William A. Burchette, Esq.  
Heron, Burchette, Ruckert & Rothwell  
Suite 700  
1025 Thomas Jefferson Street, NW  
Washington, D.C. 20007

Mr. James McGaughy  
Southern Engineering Company of Georgia  
1800 Peachtree, Street, NW  
Atlanta, Georgia 30367-8301

REQUEST FOR ADDITIONAL INFORMATION

CPSES-FSAR Amendments 54 and 55

1. FSAR amendment 55 added the following items to Sheet 21 of Table 17A-1, "List of Quality Assured Structures, Systems, and Components" under Item 22, "Containment Ventilation Systems."

- f. Containment purge supply and exhaust  
ductwork and supports  
dampers and supports  
containment isolation valves  
and piping
- g. Containment pressure relief  
ductwork and supports  
containment isolation valves  
and piping  
suction pipe  
debris screen

This is acceptable except that the suction pipe and debris screen do not show a note under the column headed "Quality Assurance" which indicates that these items will be subject to the pertinent provisions of the 10 CFR 50 appendix B QA program during the operations phase. Add such a note (i.e., A, B, or C) to these items or justify not doing so.

2. FSAR amendment 54 revised the commitment to Regulatory Guide 1.144 [page 1 A(B) -59] to say that TUGCO "has elected to adopt, as an alternative commitment to the above referenced ANSI standard, the guidance...." To avoid misinterpreting what is intended, the commitment should be revised to say that TUGCO "has elected to adopt, as an alternative commitment to the external audit schedule requirements of the above referenced ANSI standard, the guidance...." So revise the commitment or justify not doing so.