


**TEXAS UTILITIES GENERATING COMPANY**  
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

Log # TXX-4629  
File # 10110

November 20, 1985

WILLIAM G. COUNCIL  
EXECUTIVE VICE PRESIDENT

Mr. R. P. Denise, Director  
Division of Reactor Safety and Projects  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76012



SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
DOCKET NOS. 50-445 AND 50-446  
DAMAGE STUDY EVALUATION OF WESTINGHOUSE  
ANALYZED PIPING  
QA FILE: CP-85-46, SDAR-208

Dear Mr. Denise:

On October 29, 1985, we verbally notified your Mr. T. F. Westerman of a deficiency involving high energy piping analyzed by Westinghouse. Postulated longitudinal line breaks were not evaluated by the damage study group. An evaluation is underway by Westinghouse to determine the significance of this concern. This analysis is proceeding based upon a recently completed site walkdown of affected piping systems.

We are continuing our evaluation and anticipate completion by December 20, 1985.

Very truly yours,

*W.G. Council*

W. G. Council

By: *D.R. Woodlan*  
D. R. Woodlan  
Licensing Supervisor

JCH/grr

c - NRC Region IV (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

85-1066  
8512090448 851120  
PDR ADOCK 05000445  
S PDR