

yellow

September 25, 1985

✓ Tennessee Valley Authority
ATTN: Mr. H. G. Parris
Manager of Power and
Engineering (Nuclear)
6N11 B Missionary Ridge Place
1101 Market Street
Chattanooga, TN 37402-2801

Gentlemen:

SUBJECT: REPORT NOS. 50-327/85-24 AND 50-328/85-24

Thank you for your response of September 6, 1985, to our Notice of Violation issued on August 7, 1985, concerning activities conducted at your Sequoyah facility. We have evaluated your response to Violation 50-328/85-24-02 and found that it meets the requirements of 10 CFR 2.201. We will examine the implementation of your corrective actions during future inspections.

Regarding your response to Violation 50-328/85-24-03, you state that the ice buildup on June 10, 1985, was removed the same day and that a surveillance instruction was performed to document that the intermediate deck doors were free of ice. Our evaluation indicates that Maintenance Request A-553690 was generated on June 10, 1985, to control the repair of insulation tape and removal of ice and/or moisture buildup. It is our understanding that the maintenance request documented completion of these activities on June 16, 1985. Since your response indicates that ice removal and surveillance testing occurred within 48 hours of finding the June 10, 1985 ice buildup, please provide in a supplemental response specific explanation and documentation to justify your position that the requirements of the limiting condition of operation of Technical Specification 3.6.5.3 were met. This request was discussed during a telephone call between Mr. P. Wallace of your staff and Mr. S. Weise and Mr. B. Debs of the Region II staff on September 13, 1985.

We appreciate your cooperation in this matter.

Sincerely,

Original Signed by
Roger D. Walker

Roger D. Walker, Director
Division of Reactor Projects

cc: (See page 2)

8510040118 850925
PDR ADOCK 05000327
G PDR

10 IE01

September 25, 1985

cc: ✓ H. L. Abercrombie, Sequoyah Nuclear
Plant Site Director
✓ P. R. Wallace, Plant Manager
✓ K. W. Whitt, Chief, Nuclear Safety
Staff
✓ D. L. Williams, Jr., Supervisor
Licensing Section
✓ G. B. Kirk, Compliance Staff
Supervisor
✓ J. E. Wills, Project Engineer

bcc: ✓ NRC Resident Inspector
Document Control Desk
State of Tennessee

RII

BDebs:pph
09/11/85

RII

CJ Julian
09/17/85

RII

AGibson
09/19/85

RII

Sweise
09/21/85

RII

DVerrelli
09/24/85