

November 25, 1985

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-85-112

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

FACILITY: Florida Power and Light Company
Turkey Point Unit 4
Docket No. 50-251
Homestead, Florida

Licensee Emergency Classification:
☐ Notification of Unusual Event
☐ Alert
☐ Site Area Emergency
☐ General Emergency
☒ Not Applicable

SUBJECT: SHUTDOWN TO CHECK VALVE MOTORS

Florida Power and Light (FPL) took Turkey Point Unit 4 out of service on November 23 for inspection of several Limitorque valve motors both inside and outside the containment building. The inspection was scheduled after FPL determined that some of the motors may not meet environmental qualification requirements in regard to such factors as lubricants and insulation.

FPL plans to restart Unit 4 later this week, and is formulating plans for confirming environmental qualification of valve motors at Unit 3, which is operating at 100 percent power.

FPL is prepared to respond to media inquiries.

The State of Florida has been informed.

This PN is issued for information only.

Contact: Fred Guenther, 242-5568

S. A. Elrod, 242-5536

DISTRIBUTION:

H. Sreet
Chairman Palladino
Comm. Roberts
Comm. Asselstine
Comm. Bernthal
Comm. Zech
SECY
ACRS
CA
PDR

MNBB - 4:40	Phillips - 4:44	E/W - 8:43	Willste - 4:45	MAIL:
EDO	NRR	IE	NMSS	ADM:DMB
PA		OIA	RES	DOT: Trans Only
MPA		AEOD		Applicable State
ELD				
Air Rights - 8:32		INPO - 8:38		
SP		NSAC		

Regions: I-7:40, III-7:48, IV-7:51
Licensee: 12:52
(Reactor Licensees)
Applicable Resident Site 12:56

8512100076 851125
PDR I&E
PNO-II-85-112 PDR

0/1
IE 34