

Official

NOV 27 1985

Georgia Power Company  
✓ ATTN: Mr. R. J. Kelly  
Executive Vice President  
P. O. Box 4545  
Atlanta, GA 30302

Gentlemen:

SUBJECT: DOCKET NOS. 50-424 AND 50-425 UTILITY SERVICES AND PARKING  
ARRANGEMENTS FOR NRC REGION II MOBILE LABORATORY AT PLANT VOGTLE

Reference is made to the telephone conversation between Mr. Jimmy D. Harris of the NRC and Mr. William Ollinger of Georgia Power Company on October 8, 1985, regarding the subject above. During the referenced telephone conversation, specifications for parking arrangements and utility services for the Region II Mobile Laboratory were discussed. We request that you make these services available at two separate locations. One location should be near the facility count room and will be used during routine inspections. The other location should be near your emergency operations facility and would be used during emergency situations.

The specifications are provided in the Enclosure.

We appreciate your cooperation on this matter. If you have any questions, please call William E. Cline at 404-331-2665.

Sincerely,

Virgil L. Brownlee, Chief  
Reactor Projects Branch 2  
Division of Reactor Projects

Enclosure:  
Specifications for Region II  
Mobile Laboratory

bcc: ✓ NRC Resident Inspector  
Document Control Desk  
State of Georgia

RII  
JHarris  
11/21/85

RII  
WCline  
11/21/85

RII  
DCollins  
11/22/85

RII  
MSinkule  
11/27/85

8512100079 851127  
PDR ADOCK 05000424  
A PDR

110  
IECI

ENCLOSURE

Specification for Region II Mobile Laboratory

<u>Item</u>	<u>Specification</u>	<u>Comment</u>
Vehicle Parking	30 feet long 8 feet wide 14 feet tall	Site should be surfaced and level. Additional clearance for ease of parking should be considered.
Electrical outlets	3 lines with separate circuit breakers each 12 OV, 20A. 3 phase within 25 feet of Mobile Lab. Receptacles to be compatible with Hubbell 125 V, 20 amp three prong twist lock plugs.	Care should be taken to ensure that there are no surges or large fluctuations on these lines.
Telephone outlet	One standard telephone outlet within 25 feet of Mobile Lab.	