



Power Generation Group

Perry Nuclear Power Plant
10 Center Road
Perry, Ohio 44081

Mail Address:
P.O. Box 97
Perry, OH 44081

216-280-5915
FAX: 216-280-8029

Lew W. Myers
Vice President

April 11, 1997
PY-CEI/OEPA-0268L

Ohio Environmental Protection Agency
Division of Surface Water
Enforcement Section, ES/MOR
P.O. Box 1049
Columbus, Ohio 43266-0149

Gentlemen:

Enclosed are the National Pollutant Discharge Elimination System (NPDES) monthly report forms for the month of March, 1997.

No violations occurred during this time period.

If you have questions or require additional information, please contact Ms. Donna Tizzano at (216) 280-5514.

Very truly yours,


DGT:sc

Enclosure

cc: NRC Region III
NRC Resident Inspector
NRC Project Manager
NRC Document Control Desk (Docket No. 50-440)

IR25/1

9704170417 970331
PDR ADOCK 05000440
R PDR



Perry Nuclear Power Plant

31B00016800 MAR 1997

1 1 04/07/97 00634

10 Center Rd.
Perry

14081 Lake

800 INTAKE WATER TO PLANT FROM LAKE ERIE

FORM

Perry-E240

D. G. Tizzano

1
999WATER
TEMP.
F

00011

01	38
02	40
03	40
04	39
05	40
06	40
07	39
08	39
09	38
10	38
11	39
12	39
13	39
14	38
15	39
16	37
17	37
18	37
19	37
20	38
21	38
22	39
23	39
24	38
25	38
26	39
27	39
28	41
29	42
30	42
31	42

1208.0
38.968
42.000
37.000

NONE

REPORTER

4-11-97

Worley for

VP-Nuclear

Perry Nuclear Power Plant

3IB00016004 MAR 1997

1 1 04/07/97 0063

10 Center Rd.
Perry

44081 Lake

004 POINT REP OF DISCHARGE PRIOR TO TUNNEL ENTRY
FORM

Perry-E240

D. G. Tizzano

	1 999	1 999	3 001	3 001	3 001				
	WATER TEMP. F	CONDUIT FLOW MGD	CHLORINE FREE A MG/L	PH S.U.	PHOS-T P-WET MG/L				
01	00011	50050	50064	00400	00665				
02	52	70.1	0						
03	52	71.0	0						
04	53	71.3	0		.06				
05	53	64.8	0	8.2					
06	53	70.1	0						
07	52	76.2	0						
08	50	73.7	0	8.1					
09	51	72.3	0						
10	49	79.0	0						
11	50	80.1	0		.28				
12	51	72.8	0	8.1					
13	51	76.9	0						
14	51	76.7	0						
15	51	80.1	0	8.1					
16	51	78.6	0						
17	50	80.1	0						
18	49	83.3	0		.15				
19	50	79.3	0	8.1					
20	49	74.7	0						
21	49	68.8	0						
22	51	69.3	0	8.0					
23	50	80.1	0						
24	49	80.5	0						
25	50	80.2	0		.10				
26	51	99.5	0	8.1					
27	50	85.2	0						
28	51	79.4	0						
29	52	80.7	0	8.2					
30	53	78.7	0						
31	53	81.0	0						
	53	83.1	0		.20				
	1580.0	2397.6	0.0000	64.900	0.7700				
	50.968	77.342	0.0000	8.1125	0.1540				
	53.000	99.500	0.0000	8.2000	0.2600				
	49.000	64.800	0.0000	8.0000	0.0600				

NONE

REPORTER

4-11-97

S. Wexley for VP-Nuclear

Perry Nuclear Power Plant

31B00016001 MAR 1997

1 1 04/09 97 0023

10 Center Rd
Perry

44081 Lake

001 DISCHARGE FROM REGENERATE NEUTRALIZATION PITS

FORM

Perry-E240

D. G. Tizzano

1	1	1	2	3					
999	999	999	096	001					
CONDUIT FLOW MGD	PH (MAX) S.U.	PH (MIN) S.U.	RESIDU TOT NF MG/L	OIL GR TOTAL MG/L					
50050	00401	00402	00530	00550					
01 AH	AH	AH							
02 AH	AH	AH							
03 AH	AH	AH							
04 AH	AH	AH							
05 .016	7.6	7.6	13	AA					
06 AH	AH	AH							
07 AH	AH	AH							
08 AH	AH	AH							
09 AH	AH	AH							
10 .016	7.5	7.4	10	AA					
11 AH	AH	AH							
12 AH	AH	AH							
13 AH	AH	AH							
14 AH	AH	AH							
15 AH	AH	AH							
16 AH	AH	AH							
17 AH	AH	AH							
18 .013	8.6	8.0	14	AA					
19 AH	AH	AH							
20 AH	AH	AH							
21 AH	AH	AH							
22 AH	AH	AH							
23 AH	AH	AH							
24 .016	7.6	7.4	17	AA					
25 AH	AH	AH							
26 .018	7.9	7.6							
27 AH	AH	AH							
28 AH	AH	AH							
29 .014	7.3	7.3							
30 AH	AH	AH							
31 AH	AH	AH							
0.0930	46.500	45.300	54.000	AA					
0.0155	7.7500	7.5500	13.500	AA					
0.0180	8.6000	8.0000	17.000	AA					
0.0130	7.3000	7.3000	10.000	AA					

AA-BELOW DETECTABLE LIMIT (5MG/L FOR O&G, 2.5 MG/L FOR RESID)
 AH-SAMPLE NOT TAKEN. NO DISCHARGE PERFORMED THIS DATE.
 31B00016001 IS 31B0016601. MORMENU SOFTWARE TO BE CHANGED

REPORTER

4-11-97

Worley

for VP-Nuclear

1 1 04/09 97 0063.

002 Discharge from Chemical Cleaning Lagoon

NOTE: THIS FORM WILL BE USED TO:

D. G. Tizzano

31B000016002 IS 31B00016802. MORMENU SOFTWARE TO BE CHANGED

Wiley for VP-Nuclear