

OPPD

Omaha Public Power District
1623 Harney Omaha, Nebraska 68102-2247
402/536-4000

November 27, 1985
LIC-85-536

Mr. A. Thadani, Project Director
PWR - Directorate #8
Division of PWR - Licensing - B
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

References: (1) Docket No. 50-285
(2) Application for Amendment dated March 30, 1977
(3) Letter OPPD (W. C. Jones) to NRC (R. A. Clark)
dated January 26, 1983 (LIC-83-015)
(4) Letter OPPD (W. C. Jones) to NRC (R. A. Clark)
dated September 2, 1983 (LIC-83-221)

Dear Mr. Thadani:

10 CFR 50 Appendix J Amendment Application

In Reference (3), the Omaha Public Power District submitted changes to Reference (2), concerning 10CFR50 Appendix J. In Reference (3), OPPD provided justification for additional Technical Specification changes, including a change of the allowable containment design base accident leak rate from 0.1% to 0.2% by weight per day.

Since that time, it has been determined that the results of the Fort Calhoun Control Room Habitability study will not support an allowable containment leak rate of 0.2% by weight. Consequently, OPPD hereby resubmits Section 3.5, to maintain the maximum allowable containment leak rate at 0.1% by weight per day.

Additionally, OPPD submitted Reference (4), which contained changes to Section 3.2, Equipment and Sampling Tests. These changes were necessitated by the requested change to the allowable containment leak rate. Since we are withdrawing the requested change to the containment leak rate, we also wish to withdraw the Reference (4) request.


8512100136 851127
PDR ADOCK 05000285
P PDR

Mr. A. Thadani
Page 2
LIC-85-536

Accordingly, forty (40) copies of the revised Section 3.5 are provided here as amendment to Reference (2).

If you should have any questions, please do not hesitate to call.

Sincerely,



R. L. Andrews
Division Manager
Nuclear Production

RLA/AND/me

cc: LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Ave., N.W.
Washington, D.C. 20036

Mr. E. G. Tourigny, NRC Project Manager

Mr. P. H. Harrell, NRC Senior Resident Inspector