

December 2, 1985

Docket Nos: 50-369
and 50-370

Mr. H. B. Tucker, Vice President
Nuclear Production Department
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242

Dear Mr. Tucker:

DISTRIBUTION:

Docket Nos. 50-369/370

NRC PDR

Local PDR

PRC System

LB #4 r/f

EAdensam

MDuncan

DHood

Attorney, OELD

BGrimes

JPartlow

ACRS (16)

Subject: Technical Specification Change Request Regarding Diesel
Generator Reliability, Testing, and Surveillance

Your letter of July 10, 1985 proposed changes to the McGuire technical specifications regarding diesel generator testing and surveillance in five areas: (1) a change to separate the required 24-hour run of the diesel generator from an immediate test of the engineered safety features; (2) changes to action statements to be followed in the event of inoperable electrical power supplies pursuant to Generic Letter 84-15; (3) reduction of required testing, also pursuant to Generic Letter 84-15; (4) deletion of a surveillance requirement pursuant to Generic Letter 83-30; and (5) addition of alternate fuel oil testing criteria.

We are unable to process the proposed changes because of various deficiencies. Your Attachment I, "Proposed Changes to Technical Specification," includes numerous changes which are not flagged by a vertical line in the right-hand margin of the page nor identified elsewhere in text. The specific changes to which the various discussions within Attachment II, "Justification and Safety Evaluation," and Attachment III, "Analysis of Significant Hazards Consideration," are intended to apply are not identified or are only partially identified. The change to Specification 4.8.1.1.2.e.7) would result in an incoherent instruction because it violates parallel sentence construction. The proposed page renumbering would result in an unauthorized deletion of existing Specification 3/4.8.1.2. In Attachment III, the basis for each of the three standards from 10 CFR 50.92(c) should be provided separately and directly for each part of the license amendment request based upon your individual analyses pursuant to 10 CFR 50.91.

Pending a revised submittal correcting the above deficiencies, we propose to take no further action on your request. Contact your Project Manager, Darl Hood, on (301) 492-8408, if you have questions.

Sincerely,

8512100173 851202
PDR ADOCK 05000369
P PDR

B. J. Youngblood, Director
PWR Project Directorate #4
Division of PWR Licensing-A

cc: See next page

PSA
PWR PD #4
DHood/tm/hmc
11/25/85

LA:PWR PD #4
MDuncan
11/26/85

PWR PD #4
BJYoungblood
11/26/85

Mr. H. B. Tucker
Duke Power Company

McGuire Nuclear Station

cc:
Mr. A. Carr
Duke Power Company
P. O. Box 33189
422 South Church Street
Charlotte, North Carolina 28242

Dr. John M. Barry
Department of Environmental Health
Mecklenburg County
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Mr. F. J. Twogood
Power Systems Division
Westinghouse Electric Corp.
P. O. Box 355
Pittsburgh, Pennsylvania 15230

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. Robert Gill
Duke Power Company
Nuclear Production Department
P. O. Box 33189
Charlotte, North Carolina 28242

Chairman, North Carolina Utilities
Commission
Dobbs Building
430 North Salisbury Street
Raleigh, North Carolina 27602

J. Michael McGarry, III, Esq.
Bishop, Liberman, Cook, Purcell
and Reynolds
1200 Seventeenth Street, N.W.
Washington, D. C. 20036

Mr. Dayne H. Brown, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
P.O. Box 12200
Raleigh, North Carolina 27605

Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
Route 4, Box 529
Huntersville, North Carolina 28078

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission,
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

L. L. Williams
Operating Plants Projects
Regional Manager
Westinghouse Electric Corporation - R&D 701
P. O. Box 2728
Pittsburgh, Pennsylvania 15230