

DUB

VIRGINIA ELECTRIC AND POWER COMPANY  
RICHMOND, VIRGINIA 23261

W. L. STEWART  
VICE PRESIDENT  
NUCLEAR OPERATIONS

November 27, 1985

Dr. J. Nelson Grace  
Regional Administrator  
Region II  
U. S. Nuclear Regulatory Commission  
Suite 2900  
101 Marietta St., N.W.  
Atlanta, Georgia 30323

Serial No. 85-626A  
NAPS/JHL:vlh  
Docket Nos. 50-338  
50-339  
License Nos. NPF-4  
NPF-7  
3:34

Dear Dr. Grace:

VIRGINIA ELECTRIC AND POWER COMPANY  
NORTH ANNA POWER STATION UNIT NOS. 1 AND 2  
SUPPLEMENTAL RESPONSE TO NOTICE OF VIOLATION  
NRC INSPECTION REPORT NOS. 50-338/85-18 AND 50-339/85-18

By letter dated October 17, 1985 and in a prior telephone conversation between our staffs, your staff requested supplemental information regarding the Virginia Electric and Power Company (the Company) response to Inspection Report Nos. 50-338/85-18 and 50-339/85-18. The supplemental information provides further details regarding the reason the Company feels that the violation is an isolated event and corrective actions that will be implemented.

The Periodic Test (PT) Program has approximately 1360 periodic test procedures of which approximately 45 are weekly PTs. An initial review by the Performance and Test Group at North Anna revealed that this is an isolated event. The internal scheduling methods used by most departments have proven effective. The one department that missed the weekly PT has begun to use scheduling measures used by other departments.

The Company however is performing an evaluation of the PT scheduling program. In the interim while the scheduling program evaluation is in progress, we have implemented scheduling measures to ensure timely performance of PTs in the affected department. Effective internal department scheduling techniques, including scheduling weekly PTs on a specific day each week, will be incorporated into the administrative procedures for the PT program to provide for uniform scheduling of PTs within station departments. This procedure will be revised by March 31, 1986.


8512100263 851127  
PDR ADOCK 05000338  
Q PDR

1/0  
IE01

VIRGINIA ELECTRIC AND POWER COMPANY TO Dr. J. Nelson Grace

If you have any further questions, please contact me.

Very truly yours,

  
W. L. Stewart

cc: Mr. Roger D. Walker, Director  
Division of Project and Resident Programs

Mr. Edward J. Butcher, Acting Chief  
Operating Reactors Branch No. 3  
Division of Licensing

Mr. M. W. Branch  
NRC Resident Inspector  
North Anna Power Station