

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of

GENERAL PUBLIC UTILITIES NUCLEAR  
CORPORATION

(Three Mile Island Nuclear Station,  
Unit 2)

Docket No. 50-320


CORRECTION TO AMENDMENT OF ORDER

On August 8, 1985, the Director, Nuclear Reactor Regulation, issued an Amendment of Order to be effective September 23, 1985, modifying certain limiting conditions for operation and their corresponding bases in the Proposed Technical Specifications to more correctly reflect the systems or equipment that are necessary, based on the present status of TMI-2. The Director's action was supported by the staff's safety evaluation issued concurrently with the August 8, 1985 Amendment of Order. The changes to the Proposed Technical Specifications, which included the deletion of the closed cycle cooling water systems in Section 3.7.3, contain two errors of an editorial nature. Proposed Technical Specification page 3.7-1 correctly deleted the requirements of Sections 3.7.3.1, 3.7.3.2, and 3.7.3.3, as addressed in the staff's safety evaluation. However, in the revised Proposed Technical Specifications the licensee failed to delete Sections 3.7.3.2 and 3.7.3.3 from page 3.7-2, although these sections had been correctly modified and added to page 3.7-1. On page B 3/4 7-1 of the Proposed Technical Specifications, the licensee neglected to list Section 3/4 7.3.3 MINI DECAY HEAT REMOVAL SYSTEM (MDHRS), which, although correctly deleted as addressed in the safety evaluation and authorized by the Amendment of Order, should nonetheless have been listed on that page.

Unrelated to the actions authorized by the Amendment of Order, the licensee has identified a typographical error contained on page B 3/4 7-1 of the Proposed Technical Specifications. In Section 3/4 7.6 FLOOD PROTECTION, the value 301 ft. should be 302 ft. The correct value, 302 ft., remains unchanged, consistent with the current Proposed Technical Specifications.

Accordingly, the Amendment of Order dated August 8, 1985, is hereby corrected to incorporate the modifications set forth in Enclosure 1 hereto.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in dark ink, appearing to read "Darrell G. Eisenhut", is written over the typed name.

Darrell G. Eisenhut, Deputy Director  
Office of Nuclear Reactor Regulation

Effective Date: September 23, 1985  
Dated at Bethesda, Maryland  
Issuance Date: September 20, 1985

ENCLOSURE 2

LIMITING CONDITIONS FOR OPERATION

---

3.7.4 NUCLEAR SERVICE RIVER WATER SYSTEM

3.7.4.1 Two independent Nuclear Service River Water loops shall be OPERABLE.

APPLICABILITY: RECOVERY MODE.

ACTION:

With one Nuclear Service River Water loop inoperable, restore the inoperable loop to OPERABLE status within 72 hours.

### 3/4.7 PLANT SYSTEMS

#### BASES

---

##### 3/4.7.1 FEEDWATER SYSTEM

Deleted by Amendment of Order Dated April 1, 1982.

##### 3/4.7.2 SECONDARY SERVICES CLOSED COOLING WATER SYSTEM

Deleted.

##### 3/4.7.3 CLOSED CYCLE COOLING WATER SYSTEM

###### 3/4.7.3.1 NUCLEAR SERVICES CLOSED CYCLE COOLING SYSTEM

Deleted.

###### 3/4.7.3.2 DECAY HEAT CLOSED COOLING WATER SYSTEM

Deleted.

###### 3/4.7.3.3 MINI DECAY HEAT REMOVAL SYSTEM (MDHRS)

Deleted.

##### 3/4.7.4 NUCLEAR SERVICE RIVER WATER SYSTEM

The Nuclear Service River Water System uses river water to cool the diesel generators. Therefore, it must be OPERABLE also. This system rejects its heat to the river as the Ultimate Heat Sink.

##### 3/4.7.6 FLOOD PROTECTION

The limitation on flood protection ensures that facility protective actions will be taken in the event of flood conditions. The limit of elevation of 302 ft. Mean Sea Level USGS datum is the elevation at which facility flood control measures are required to be taken to provide protection to Safety Related equipment.

ENCLOSURE 3



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

September 20, 1985

Docket No. 50-320

Docketing and Service Section  
Office of the Secretary of the Commission

SUBJECT: Three Mile Island Unit 2  
Correction to Amendment of Order, Issued August 8, 1985  
(Effective September 23, 1985)

Two signed originals of the Federal Register Notice identified below are enclosed for your transmittal to the Office of the Federal Register for publication. Additional conformed copies ( ) of the Notice are enclosed for your use.

- ☐ Notice of Receipt of Application for Construction Permit(s) and Operating License(s).
- ☐ Notice of Receipt of Partial Application for Construction Permit(s) and Facility License(s): Time for Submission of Views on Antitrust Matters.
- ☐ Notice of Availability of Applicant's Environmental Report.
- ☐ Notice of Proposed Issuance of Amendment to Facility Operating License.
- ☐ Notice of Receipt of Application for Facility License(s); Notice of Availability of Applicant's Environmental Report; and Notice of Consideration of Issuance of Facility License(s) and Notice of Opportunity for Hearing.
- ☐ Notice of Availability of NRC Draft/Final Environmental Statement.
- ☐ Notice of Limited Work Authorization.
- ☐ Notice of Availability of Safety Evaluation Report.
- ☐ Notice of Issuance of Construction Permit(s).
- ☐ Notice of Issuance of Facility Operating License(s) or Amendment(s).
- ☒ Other: Correction to Amendment of Order

*Bernard J. Snyder*

Bernard J. Snyder, Program Director  
Office of Nuclear Reactor Regulation

Enclosure:  
As Stated