

NOV 20 1985

In Reply Refer To:
Docket: 50-313/84-36

Arkansas Power & Light Company
ATTN: John M. Griffin, Senior
Vice President - Energy Supply
P. O. Box 551
Little Rock, Arkansas 72203

Gentlemen:

This refers to the inspection conducted by Mr. J. I. Tapia of this office during the period December 13-15, 1984, and March 28-30, 1985, of activities authorized by NRC Operating License DPR-51 for Arkansas Nuclear One, Unit 1, and to the discussion of our findings with members of your staff at the conclusion of the inspection.

The area examined during the inspection covered the containment integrated leak rate test. Within this area, the inspection consisted of selective examination of procedures and representative records, interviews with personnel, and observations by the inspector. These findings are documented in the enclosed inspection report.

During this inspection, it was found that certain of your activities were in violation of NRC requirements. We have reviewed the actions taken prior to the issuance of this Notice of Violation and find them responsive to the concerns raised. We reviewed the implementation of your corrective actions during the inspection of the Unit 2 Containment Integrated Leakage Rate Test during April 28-30, 1985, and determined that full compliance had been achieved and will be maintained by those actions taken in response to the inspectors concerns expressed during the exit interview on December 15, 1984.

No further response from you concerning this violation is required at this time. The corrective actions taken and subsequent NRC followup are discussed in paragraph 2 of the enclosed inspection report.

for RIV:RSB
JTapia:de
11/18/85

R Ireland
ES RIR
RIRland DHunnicut
11/18/85 11/18/85

AC:RPSB
RSB DHunter
11/19/85 11/19/85

CMS
AC:RPB
LMartin
11/19/85

8512100617 851120
PDR ADOCK 05000313
G PDR

1E01
1/1

We apologize for any inconvenience that may have been caused by late issuance of this report. Should you have any questions concerning this inspection, we will be pleased to discuss them with you.

Sincerely,

Original Signed By
E. H. Johnson

J. E. Martin, Acting Chief
Reactor Projects Branch

Enclosures:

1. Appendix A - Notice of Violation
2. Appendix B - NRC Inspection Report
50-313/84-36

cc w/enclosures:

J. M. Levine, General Manager
Arkansas Nuclear One
P. O. Box 608
Russellville, Arkansas 72801

Arkansas Radiation Control Program Director

bcc to DMB (IE01)

bcc distrib. by RIV:

| | |
|-------------|------------------------|
| *RPB | *Resident Inspector |
| *R&SPB | *Section Chief (RPB/B) |
| *RIV File | E. Johnson, DRS&P |
| *MIS SYSTEM | *RSTS Operator |
| | RSB (ES) |

*w/766

R. D. Martin, RA
*D. Weiss, LFMB (AR-2015)
*RSB
J. Tapia