

March 3, 1986

Docket No. 50-344

DISTRIBUTION

~~Docket File~~

LPDR

PAD-3 Rdg

OELD

K. Johnston

E. Jordan

J. Partlow

NRC PDR

Gray File

H. Thompson

C. Vogan

J.D. Neighbors

B. Grimes

ACRS 10

Mr. Bart D. Withers  
Vice President Nuclear  
Portland General Electric Company  
121 S.W. Salmon Street  
Portland, Oregon 97204

Dear Mr. Withers:

The enclosed report of the NRC pilot audit of your Safety Display Parameter System is forwarded for your information and appropriate action. This audit was conducted at the Trojan Nuclear Plant during the period of August 6-8, 1985.

Please note that the report identifies potential concerns in the areas of system reliability, system testing and operation training. There also appears to be a lack of operator acceptance of the system. We would be happy to meet with you to discuss these and related matters. If you should have any questions, please contact me at (301) 492-8140.

/s/JDNeighbors

Joseph D. Neighbors, Senior Project Manager  
PWR Project Directorate No. 3  
Division of PWR Licensing-A

Enclosure:  
As stated

cc w/enclosure:  
See next page

\*SEE PREVIOUS PAGE FOR CONCURRENCES

PAD-3\*  
CVogan  
02/26/86

PAD-3\*  
KJohnston/pws  
02/26/86

PAD-3\*  
JNeighbors  
03/3/86

D/PAD-3  
SVarga  
03/3/86

8603120349 860303  
PDR ADDCK 05000344  
P PDR

Docket No. 50-344

Mr. Bart D. Withers  
Vice President Nuclear  
Portland General Electric Company  
121 S.W. Salmon Street  
Portland, Oregon 97204

DISTRIBUTION

Docket File	NRC PDR
LPDR	Gray File
PAD-3 Rdg	H. Thompson
OELD	C. Vogan
K. Johnston	J.D. Neighbors
E. Jordan	B. Grimes
J. Partlow	ACRS 10

Dear Mr. Withers:

The enclosed report of the NRC pilot audit of your Safety Display Parameter System is forwarded for your information and appropriate action. This audit was conducted at the Trojan Nuclear Plant during the period of August 6-8, 1985.

Please note that the report identifies potential concerns in the areas of system reliability, system testing and operation training. There also appears to be a lack of operator acceptance of the system. We would be happy to meet with you. If you should have any questions, please contact me at (301) 492-8140.

Joseph D. Neighbors, Senior Project Manager  
PWR Project Directorate No. 3  
Division of PWR Licensing-A

Enclosure:  
As stated

cc w/enclosure:  
See next page

PAD-3  
CVogan  
02/16/86

PAD-3  
KJohnston/pws  
02/16/86

PAD-3  
JDNeighbors  
02/ /86

D/PAD-3  
SVarga  
02/ /86