



# Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

December 2, 1985

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSEE EVENT REPORT 85-032-01  
ER 100450 FILE 841-23  
PLAS- 136

---

Docket No. 50-387  
License No. NPF-14

Reference: PLAS-130

Attached is Licensee Event Report 85-032-01. This event was determined reportable per 10CFR73(a) (2) (iv), in that Reactor Water Cleanup System isolation valves actuated. These valves are containment isolation valves. The actuation of these valves during this event constituted an unplanned, automatic Engineered Safety Feature (ESF) actuation. This revised LER is being submitted, without any text revisions, to incorporate Attachment 1 "Simplified Drawing of the Reactor Water Cleanup System 1A Filter Demineralizer" which was inadvertently excluded on the initial submittal.

T.M. Crimmins, Jr.  
Superintendent of Plant-Susquehanna

DDS/pjg

cc: Dr. Thomas E. Murley  
Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

Mr. R.H. Jacobs  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 52  
Shickshinny, PA 18655

8512110254 851202  
PDR ADOCK 05000387  
S PDR

IE22  
11