

SOUTHERN NUCLEAR OPERATING COMPANY
FARLEY NUCLEAR PLANT UNIT NO. ONE
LICENSE NO. NPF-2
AND
FARLEY NUCLEAR PLANT UNIT NO. TWO
LICENSE NO. NPF-8

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
CALENDAR YEAR 1996

9704280057 970421
PDR ADOCK 05000348
R PDR

FARLEY NUCLEAR PLANT
ANNUAL RADIOACTIVE EFFLUENT
RELEASE REPORT

SECTION	TITLE	PAGE
1.0	INTRODUCTION	1
2.0	LIQUID EFFLUENTS	3
2.1	ODCM Limits	3
2.2	Measurements and Approximation of Total Radioactivity	3
2.3	Abnormal Releases	4
2.4	Batch Releases	4
2.5	Release Summaries	9
2.5.1	Liquid Effluents - Summation of All Releases	9
2.5.2	Liquid Effluents - Continuous and Batch Releases	16
2.6	Radiological Impact	29
3.0	GASEOUS EFFLUENTS	39
3.1	ODCM Limits	39
3.2	Measurements and Approximation of Total Radioactivity	39
3.3	Abnormal Releases	41
3.4	Batch Releases	41

FARLEY NUCLEAR PLANT
ANNUAL RADIOACTIVE EFFLUENT
RELEASE REPORT

SECTION	TITLE	PAGE
3.5	Release Summaries	50
3.5.1	Gaseous Effluents - Summation of All Releases	50
3.5.2	Gaseous Effluents - Mixed Mode Releases	57
3.5.3	Gaseous Effluents - Ground Mode Releases	64
3.6	Radiological Impact	71
4.0	SOLID WASTE	81
5.0	ONSITE DOSES TO MEMBERS OF THE PUBLIC	87
6.0	MISCELLANEOUS	94
6.1	Total Dose From Uranium Fuel Cycle	94
6.2	Licensee Initiated Changes to the ODCM	94
6.3	Program Deviations	94
6.4	Major Changes to the Radwaste Treatment Systems	96

FARLEY NUCLEAR PLANT
ANNUAL RADIOACTIVE EFFLUENT
RELEASE REPORT

TABLE	LIST OF TABLES	PAGE
1-4A	Liquid Effluents - Batch Release Summary, Unit 1	5
1-4B	Liquid Effluents - Batch Release Summary, Unit 2	7
1-1A	Liquid Effluents - Summation of All Releases, Unit 1	10
1-1B	Liquid Effluents - Summation of All Releases, Unit 2	12
1-1C	Liquid Effluents - Summation of All Releases, Site	14
1-2A	Liquid Effluents - Continuous and Batch Releases, Unit 1	17
1-2B	Liquid Effluents - Continuous and Batch Releases, Unit 2	21
1-2C	Liquid Effluents - Continuous and Batch Releases, Site	25
1-3A	Doses to a MEMBER OF THE PUBLIC Due to Liquid Releases, Unit 1	30
1-3B	Doses to a MEMBER OF THE PUBLIC Due to Liquid Releases, Unit 2	32
1-5	Typical Liquid MDC's Achieved on Counting System	34
1-6A	Liquid Effluents - Abnormal Release Summary, Unit 1	35
1-6B	Liquid Effluents - Abnormal Release Summary, Unit 2	37
2-8A	Gaseous Effluents - Abnormal Release Summary, Unit 1	42
2-8B	Gaseous Effluents - Abnormal Release Summary, Unit 2	44
2-6A	Gaseous Effluents - Batch Release Summary, Unit 1	46
2-6B	Gaseous Effluents - Batch Release Summary, Unit 2	48

FARLEY NUCLEAR PLANT
ANNUAL RADIOACTIVE EFFLUENT
RELEASE REPORT

TABLE	LIST OF TABLES	PAGE
2-1A	Gaseous Effluents - Summation of All Releases, Unit 1	51
2-1B	Gaseous Effluents - Summation of All Releases, Unit 2	53
2-1C	Gaseous Effluents - Summation of All Releases, Site	55
2-2A	Gaseous Effluents - Mixed Mode Level Releases, Unit 1	58
2-2B	Gaseous Effluents - Mixed Mode Level Releases, Unit 2	60
2-2C	Gaseous Effluents - Mixed Mode Level Releases, Site	62
2-3A	Gaseous Effluents - Ground Level Releases, Unit 1	65
2-3B	Gaseous Effluents - Ground Level Releases, Unit 2	67
2-3C	Gaseous Effluents - Ground Level Releases, Site	69
2-4A	Air Doses Due to Gaseous Releases, Unit 1	72
2-4B	Air Doses Due to Gaseous Releases, Unit 2	74
2-5A	Doses to a MEMBER OF THE PUBLIC Due to Radioiodines, Tritium, and Particulates in Gaseous Releases, Unit 1	76
2-5B	Doses to a MEMBER OF THE PUBLIC Due to Radioiodines, Tritium, and Particulates in Gaseous Releases, Unit 2	78
2-7	Typical Gaseous MDC's Achieved on Counting System	80
3	Solid Waste and Irradiated Fuel Shipments	82

FARLEY NUCLEAR PLANT
ANNUAL RADIOACTIVE EFFLUENT
RELEASE REPORT

TABLE	LIST OF TABLES	PAGE
4-1	Doses to a MEMBER OF THE PUBLIC Due to Activities Inside the Site Boundary, Site	88

1.0 INTRODUCTION

In accordance with Technical Specification (TS) 6.9.1.8 and 6.9.1.9 and Offsite Dose Calculation Manual (ODCM) 7.2, this Annual Radioactive Effluent Release Report covers the operations of the Farley Nuclear Plant (FNP) during 1996. Information regarding the radioactive liquid and gaseous effluents and solid waste releases are summarized in formats similar to those provided in the Nuclear Regulatory Commission (NRC) Regulatory Guide 1.21, "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light Water Cooled Nuclear Power Plants", Revision 1, June 1974. In addition the report includes required or appropriate information regarding meteorology, dose assessment and other pertinent matters.

Detailed information on liquid effluents is provided in Section 2. The quantities of the radioactive effluents (including any unplanned releases) are summarized on a quarterly basis. A tabulation of the total body and organ doses which were calculated in accordance with ODCM 2.4 are presented to show conformance with the limits of ODCM 2.1.3.

Detailed information on gaseous effluents similar to that for liquid effluents is provided in Section 3. Tabulations are provided of the offsite air doses calculated in accordance with ODCM 3.4.2 to show conformance with the limits of ODCM 3.1.3, and the offsite organ doses to a member of the public calculated in accordance with ODCM 3.4.3 to show conformance with the limits of ODCM 3.1.4.

Detailed information as specified by ODCM 7.2.2.4 on any solid radwastes shipped offsite is provided in Section 4. The data is summarized on a semiannual basis.

Assessments of the doses to members of the public due to their activities inside the site boundary are provided in Section 5. These assessments are performed as specified by ODCM 6.2.

A number of miscellaneous matters are addressed in Section 6. These are matters which require reporting only under certain conditions. The alphabetized list given below includes the conditional matters addressed.

A. An assessment of the radiation doses to the likely most exposed member of the public from reactor releases and other nearby uranium fuel cycle sources to show conformance with 40CFR190, should a determination be required by ODCM 5.1.2.

B. Any licensee initiated changes to the ODCM pursuant to TS 6.14 including changes to the sampling locations in the Radiological Environmental Monitoring Program pursuant to ODCM 4.1.1.2.3 or 4.1.2.2.2, or changes in the location of the controlling dose receptor identified in ODCM 3.4.3 pursuant to ODCM 4.1.2.2.1.

C. Discussions of deviations in the Radioactive Effluent Control Program pursuant to ODCM 7.2.2.6.

D. Any major changes to the liquid or gaseous radwaste treatment systems initiated by the licensee as required by ODCM 2.1.5 and 3.1.6, respectively, or to the solid radwaste treatment system pursuant to the Process Control Program (PCP) App. B section B.4.1.

Meteorological data are retained onsite; these data are available to the NRC upon request. The meteorological data include annual as well as quarterly summaries of hourly measurements of wind speed, wind direction and atmospheric stability in the form of joint frequency distribution tables.

2.0 LIQUID EFFLUENTS

This section contains applicable ODCM limits for liquid effluents as well as the quantities of radioactive liquid effluents released during 1996. These quantities are summarized on a quarterly basis and include any unplanned releases. A tabulation of the total body and organ doses which were calculated in accordance with ODCM 2.4 are presented to show conformance with the limits of ODCM 2.1.3.

2.1 ODCM Limits

In accordance with Technical Specifications 6.8.3.e(ii) and 6.8.3.e(iii), the concentration of radioactive material released in liquid effluents to UNRESTRICTED AREAS (see ODCM Figure 10-1) shall be limited at all times to ten times the concentrations specified in 10CFR20, Appendix B, Table 2, Column 2 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to 1E-04 uCi/ML total activity.

In accordance with Technical Specifications 6.8.3.e(iv) and 6.8.3.e(v), the dose or dose commitment to a MEMBER OF THE PUBLIC from radioactive materials in liquid effluents released, from each unit, to UNRESTRICTED AREAS (see ODCM Figure 10-1) shall be limited:

- a. During any calendar quarter to less than or equal to 1.5 mrem to the total body and to less than or equal to 5 mrem to any organ, and
- b. During any calendar year to less than or equal to 3 mrem to the total body and to less than or equal to 10 mrem to any organ.

2.2 Measurements and Approximation of Total Radioactivity

The radionuclides listed below are considered when evaluating liquid effluents:

MN-54	CS-134
FE-59	CS-137
CO-58	CF 141
CO-60	CE-144
ZN-65	MO-99
SR-89	FE-55
SR-90	H-3
I-131	

Batch Releases: Representative pre-release grab samples are obtained and analyzed in accordance with ODCM Table 2-3. Isotopic analyses are performed using the computerized pulse height analysis system utilizing high resolution germanium detectors. Isotopic values thus obtained are used for release rate calculations as specified in the ODCM. Only those nuclides that are detected are used in the calculations. Strontium analyses prior to October 8, 1996 were performed onsite using chemical separation and a 2 pi gas flow proportional counter. Iron-55 analyses prior to October, 1996 were performed onsite using liquid scintillation techniques. Starting on October 8, 1996 all Strontium and Iron-55 samples were sent offsite to the Georgia Power Environmental Laboratory for analysis. Gross beta and gross alpha determinations are made using 2 pi gas flow proportional counters. Tritium determinations are made using liquid scintillation techniques. Dissolved gases are determined employing grab sampling techniques and then counting on the pulse height analyzer.

Continuous Releases: Continuous releases are analogous to batch releases except that they are analyzed on a weekly composite basis in accordance with ODCM Table 2-3.

The maximum error associated with volume and flow measurements, based upon plant calibration practice is estimated to be + or - 10%. The average error associated with counting is estimated to be less than + or - 15%.

2.3 Abnormal Releases

An abnormal release occurred on Unit 1 during the first half of 1996. On March 28 there was a Steam Generator Blowdown leak inside the Protected Area while a small (0.55 GPD) primary to secondary leak was present. This release is documented in Chemistry Incident Report # 1-96-023.

Abnormal release information for Units 1 and 2 is summarized in the following tables:

Unit 1 1996 Liquid Abnormal Releases : Table 1-6A

Unit 2 1996 Liquid Abnormal Releases : Table 1-6B

2.4 Batch Releases

Batch release information for Units 1 and 2 is summarized in the following tables:

Unit 1 1996 Liquid Batch Releases : Table 1-4A

Unit 2 1996 Liquid Batch Releases : Table 1-4B

TABLE 1-4A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Liquid Effluents - Batch Release Summary
Unit: 1
Starting : 1-Jan-1996 Ending : 30-Jun-1996

LIQUID RELEASES

NUMBER OF BATCH RELEASES	:	384	
TOTAL TIME PERIOD FOR BATCH RELEASES	:	36969.00	MINUTES
MAXIMUM TIME PERIOD FOR A BATCH RELEASE	:	308.00	MINUTES
AVERAGE TIME PERIOD FOR BATCH RELEASES	:	96.27	MINUTES
MINIMUM TIME PERIOD FOR A BATCH RELEASE	:	1.00	MINUTES
AVERAGE STREAM FLOW DURING PERIODS OF RELEASE OF LIQUID EFFLUENT INTO A FLOWING STREAM :		1.58E+04	CFS *

* Average River Flow Rate, taken at Walter F. George Lock and Dam, located 30.7 miles above Farley Nuclear Plant.

TABLE 1-4A
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents - Batch Release Summary
 Unit: 1
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

 LIQUID RELEASES

NUMBER OF BATCH RELEASES	:	273	
TOTAL TIME PERIOD FOR BATCH RELEASES	:	25716.00	MINUTES
MAXIMUM TIME PERIOD FOR A BATCH RELEASE	:	118.00	MINUTES
AVERAGE TIME PERIOD FOR BATCH RELEASES	:	94.20	MINUTES
MINIMUM TIME PERIOD FOR A BATCH RELEASE	:	67.00	MINUTES
AVERAGE STREAM FLOW DURING PERIODS OF RELEASE OF LIQUID EFFLUENT INTO A FLOWING STREAM :		5.81E+03	CFS *

* Average River Flow Rate, taken at Walter F. George Lock and Dam, located 30.7 miles above Farley Nuclear Plant.

TABLE 1-4B
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents - Batch Release Summary
 Unit: 2
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

 LIQUID RELEASES

NUMBER OF BATCH RELEASES	:	142	
TOTAL TIME PERIOD FOR BATCH RELEASES	:	14087.00	MINUTES
MAXIMUM TIME PERIOD FOR A BATCH RELEASE	:	158.00	MINUTES
AVERAGE TIME PERIOD FOR BATCH RELEASES	:	99.20	MINUTES
MINIMUM TIME PERIOD FOR A BATCH RELEASE	:	84.00	MINUTES
AVERAGE STREAM FLOW DURING PERIODS OF RELEASE OF LIQUID EFFLUENT INTO A FLOWING STREAM :		1.58E+04	CFS *

* Average River Flow Rate, taken at Walter F. George Lock and Dam, located 30.7 miles above Farley Nuclear Plant.

TABLE 1-4B
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents - Batch Release Summary
 Unit: 2
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

LIQUID RELEASES

NUMBER OF BATCH RELEASES	:	175	
TOTAL TIME PERIOD FOR BATCH RELEASES	:	17496.00	MINUTES
MAXIMUM TIME PERIOD FOR A BATCH RELEASE	:	120.00	MINUTES
AVERAGE TIME PERIOD FOR BATCH RELEASES	:	99.98	MINUTES
MINIMUM TIME PERIOD FOR A BATCH RELEASE	:	79.00	MINUTES
AVERAGE STREAM FLOW DURING PERIODS OF RELEASE OF LIQUID EFFLUENT INTO A FLOWING STREAM :		5.81E+03	CFS *

* Average River Flow Rate, taken at Walter F. George Lock and Dam, located 30.7 miles above Farley Nuclear Plant.

2.5 Release Summaries

This section contains the summaries of all radioactive liquid effluents released for Units 1 and 2 during 1996. Typical liquid Minimum Detectable Concentrations (MDC'S) for analyses are in Table 1-5 of this section. Regulatory Guide 1.21 Table 2A is found in this report as Tables 1-1A, 1-1B, and 1-1C. Regulatory Guide 1.21 Table 2B is found in this report as Tables 1-2A, 1-2B, and 1-2C.

2.5.1 Liquid Effluents - Summation of All Releases

The summations of all liquid effluent releases are contained in the following tables:

Unit 1 1996 Summation of All Releases : Table 1-1A
Unit 2 1996 Summation of All Releases : Table 1-1B
Site 1996 Summation of All Releases : Table 1-1C

TABLE 1-1A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Liquid Effluents - Summation of All Releases
Unit: 1
Starting : 1-Jan-1996 Ending : 30-Jun-1996

TYPE OF EFFLUENT	UNITS	QUARTER 1	QUARTER 2	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CURIES	2.28E-02	7.47E-03	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	1.41E-09	3.94E-10	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. TRITIUM				

1. TOTAL RELEASE	CURIES	1.30E+02	2.34E+02	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	8.06E-06	1.23E-05	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. DISSOLVED AND ENTRAINED GASES				

1. TOTAL RELEASE	CURIES	8.54E-05	9.02E-04	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	5.28E-12	4.75E-11	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

D. GROSS ALPHA RADIOACTIVITY				

1. TOTAL RELEASE	CURIES	2.55E-05	3.09E-05	2.50E+01

E. WASTE VOL RELEASED (PRE-DILUTION)	LITERS	8.13E+07	8.18E+07	1.00E+01

F. VOLUME OF DILUTION WATER USED	LITERS	1.61E+10	1.89E+10	1.00E+01

* Applicable limits are expressed in terms of dose. See Tables 1-3A and 1-3B of this report.

TABLE 1-1A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Liquid Effluents - Summation of All Releases
Unit: 1
Starting : 1-Jul-1996 Ending : 31-Dec-1996

TYPE OF EFFLUENT	UNITS	QUARTER 3	QUARTER 4	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CURIES	7.65E-03	2.55E-02	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	4.24E-10	1.48E-09	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. TRITIUM				

1. TOTAL RELEASE	CURIES	1.60E+02	1.39E+02	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	8.87E-06	8.07E-06	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. DISSOLVED AND ENTRAINED GASES				

1. TOTAL RELEASE	CURIES	6.01E-04	2.04E-04	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	3.33E-11	1.19E-11	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

D. GROSS ALPHA RADIOACTIVITY				

1. TOTAL RELEASE	CURIES	1.52E-05	3.01E-05	2.50E+01

E. WASTE VOL RELEASED (PRE-DILUTION)	LITERS	8.22E+07	8.35E+07	1.00E+01

F. VOLUME OF DILUTION WATER USED	LITERS	1.80E+10	1.71E+10	1.00E+01

* Applicable limits are expressed in terms of dose. See Tables 1-3A and 1-3B of this report.

TABLE 1-1B
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents - Summation of All Releases
 Unit: 2
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

TYPE OF EFFLUENT	UNITS	QUARTER 1	QUARTER 2	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CURIES	1.21E-02	3.15E-03	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	7.47E-10	1.82E-10	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. TRITIUM				

1. TOTAL RELEASE	CURIES	2.51E+02	2.68E+02	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	1.54E-05	1.55E-05	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. DISSOLVED AND ENTRAINED GASES				

1. TOTAL RELEASE	CURIES	1.62E-04	5.57E-03	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	9.96E-12	3.21E-10	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

D. GROSS ALPHA RADIOACTIVITY				

1. TOTAL RELEASE	CURIES	1.44E-05	7.09E-06	2.50E+01

E. WASTE VOL RELEASED(PRE-DILUTION)	LITERS	7.74E+07	7.30E+07	1.00E+01

F. VOLUME OF DILUTION WATER USED	LITERS	1.62E+10	1.73E+10	1.00E+01

* Applicable limits are expressed in terms of dose. See Tables 1-3A and 1-3B of this report.

TABLE 1-1B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Liquid Effluents - Summation of All Releases
Unit: 2
Starting : 1-Jul-1996 Ending : 31-Dec-1996

TYPE OF EFFLUENT	UNITS	QUARTER 3	QUARTER 4	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CURIES	1.19E-02	3.64E-02	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	6.46E-10	2.45E-09	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. TRITIUM				

1. TOTAL RELEASE	CURIES	2.03E+02	1.37E+02	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	1.11E-05	9.23E-06	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. DISSOLVED AND ENTRAINED GASES				

1. TOTAL RELEASE	CURIES	8.53E-04	4.45E-04	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	4.65E-11	2.99E-11	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

D. GROSS ALPHA RADIOACTIVITY				

1. TOTAL RELEASE	CURIES	7.18E-06	7.18E-06	2.50E+01

E. WASTE VOL RELEASED(PRE-DILUTION)	LITERS	7.68E+07	4.41E+07	1.00E+01

F. VOLUME OF DILUTION WATER USED	LITERS	1.83E+10	1.48E+10	1.00E+01

* Applicable limits are expressed in terms of dose. See Tables
1-3A and 1-3B of this report.

TABLE 1-1C
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Liquid Effluents - Summation of All Releases
Unit: Site
Starting : 1-Jan-1996 Ending : 30-Jun-1996

TYPE OF EFFLUENT	UNITS	QUARTER 1	QUARTER 2	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CURIES	3.49E-02	1.06E-02	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	1.08E-09	2.93E-10	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. TRITIUM				

1. TOTAL RELEASE	CURIES	3.81E+02	5.02E+02	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	1.17E-05	1.38E-05	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. DISSOLVED AND ENTRAINED GASES				

1. TOTAL RELEASE	CURIES	2.47E-04	6.47E-03	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	7.63E-12	1.78E-10	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

D. GROSS ALPHA RADIOACTIVITY				

1. TOTAL RELEASE	CURIES	3.99E-05	3.80E-05	2.50E+01

E. WASTE VOL RELEASED(PRE-DILUTION)	LITERS	1.59E+08	1.55E+08	1.00E+01

F. VOLUME OF DILUTION WATER USED	LITERS	3.23E+10	3.62E+10	1.00E+01

* Applicable limits are expressed in terms of dose. See Tables 1-3A and 1-3B of this report.

TABLE 1-1C
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Liquid Effluents - Summation of All Releases
Unit: Site
Starting : 1-Jul-1996 Ending : 31-Dec-1996

TYPE OF EFFLUENT	UNITS	QUARTER 3	QUARTER 4	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE (NOT INCLUDING TRITIUM, GASES, ALPHA)	CURIES	1.95E-02	6.19E-02	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	5.36E-10	1.93E-09	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. TRITIUM				

1. TOTAL RELEASE	CURIES	3.64E+02	2.76E+02	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	9.99E-06	8.61E-06	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. DISSOLVED AND ENTRAINED GASES				

1. TOTAL RELEASE	CURIES	1.45E-03	6.49E-04	2.50E+01

2. AVERAGE DILUTED CONCENTRATION DURING PERIOD	uCi/ML	4.00E-11	2.02E-11	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

D. GROSS ALPHA RADIOACTIVITY				

1. TOTAL RELEASE	CURIES	2.24E-05	3.72E-05	2.50E+01

E. WASTE VOL RELEASED (PRE-DILUTION)	LITERS	1.59E+08	1.28E+08	1.00E+01

F. VOLUME OF DILUTION WATER USED	LITERS	3.62E+10	3.19E+10	1.00E+01

* Applicable limits are expressed in terms of dose. See Tables 1-3A and 1-3B of this report.

2.5.2 Liquid Effluents - Continuous and Batch Releases

The continuous and batch release summaries of all liquid effluent releases (includes listing by nuclide) are contained in the following tables:

Unit 1 1996 Continuous and Batch Releases : Table 1-2A
Unit 2 1996 Continuous and Batch Releases : Table 1-2B
Site 1996 Continuous and Batch Releases : Table 1-2C

TABLE 1-2A*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents
 Unit: 1
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

NUCLIDE	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
H-3	CURIES	2.32E-01	3.06E-01	1.30E+02	2.34E+02

FISSION & ACTIVATION PRODUCTS

AG-110M	CURIES	0.00E+00	0.00E+00	2.52E-03	1.98E-05
CE-144	CURIES	0.00E+00	0.00E+00	0.00E+00	5.80E-06
CO-57	CURIES	0.00E+00	0.00E+00	1.35E-05	8.10E-06
CO-58	CURIES	0.00E+00	0.00E+00	6.19E-03	1.22E-03
CO-60	CURIES	0.00E+00	0.00E+00	5.20E-03	1.65E-03
CR-51	CURIES	0.00E+00	0.00E+00	5.77E-04	0.00E+00
CS-134	CURIES	0.00E+00	0.00E+00	4.71E-04	3.03E-04
CS-137	CURIES	0.00E+00	0.00E+00	1.44E-03	1.06E-03
FE-55	CURIES	1.85E-03	4.27E-04	2.12E-03	2.06E-03
I-131	CURIES	0.00E+00	0.00E+00	5.88E-07	1.19E-06
MN-54	CURIES	0.00E+00	0.00E+00	4.10E-04	1.43E-04
NB-95	CURIES	0.00E+00	0.00E+00	5.50E-04	3.31E-05
NB-95M	CURIES	0.00E+00	0.00E+00	0.00E+00	8.37E-07
NB-97	CURIES	0.00E+00	0.00E+00	2.61E-04	1.78E-04
PM-149	CURIES	0.00E+00	0.00E+00	0.00E+00	1.56E-05
RH-106	CURIES	0.00E+00	0.00E+00	2.56E-05	0.00E+00
RU-106	CURIES	0.00E+00	0.00E+00	2.56E-05	0.00E+00
SB-122	CURIES	0.00E+00	0.00E+00	1.83E-06	3.58E-06
SB-125	CURIES	0.00E+00	0.00E+00	8.66E-04	2.69E-04
SN-113	CURIES	0.00E+00	0.00E+00	2.08E-05	0.00E+00
SR-85	CURIES	0.00E+00	0.00E+00	0.00E+00	6.26E-07
SR-89	CURIES	5.46E-11	1.07E-10	1.50E-05	1.89E-05
SR-90	CURIES	2.14E-11	1.27E-11	5.29E-07	2.92E-05
SR-92	CURIES	0.00E+00	0.00E+00	1.47E-05	0.00E+00
TC-99M	CURIES	0.00E+00	0.00E+00	3.89E-07	1.69E-06
ZN-65	CURIES	0.00E+00	0.00E+00	1.71E-05	1.14E-05
ZR-95	CURIES	0.00E+00	0.00E+00	1.96E-04	1.83E-06
TOTALS	CURIES	1.85E-03	4.27E-04	2.09E-02	7.04E-03

TABLE 1-2A*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents
 Unit: 1
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDE	UNIT	QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
DISSOLVED AND ENTRAINED GASES					
KR-85	CURIES	0.00E+00	0.00E+00	0.00E+00	1.43E-04
KR-85M	CURIES	0.00E+00	0.00E+00	3.86E-07	0.00E+00
XE-133	CURIES	0.00E+00	0.00E+00	8.50E-05	7.54E-04
XE-133M	CURIES	0.00E+00	0.00E+00	0.00E+00	2.21E-06
XE-135	CURIES	0.00E+00	0.00E+00	0.00E+00	2.08E-06
TOTALS	CURIES	0.00E+00	0.00E+00	8.54E-05	9.02E-04
G-ALPHA	CURIES	4.37E-11	7.28E-11	2.55E-05	3.09E-05

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 1-5 for typical minimum detectable concentrations.

TABLE 1-2A*
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Liquid Effluents
Unit: 1
Starting : 1-Jul-1996 Ending : 31-Dec-1996

NUCLIDE	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
H-3	CURIES	1.54E-01	1.75E-01	1.60E+02	1.38E+02

FSSION & ACTIVATION PRODUCTS

AG-110M	CURIES	0.00E+00	0.00E+00	4.68E-05	3.92E-04
CO-57	CURIES	0.00E+00	0.00E+00	7.75E-06	2.97E-05
CO-58	CURIES	0.00E+00	0.00E+00	9.08E-04	1.41E-02
CO-60	CURIES	0.00E+00	0.00E+00	2.04E-03	3.41E-03
CR-51	CURIES	0.00E+00	0.00E+00	0.00E+00	1.25E-04
CS-134	CURIES	0.00E+00	0.00E+00	2.09E-04	3.27E-05
CS-136	CURIES	0.00E+00	0.00E+00	8.38E-06	0.00E+00
CS-137	CURIES	0.00E+00	0.00E+00	8.53E-04	3.68E-04
FE-55	CURIES	2.33E-09	6.52E-09	2.16E-03	4.01E-03
I-131	CURIES	0.00E+00	0.00E+00	2.26E-05	0.00E+00
I-133	CURIES	0.00E+00	1.42E-03	4.52E-05	0.00E+00
MN-54	CURIES	0.00E+00	0.00E+00	1.43E-04	1.93E-04
MO-99	CURIES	0.00E+00	0.00E+00	3.10E-05	0.00E+00
NA-24	CURIES	0.00E+00	0.00E+00	1.70E-05	0.00E+00
NB-95	CURIES	0.00E+00	0.00E+00	1.14E-05	1.59E-04
NB-97	CURIES	0.00E+00	0.00E+00	1.10E-04	5.03E-05
PR-144	CURIES	0.00E+00	0.00E+00	1.01E-04	0.00E+00
SB-122	CURIES	0.00E+00	0.00E+00	1.11E-06	7.09E-07
SB-124	CURIES	0.00E+00	0.00E+00	0.00E+00	8.19E-05
SB-125	CURIES	0.00E+00	0.00E+00	8.12E-04	9.06E-04
SN-113	CURIES	0.00E+00	0.00E+00	7.60E-07	0.00E+00
SR-89	CURIES	1.14E-10	2.91E-11	1.58E-05	1.84E-05
SR-90	CURIES	1.27E-11	2.00E-11	4.10E-06	3.65E-06
SR-92	CURIES	0.00E+00	0.00E+00	4.26E-06	2.74E-06
TC-99M	CURIES	0.00E+00	0.00E+00	5.76E-05	0.00E+00
TN-65	CURIES	0.00E+00	0.00E+00	3.52E-05	7.96E-05
ZR-95	CURIES	0.00E+00	0.00E+00	0.00E+00	5.78E-05
TOTALS	CURIES	2.45E-09	1.42E-03	7.65E-03	2.41E-02

TABLE 1-2A*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents
 Unit: 1
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDE	UNIT	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
DISSOLVED AND ENTRAINED GASES					
XE-133	CURIES	0.00E+00	0.00E+00	5.96E-04	2.04E-04
XE-135	CURIES	0.00E+00	0.00E+00	5.11E-06	5.53E-07
TOTALS	CURIES	0.00E+00	0.00E+00	6.01E-04	2.04E-04
G-ALPHA	CURIES	3.82E-11	9.09E-11	1.52E-05	3.01E-05

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 1-5 for typical minimum detectable concentrations.

TABLE 1-2B*
 Josep arley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents
 Unit: 2
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDE	UNIT	QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
H-3	CURIES	7.79E-02	1.19E-06	2.50E+02	2.68E+02

FISSION & ACTIVATION PRODUCTS

AG-110M	CURIES	0.00E+00	0.00E+00	4.24E-04	3.32E-06
CO-57	CURIES	0.00E+00	0.00E+00	2.35E-05	5.78E-06
CO-58	CURIES	0.00E+00	0.00E+00	2.12E-03	3.92E-04
CO-60	CURIES	0.00E+00	0.00E+00	2.32E-03	5.82E-04
CR-51	CURIES	0.00E+00	0.00E+00	1.39E-04	4.61E-06
CS-134	CURIES	0.00E+00	0.00E+00	4.93E-04	4.35E-04
CS-137	CURIES	0.00E+00	0.00E+00	1.36E-03	1.24E-03
FE-55	CURIES	1.71E-03	3.65E-05	6.12E-04	3.22E-04
MN-54	CURIES	0.00E+00	0.00E+00	1.69E-04	9.48E-06
NB-95	CURIES	0.00E+00	0.00E+00	2.28E-04	1.99E-06
NB-97	CURIES	0.00E+00	0.00E+00	1.17E-04	2.00E-05
PR-144	CURIES	0.00E+00	0.00E+00	2.13E-04	0.00E+00
RU-103	CURIES	0.00E+00	0.00E+00	0.00E+00	2.25E-06
SB-122	CURIES	0.00E+00	0.00E+00	1.80E-06	3.78E-06
SB-124	CURIES	0.00E+00	0.00E+00	8.66E-05	0.00E+00
SB-125	CURIES	0.00E+00	0.00E+00	1.82E-03	3.95E-05
SR-85	CURIES	0.00E+00	0.00E+00	0.00E+00	1.63E-05
SR-89	CURIES	1.29E-10	1.02E-10	9.91E-06	4.89E-06
SR-90	CURIES	6.59E-12	7.73E-12	2.83E-07	1.40E-07
SR-92	CURIES	0.00E+00	0.00E+00	1.11E-05	0.00E+00
Y-91M	CURIES	0.00E+00	0.00E+00	0.00E+00	8.21E-07
ZN-65	CURIES	0.00E+00	0.00E+00	2.14E-04	3.74E-05
ZR-95	CURIES	0.00E+00	0.00E+00	6.03E-05	0.00E+00
TOTALS	CURIES	1.71E-03	3.65E-05	1.04E-02	3.12E-03

TABLE 1-2B*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents
 Unit: 2
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDE	UNIT	QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
DISSOLVED AND ENTRAINED GASES					
KR-85	CURIES	0.00E+00	0.00E+00	0.00E+00	3.73E-03
XE-133	CURIES	0.00E+00	0.00E+00	1.57E-04	1.83E-03
XE-135	CURIES	0.00E+00	0.00E+00	4.79E-06	4.71E-06
TOTALS	CURIES	0.00E+00	0.00E+00	1.62E-04	5.57E-03
G-ALPHA	CURIES	1.27E-11	1.27E-11	1.44E-05	7.09E-06

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 1-5 for typical minimum detectable concentrations.

TABLE 1-2B*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents
 Unit: 2
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDE	UNIT	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
H-3	CURIES	2.80E-06	3.54E-07	2.03E+02	1.37E+02

FISSION & ACTIVATION PRODUCTS

AG-110M	CURIES	0.00E+00	0.00E+00	3.81E-04	3.03E-04
BE-7	CURIES	0.00E+00	0.00E+00	3.92E-04	7.14E-06
CO-57	CURIES	0.00E+00	0.00E+00	1.50E-05	5.21E-05
CO-58	CURIES	0.00E+00	0.00E+00	6.91E-04	2.66E-02
CO-60	CURIES	0.00E+00	0.00E+00	2.18E-03	2.72E-03
CR-51	CURIES	0.00E+00	0.00E+00	8.38E-06	1.03E-03
CS-134	CURIES	0.00E+00	0.00E+00	6.66E-04	2.76E-05
CS-137	CURIES	0.00E+00	0.00E+00	2.05E-03	2.75E-04
FE-55	CURIES	3.84E-09	1.02E-03	1.19E-03	1.92E-03
FE-59	CURIES	0.00E+00	0.00E+00	0.00E+00	3.37E-05
I-130	CURIES	0.00E+00	0.00E+00	0.00E+00	4.19E-05
MN-54	CURIES	0.00E+00	0.00E+00	6.00E-05	9.65E-05
NB-95	CURIES	0.00E+00	0.00E+00	4.09E-06	2.12E-05
NB-97	CURIES	0.00E+00	0.00E+00	5.47E-05	1.39E-04
SB-122	CURIES	0.00E+00	0.00E+00	1.63E-06	0.00E+00
SB-124	CURIES	0.00E+00	0.00E+00	0.00E+00	2.47E-04
SB-125	CURIES	0.00E+00	0.00E+00	3.80E-03	1.39E-03
SR-89	CURIES	6.00E-11	3.69E-11	4.95E-06	4.95E-06
SR-90	CURIES	1.11E-11	2.01E-05	1.02E-06	1.42E-07
SR-92	CURIES	0.00E+00	0.00E+00	3.05E-06	9.06E-06
TE-125M	CURIES	0.00E+00	0.00E+00	0.00E+00	1.07E-04
TE-132	CURIES	0.00E+00	0.00E+00	2.38E-06	0.00E+00
ZN-65	CURIES	0.00E+00	0.00E+00	3.51E-04	3.98E-04
TOTALS	CURIES	3.91E-09	1.04E-03	1.19E-02	3.54E-02

TABLE 1-2B*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents
 Unit: 2
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDE	UNIT	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
DISSOLVED AND ENTRAINED GASES					
XE-133	CURIES	0.00E+00	0.00E+00	8.52E-04	4.44E-04
XE-135	CURIES	0.00E+00	0.00E+00	7.43E-07	1.11E-06
TOTALS	CURIES	0.00E+00	0.00E+00	8.53E-04	4.45E-04
G-ALPHA	CURIES	4.14E-11	6.39E-12	7.18E-06	7.18E-06

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 1-5 for typical minimum detectable concentrations.

TABLE 1-2C*
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Liquid Effluents
Unit: Site
Starting : 1-Jan-1996 Ending : 30-Jun-1996

NUCLIDE	UNIT	CONTINUOUS MODE		BATCH MODE	
		QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
H-3	CURIES	3.10E-01	3.06E-01	3.81E+02	5.02E+02

FISSION & ACTIVATION PRODUCTS

AG-110M	CURIES	0.00E+00	0.00E+00	2.94E-03	2.31E-05
CE-144	CURIES	0.00E+00	0.00E+00	0.00E+00	5.80E-06
CC-57	CURIES	0.00E+00	0.00E+00	3.70E-05	1.39E-05
CO-58	CURIES	0.00E+00	0.00E+00	8.31E-03	1.61E-03
CO-60	CURIES	0.00E+00	0.00E+00	7.51E-03	2.24E-03
CR-51	CURIES	0.00E+00	0.00E+00	7.16E-04	4.61E-06
CS-134	CURIES	0.00E+00	0.00E+00	9.64E-04	7.38E-04
CS-137	CURIES	0.00E+00	0.00E+00	2.80E-03	2.30E-03
FE-55	CURIES	3.57E-03	4.63E-04	2.73E-03	2.39E-03
I-131	CURIES	0.00E+00	0.00E+00	5.88E-07	1.19E-06
MN-54	CURIES	0.00E+00	0.00E+00	5.79E-04	1.53E-04
NB-95	CURIES	0.00E+00	0.00E+00	7.78E-04	3.51E-05
NB-95M	CURIES	0.00E+00	0.00E+00	0.00E+00	8.37E-07
NB-97	CURIES	0.00E+00	0.00E+00	3.78E-04	1.98E-04
PM-149	CURIES	0.00E+00	0.00E+00	0.00E+00	1.56E-05
PR-144	CURIES	0.00E+00	0.00E+00	2.13E-04	0.00E+00
RH-106	CURIES	0.00E+00	0.00E+00	2.56E-05	0.00E+00
RU-103	CURIES	0.00E+00	0.00E+00	0.00E+00	2.25E-06
RU-106	CURIES	0.00E+00	0.00E+00	2.56E-05	0.00E+00
SB-122	CURIES	0.00E+00	0.00E+00	3.63E-06	7.36E-06
SB-124	CURIES	0.00E+00	0.00E+00	8.66E-05	0.00E+00
SB-125	CURIES	0.00E+00	0.00E+00	2.69E-03	3.08E-04
SN-113	CURIES	0.00E+00	0.00E+00	2.08E-05	0.00E+00
SR-85	CURIES	0.00E+00	0.00E+00	0.00E+00	1.70E-05
SR-89	CURIES	1.84E-10	2.09E-10	2.49E-05	2.38E-05
SR-90	CURIES	2.80E-11	2.05E-11	8.12E-07	2.94E-05
SR-92	CURIES	0.00E+00	0.00E+00	2.58E-05	0.00E+00
TC-99M	CURIES	0.00E+00	0.00E+00	3.89E-07	1.69E-06
Y-91M	CURIES	0.00E+00	0.00E+00	0.00E+00	8.21E-07
ZN-65	CURIES	0.00E+00	0.00E+00	2.31E-04	4.88E-05
ZR-95	CURIES	0.00E+00	0.00E+00	2.57E-04	1.83E-06
TOTALS	CURIES	3.57E-03	4.63E-04	3.14E-02	1.02E-02

TABLE 1-2C*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents
 Unit: Site
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDE	UNIT	QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
DISSOLVED AND ENTRAINED GASES					
KR-85	CURIES	0.00E+00	0.00E+00	0.00E+00	3.88E-03
KR-85M	CURIES	0.00E+00	0.00E+00	3.86E-07	0.00E+00
XE-133	CURIES	0.00E+00	0.00E+00	2.42E-04	2.58E-03
XE-133M	CURIES	0.00E+00	0.00E+00	0.00E+00	2.21E-06
XE-135	CURIES	0.00E+00	0.00E+00	4.79E-06	6.79E-06
TOTALS	CURIES	0.00E+00	0.00E+00	2.47E-04	6.47E-03
G-ALPHA	CURIES	5.64E-11	8.55E-11	3.99E-05	3.80E-05

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 1-5 for typical minimum detectable concentrations.

TABLE 1-2C*
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Liquid Effluents
Unit: Site
Starting : 1-Jul-1996 Ending : 31-Dec-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDE	UNIT	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
H-3	CURIES	1.54E-01	1.75E-01	3.63E+02	2.76E+02

FISSION & ACTIVATION PRODUCTS

AG-110M	CURIES	0.00E+00	0.00E+00	4.28E-04	6.95E-04
BE-7	CURIES	0.00E+00	0.00E+00	3.92E-04	7.14E-06
CO-57	CURIES	0.00E+00	0.00E+00	2.28E-05	8.18E-05
CO-58	CURIES	0.00E+00	0.00E+00	1.60E-03	4.07E-02
CO-60	CURIES	0.00E+00	0.00E+00	4.23E-03	6.13E-03
CR-51	CURIES	0.00E+00	0.00E+00	8.38E-06	1.15E-03
CS-134	CURIES	0.00E+00	0.00E+00	8.75E-04	6.02E-05
CS-136	CURIES	0.00E+00	0.00E+00	8.38E-06	0.00E+00
CS-137	CURIES	0.00E+00	0.00E+00	2.90E-03	6.42E-04
FE-55	CURIES	6.17E-09	1.02E-03	5.35E-03	5.93E-03
FE-59	CURIES	0.00E+00	0.00E+00	0.00E+00	3.37E-05
I-130	CURIES	0.00E+00	0.00E+00	0.00E+00	4.19E-05
I-131	CURIES	0.00E+00	0.00E+00	2.26E-05	0.00E+00
I-133	CURIES	0.00E+00	1.42E-03	4.52E-05	0.00E+00
MN-54	CURIES	0.00E+00	0.00E+00	2.03E-04	2.89E-04
MO-99	CURIES	0.00E+00	0.00E+00	3.10E-05	0.00E+00
NA-24	CURIES	0.00E+00	0.00E+00	1.70E-05	0.00E+00
NB-95	CURIES	0.00E+00	0.00E+00	1.55E-05	1.80E-04
NB-97	CURIES	0.00E+00	0.00E+00	1.64E-04	1.90E-04
PR-144	CURIES	0.00E+00	0.00E+00	1.01E-04	0.00E+00
SB-122	CURIES	0.00E+00	0.00E+00	2.75E-06	7.09E-07
SB-124	CURIES	0.00E+00	0.00E+00	0.00E+00	3.29E-04
SB-125	CURIES	0.00E+00	0.00E+00	4.61E-03	2.29E-03
SN-113	CURIES	0.00E+00	0.00E+00	7.60E-07	0.00E+00
SR-89	CURIES	1.74E-10	6.61E-11	2.08E-05	2.34E-05
SR-90	CURIES	2.39E-11	2.01E-05	5.13E-06	3.79E-06
SR-92	CURIES	0.00E+00	0.00E+00	7.31E-06	1.18E-05
TC-99M	CURIES	0.00E+00	0.00E+00	5.76E-05	0.00E+00
TE-125M	CURIES	0.00E+00	0.00E+00	0.00E+00	1.07E-04
TE-132	CURIES	0.00E+00	0.00E+00	2.38E-06	0.00E+00
ZN-65	CURIES	0.00E+00	0.00E+00	3.86E-04	4.78E-04

TABLE 1-2C*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents
 Unit: Site
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDE	UNIT	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4

FISSION & ACTIVATION PRODUCTS

ZR-95	CURIES	0.00E+00	0.00E+00	0.00E+00	5.78E-05
TOTALS	CURIES	6.37E-09	2.46E-03	1.95E-02	5.95E-02

DISSOLVED AND ENTRAINED GASES

XE-133	CURIES	0.00E+00	0.00E+00	1.45E-03	6.47E-04
XE-135	CURIES	0.00E+00	0.00E+00	5.86E-03	1.66E-06
TOTALS	CURIES	0.00E+00	0.00E+00	1.45E-03	6.49E-04
G-ALPHA	CURIES	7.96E-11	9.73E-11	2.24E-05	3.72E-05

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 1-5 for typical minimum detectable concentrations.

2.6 Radiological Impact

The total body and organ doses for Units 1 and 2 are provided in the following tables in order to show conformance with the limits of ODCM 2.1.3 :

Unit 1 1996 Liquid Doses : Table 1-3A

Unit 2 1996 Liquid Doses : Table 1-3B

TABLE 1-3A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSES TO A MEMBER OF THE PUBLIC DUE TO LIQUID RELEASES
Unit: 1
Starting: 01-Jan-1996 Ending: 30-Jun-1996

Cumulative Doses per Quarter

Organ	ODCM Limit	Units	Quarter 1	% of ODCM Limit	Quarter 2	% of ODCM Limit
Bone	5.0	mrem	2.96E-03	5.92E-02	2.34E-03	4.68E-02
Liver	5.0	mrem	4.95E-03	9.90E-02	4.18E-03	8.35E-02
TBody	1.5	mrem	3.69E-03	2.46E-01	3.43E-03	2.28E-01
Thyroid	5.0	mrem	1.00E-03	2.00E-02	1.66E-03	3.31E-02
Kidney	5.0	mrem	2.09E-03	4.19E-02	2.38E-03	4.76E-02
Lung	5.0	mrem	5.98E-03	1.20E-01	3.35E-03	6.69E-02
GILLI	5.0	mrem	4.14E-03	8.29E-02	2.59E-03	5.17E-02

Cumulative Doses per Year

Organ	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Bone	10.0	mrem	5.30E-03	5.30E-02
Liver	10.0	mrem	9.12E-03	9.12E-02
TBody	3.0	mrem	7.12E-03	2.37E-01
Thyroid	10.0	mrem	2.66E-03	2.66E-02
Kidney	10.0	mrem	4.48E-03	4.48E-02
Lung	10.0	mrem	9.33E-03	9.33E-02
GILLI	10.0	mrem	6.73E-03	6.73E-02

TABLE 1-3A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSES TO A MEMBER OF THE PUBLIC DUE TO LIQUID RELEASES
Unit: 1
Starting: 01-Jul-1996 Ending: 31-Dec-1996

Cumulative Doses per Quarter

Organ	ODCM Limit	Units	Quarter 3	% of ODCM Limit	Quarter 4	% of ODCM Limit
Bone	5.0	mrem	1.57E-03	3.15E-02	1.30E-03	2.60E-02
Liver	5.0	mrem	3.07E-03	6.15E-02	2.28E-03	4.56E-02
TBody	1.5	mrem	2.43E-03	1.62E-01	1.84E-03	1.23E-01
Thyroid	5.0	mrem	1.18E-03	2.37E-02	1.35E-03	2.70E-02
Kidney	5.0	mrem	1.68E-03	3.35E-02	1.23E-03	2.46E-02
Lung	5.0	mrem	5.28E-03	1.06E-01	5.78E-03	1.16E-01
GILLI	5.0	mrem	2.28E-03	4.55E-02	4.28E-03	8.56E-02

Cumulative Doses per Year

Organ	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Bone	10.0	mrem	8.18E-03	8.18E-02
Liver	10.0	mrem	1.45E-02	1.45E-01
TBody	3.0	mrem	1.14E-02	3.80E-01
Thyroid	10.0	mrem	5.19E-03	5.19E-02
Kidney	10.0	mrem	7.38E-03	7.38E-02
Lung	10.0	mrem	2.04E-02	2.04E-01
GILLI	10.0	mrem	1.33E-02	1.33E-01

TABLE 1-3B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSES TO A MEMBER OF THE PUBLIC DUE TO LIQUID RELEASES
Unit: 2
Starting: 01-Jan-1996 Ending: 30-Jun-1996

Cumulative Doses per Quarter

Organ	ODCM Limit	Units	Quarter 1	% of ODCM Limit	Quarter 2	% of ODCM Limit
Bone	5.0	mrem	2.50E-03	4.99E-02	2.27E-02	4.54E-01
Liver	5.0	mrem	5.30E-03	1.06E-01	1.67E-02	3.33E-01
TBody	1.5	mrem	4.22E-03	2.81E-01	7.60E-03	5.07E-01
Thyroid	5.0	mrem	1.84E-03	3.67E-02	2.20E-03	4.40E-02
Kidney	5.0	mrem	2.88E-03	5.76E-02	3.07E-03	6.15E-02
Lung	5.0	mrem	1.09E-02	2.17E-01	9.30E-03	1.86E-01
GILLI	5.0	mrem	3.85E-03	7.71E-02	9.50E-03	1.90E-01

Cumulative Doses per Year

Organ	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Bone	10.0	mrem	2.52E-02	2.52E-01
Liver	10.0	mrem	2.20E-02	2.20E-01
TBody	3.0	mrem	1.18E-02	3.94E-01
Thyroid	10.0	mrem	4.04E-03	4.04E-02
Kidney	10.0	mrem	5.95E-03	5.95E-02
Lung	10.0	mrem	2.02E-02	2.02E-01
GILLI	10.0	mrem	1.34E-02	1.34E-01

TABLE 1-3B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSES TO A MEMBER OF THE PUBLIC DUE TO LIQUID RELEASES
Unit: 2
Starting: 01-Jul-1996 Ending: 31-Dec-1996

Cumulative Doses per Quarter

Organ	ODCM Limit	Units	Quarter 3	% of ODCM Limit	Quarter 4	% of ODCM Limit
Bone	5.0	mrem	2.39E-02	4.78E-01	1.53E-03	3.05E-02
Liver	5.0	mrem	1.77E-02	3.53E-01	2.17E-03	4.33E-02
TBody	1.5	mrem	8.17E-03	5.45E-01	1.91E-03	1.28E-01
Thyroid	5.0	mrem	1.67E-03	3.34E-02	1.00E-03	2.01E-02
Kidney	5.0	mrem	3.04E-03	6.08E-02	1.32E-03	2.64E-02
Lung	5.0	mrem	2.53E-02	5.06E-01	7.99E-03	1.60E-01
GILLI	5.0	mrem	1.09E-02	2.18E-01	5.98E-03	1.20E-01

Cumulative Doses per Year

Organ	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Bone	10.0	mrem	5.06E-02	5.06E-01
Liver	10.0	mrem	4.18E-02	4.18E-01
TBody	3.0	mrem	2.19E-02	7.30E-01
Thyroid	10.0	mrem	6.71E-03	6.71E-02
Kidney	10.0	mrem	1.03E-02	1.03E-01
Lung	10.0	mrem	5.34E-02	5.34E-01
GILLI	10.0	mrem	3.02E-02	3.02E-01

TABLE 1-5
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
TYPICAL LIQUID MDC'S ACHIEVED ON COUNTING SYSTEM

Nuclide	MDC (uCi/ML)
MN-54	3.14E-08
CO-58	4.92E-08
FE-59	7.19E-08
CO-60	4.77E-08
ZN-65	8.11E-08
MO-99	1.29E-07
I-131	2.53E-08
CS-134	3.51E-08
CS-137	4.28E-08
CE-141	5.41E-08
CE-144	1.95E-07

TABLE 1-6A
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents - Abnormal Release Summary
 Unit: 1
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

LIQUID RELEASES

NUMBER OF RELEASES	:	1	
TOTAL TIME FOR ALL RELEASES	:	55.00	MINUTES
MAXIMUM TIME FOR A RELEASE	:	55.00	MINUTES
AVERAGE TIME FOR A RELEASE	:	55.00	MINUTES
MINIMUM TIME FOR A RELEASE	:	55.00	MINUTES
TOTAL ACTIVITY FOR ALL RELEASES	:	5.07E-06	CURIES

TABLE 1-6A
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Liquid Effluents - Abnormal Release Summary
 Unit: 1
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

LIQUID RELEASES

NUMBER OF RELEASES	:	0	
TOTAL TIME FOR ALL RELEASES	:	0.00	MINUTES
MAXIMUM TIME FOR A RELEASE	:	0.00	MINUTES
AVERAGE TIME FOR A RELEASE	:	0.00	MINUTES
MINIMUM TIME FOR A RELEASE	:	0.00	MINUTES
TOTAL ACTIVITY FOR ALL RELEASES	:	0.00E+00	CURIES

TABLE 1-6B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Liquid Effluents - Abnormal Release Summary
Unit: 2
Starting : 1-Jan-1996 Ending : 30-Jun-1996

LIQUID RELEASES

NUMBER OF RELEASES	:	0	
TOTAL TIME FOR ALL RELEASES	:	0.00	MINUTES
MAXIMUM TIME FOR A RELEASE	:	0.00	MINUTES
AVERAGE TIME FOR A RELEASE	:	0.00	MINUTES
MINIMUM TIME FOR A RELEASE	:	0.00	MINUTES
TOTAL ACTIVITY FOR ALL RELEASES	:	0.00E+00	CURIES

TABLE 1-6B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Liquid Effluents - Abnormal Release Summary
Unit: 2
Starting : 1-Jul-1996 Ending : 31-Dec-1996

LIQUID RELEASES

NUMBER OF RELEASES	:	0	
TOTAL TIME FOR ALL RELEASES	:	0.00	MINUTES
MAXIMUM TIME FOR A RELEASE	:	0.00	MINUTES
AVERAGE TIME FOR A RELEASE	:	0.00	MINUTES
MINIMUM TIME FOR A RELEASE	:	0.00	MINUTES
TOTAL ACTIVITY FOR ALL RELEASES	:	0.00E+00	CURIES

3.0 GASEOUS EFFLUENTS

This section contains applicable ODCM limits for gaseous effluents as well as the quantities of radioactive gaseous effluents released during 1996. These quantities are summarized on a quarterly basis and include any unplanned releases. Tabulations are provided of the offsite air doses calculated in accordance with ODCM 3.4.2 to show conformance with the limits of ODCM 3.1.3, and the offsite organ doses to a member of the public calculated in accordance with ODCM 3.4.3 to show conformance with ODCM 3.1.4.

3.1 ODCM Limits

In accordance with Technical Specifications 6.8.3.e(v) and 6.8.3.e(viii), the air dose due to noble gases released in gaseous effluents, from each reactor unit, to areas at and beyond the SITE BOUNDARY (see ODCM Figure 10-1) shall be limited to the following:

- a. During any calendar quarter: Less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation, and
- b. During any calendar year: Less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation.

In accordance with Technical Specifications 6.8.3.e(v) and 6.8.3.e(ix), the dose to a MEMBER OF THE PUBLIC from I-131, I-133, tritium, and all radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents released, from each reactor unit, to areas at and beyond the SITE BOUNDARY (see ODCM Figure 10-1) shall be limited to the following:

- a. During any calendar quarter: Less than or equal to 7.5 mrem to any organ, and
- b. During any calendar year: Less than or equal to 15 mrem to any organ.

3.2 Measurements and Approximation of Total Radioactivity

The following noble gases are considered in evaluating gaseous effluents:

KR-87	XE-133
KR-88	XE-135
XE-133M	XE-138

The following radioiodines and radioactive materials in particulate form are specifically considered in evaluating gaseous effluents:

MN-54	MO-99
FE-59	I-131
CO-58	CS-134
CO-60	CS-137
ZN-65	CE-141
SR-89	CE-144
SR-90	H-3

Periodic grab samples from plant effluent streams are analyzed by a computerized pulse height analyzer system utilizing high resolution germanium detectors. Samples are obtained and analyzed in accordance with ODCM Table 3-3. Isotopic values thus obtained are used for release rate calculations as specified in ODCM 3.4.2 and ODCM 3.4.3. Only those nuclides which are detected are used in calculations. For radioiodines and particulates, in addition to the nuclides listed above other nuclides with half-lives greater than 8 days which are identified are also considered.

Continuous Releases: Continuous sampling is performed on the continuous releases points (i.e. the Plant Vent Stack, Containment Purge, and the Turbine Building Vent). Particulate material is collected by filtration. Periodically these filters are removed and analyzed on the pulse height analyzer to identify and quantify radioactive materials collected on the filters. Particulate filters are then analyzed for gross alpha and strontium as required. Gross alpha determinations are made using a 2 pi gas flow proportional counter. SR-89 and SR-90 analyses prior to October 8, 1996 were performed onsite using chemical separation and 2 pi gas flow proportional counters. Starting on October 8, 1996 all Sr-89 and SR-90 samples were sent offsite to the Georgia Power Environmental Laboratory for analysis.

Batch Releases: The processing of batch type releases (from Containment or Waste Gas Decay Tanks) is analogous to continuous releases, except that the release is not commenced until samples have been obtained and analyzed.

The maximum errors associated with monitor readings, sample flow, vent flow, sample collection, monitor calibration and laboratory procedure are collectively estimated to be:

Fission and			
Activation Gases	Iodine	Particulates	Tritium
75%	60%	50%	45%

The average error associated with counting is estimated to be:

Fission and			
Activation Gases	Iodine	Particulates	Tritium
19%	28%	20%	8%

3.3 Abnormal Releases

There were 13 abnormal releases on Unit 1 during the first half of 1996 and 12 abnormal releases on Unit 1 during the second half of 1996. These releases were due to releases via the Turbine Driven Auxiliary Feed Pump and the Atmospheric Relief Valves while a small (approximately 1 GPD) primary to secondary leak existed on Unit 1 . Chemistry Incident Reports # 1-96-016, 1-96-030, and 1-96-033 document these releases.

There was 1 abnormal release on Unit 2 during the first half of 1996 and 3 abnormal releases on Unit 2 during the second half of 1996. These releases were due to releases via the Turbine Driven Auxiliary Feed Pump while a small (approximately 0.5 GPD) primary to secondary leak existed on Unit 2.

Abnormal release information for Units 1 and 2 is summarized in the following tables:

Unit 1 1996 Gaseous Abnormal Releases : Table 2-8A
Unit 2 1996 Gaseous Abnormal Releases : Table 2-8B

3.4 Batch Releases

Batch release information for Units 1 and 2 is summarized in the following tables:

Unit 1 1996 Gaseous Batch Releases : Table 2-6A
Unit 2 1996 Gaseous Batch Releases : Table 2-6B

TABLE 2-3A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Gaseous Effluents - Abnormal Release Summary
Unit: 1
Starting : 1-Jan-1996 Ending : 30-Jun-1996

GASEOUS RELEASES

NUMBER OF RELEASES	:	13	
TOTAL TIME FOR ALL RELEASES	:	208715.00	MINUTES
MAXIMUM TIME FOR A RELEASE	:	66757.00	MINUTES
AVERAGE TIME FOR A RELEASE	:	16055.00	MINUTES
MINIMUM TIME FOR A RELEASE	:	3.00	MINUTES
TOTAL ACTIVITY FOR ALL RELEASES	:	1.28E-01	CURIES

TABLE 2-8A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Gaseous Effluents - Abnormal Release Summary
Unit: 1
Starting : 1-Jul-1996 Ending : 31-Dec-1996

GASEOUS RELEASES

NUMBER OF RELEASES	:	12	
TOTAL TIME FOR ALL RELEASES	:	795087.98	MINUTES
MAXIMUM TIME FOR A RELEASE	:	264960.00	MINUTES
AVERAGE TIME FOR A RELEASE	:	66257.33	MINUTES
MINIMUM TIME FOR A RELEASE	:	3.00	MINUTES
TOTAL ACTIVITY FOR ALL RELEASES	:	1.61E-04	CURIES

TABLE 2-8B
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Gaseous Effluents - Abnormal Release Summary
 Unit: 2
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

 GASEOUS RELEASES

NUMBER OF RELEASES	:	1	
TOTAL TIME FOR ALL RELEASES	:	4.00	MINUTES
MAXIMUM TIME FOR A RELEASE	:	4.00	MINUTES
AVERAGE TIME FOR A RELEASE	:	4.00	MINUTES
MINIMUM TIME FOR A RELEASE	:	4.00	MINUTES
TOTAL ACTIVITY FOR ALL RELEASES	:	1.43E-06	CURIES

TABLE 2-8B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Gaseous Effluents - Abnormal Release Summary
Unit: 2
Starting : 1-Jul-1996 Ending : 31-Dec-1996

GASEOUS RELEASES

NUMBER OF RELEASES	:	3	
TOTAL TIME FOR ALL RELEASES	:	13.00	MINUTES
MAXIMUM TIME FOR A RELEASE	:	5.00	MINUTES
AVERAGE TIME FOR A RELEASE	:	4.33	MINUTES
MINIMUM TIME FOR A RELEASE	:	4.00	MINUTES
TOTAL ACTIVITY FOR ALL RELEASES	:	3.66E-06	CURIES

TABLE 2-6A
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Gaseous Effluents - Batch Release Summary
 Unit: 1
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

 GASEOUS RELEASES

NUMBER OF BATCH RELEASES	:	6	
TOTAL TIME PERIOD FOR BATCH RELEASES	:	664.00	MINUTES
MAXIMUM TIME PERIOD FOR A BATCH RELEASE	:	366.00	MINUTES
AVERAGE TIME PERIOD FOR BATCH RELEASES	:	110.67	MINUTES
MINIMUM TIME FOR A BATCH RELEASE	:	5.00	MINUTES

TABLE 2-6A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Gaseous Effluents - Batch Release Summary
Unit: 1
Starting : 1-Jul-1996 Ending : 31-Dec-1996

GASEOUS RELEASES

NUMBER OF BATCH RELEASES	:	3	
TOTAL TIME PERIOD FOR BATCH RELEASES	:	9.00	MINUTES
MAXIMUM TIME PERIOD FOR A BATCH RELEASE	:	4.00	MINUTES
AVERAGE TIME PERIOD FOR BATCH RELEASES	:	3.00	MINUTES
MINIMUM TIME FOR A BATCH RELEASE	:	2.00	MINUTES

TABLE 2-6B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Gaseous Effluents - Batch Release Summary
Unit: 2
Starting : 1-Jan-1996 Ending : 30-Jun-1996

GASEOUS RELEASES

NUMBER OF BATCH RELEASES	:	1	
TOTAL TIME PERIOD FOR BATCH RELEASES	:	198.00	MINUTES
MAXIMUM TIME PERIOD FOR A BATCH RELEASE	:	198.00	MINUTES
AVERAGE TIME PERIOD FOR BATCH RELEASES	:	198.00	MINUTES
MINIMUM TIME FOR A BATCH RELEASE	:	198.00	MINUTES

TABLE 2-6B
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Gaseous Effluents - Batch Release Summary
 Unit: 2
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

 GASEOUS RELEASES

NUMBER OF BATCH RELEASES	:	18	
TOTAL TIME PERIOD FOR BATCH RELEASES	:	5677.00	MINUTES
MAXIMUM TIME PERIOD FOR A BATCH RELEASE	:	475.00	MINUTES
AVERAGE TIME PERIOD FOR BATCH RELEASES	:	315.39	MINUTES
MINIMUM TIME FOR A BATCH RELEASE	:	135.00	MINUTES

3.5 Release Summaries

This section contains the summaries of all radioactive gaseous effluents released for Units 1 and 2 during 1996. Typical gaseous Minimum Detectable Concentrations (MDC'S) for analyses are in Table 2-7 of this section. Regulatory Guide 1.21 Table 1A is found in this report as Tables 2-1A, 2-1B, and 2-1C. Regulatory Guide 1.21 Table 1B is found in this report as Tables 2-2A, 2-2B, and 2-2C. Regulatory Guide 1.21 Table 1C is found in this report as Tables 2-3A, 2-3B, and 2-3C.

3.5.1 Gaseous Effluents - Summation of All Releases

The summations of all gaseous effluent releases are contained in the following tables:

Unit 1 1996 Summation of All Releases : Table 2-1A
Unit 2 1996 Summation of All Releases : Table 2-1B
Site 1996 Summation of All Releases : Table 2-1C

TABLE 2-1A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Gaseous Effluents - Summation of All Releases
Unit: 1
Starting : 1-Jan-1996 Ending : 30-Jun-1996

TYPE OF EFFLUENT	UNITS	QUARTER 1	QUARTER 2	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE	CURIES	7.83E+00	8.55E+00	9.40E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	9.96E-01	1.09E+00	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. RADIOIODINES				

1. TOTAL IODINE-131	CURIES	4.41E-06	6.42E-07	8.80E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	5.61E-07	8.16E-08	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. PARTICULATES				

1. PARTICULATES (HALF-LIVES > 8 DAYS)	CURIES	0.00E+00	3.66E-07	7.00E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	0.00E+00	4.65E-08	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

4. GROSS ALPHA RADIOACTIVITY	CURIES	2.12E-07	3.96E-07	

D. TRITIUM				

1. TOTAL RELEASE	CURIES	6.85E+00	6.11E+00	5.30E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	8.71E-01	7.77E-01	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

* Applicable limits are expressed in terms of dose. See Tables 2-4A, 2-4B, 2-5A, and 2-5B of this report.

TABLE 2-1A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Gaseous Effluents - Summation of All Releases
Unit: 1
Starting : 1-Jul-1996 Ending : 31-Dec-1996

TYPE OF EFFLUENT	UNITS	QUARTER 3	QUARTER 4	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE	CURIES	1.10E+01	9.14E+00	9.40E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	1.38E+00	1.15E+00	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. RADIOIODINES				

1. TOTAL IODINE-131	CURIES	1.08E-07	1.07E-06	8.80E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	1.36E-08	1.35E-07	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. PARTICULATES				

1. PARTICULATES (HALF-LIVES > 8 DAYS)	CURIES	3.73E-06	3.64E-07	7.00E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	4.69E-07	4.58E-08	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

4. GROSS ALPHA RADIOACTIVITY	CURIES	7.34E-07	2.53E-08	

D. TRITIUM				

1. TOTAL RELEASE	CURIES	7.09E+00	6.92E+00	5.30E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	8.92E-01	8.70E-01	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

* Applicable limits are expressed in terms of dose. See Tables 2-4A, 2-4B, 2-5A, and 2-5B of this report.

TABLE 2-1B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Gaseous Effluents - Summation of All Releases
Unit: 2
Starting : 1-Jan-1996 Ending : 30-Jun-1996

TYPE OF EFFLUENT	UNITS	QUARTER 1	QUARTER 2	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE	CURIES	5.69E+00	6.49E+00	9.40E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	7.24E-01	8.25E-01	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. RADIOIODINES				

1. TOTAL IODINE-131	CURIES	0.00E+00	0.00E+00	8.80E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	0.00E+00	0.00E+00	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. PARTICULATES				

1. PARTICULATES (HALF-LIVES > 8 DAYS)	CURIES	3.31E-08	5.84E-06	7.00E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	4.21E-09	7.43E-07	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

4. GROSS ALPHA RADIOACTIVITY	CURIES	1.10E-07	3.17E-07	

D. TRITIUM				

1. TOTAL RELEASE	CURIES	5.24E+00	7.26E+00	5.30E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	6.66E-01	9.24E-01	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

* Applicable limits are expressed in terms of dose. See Tables 2-4A, 2-4B, 2-5A, and 2-5B of this report.

TABLE 2 1B
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Gaseous Effluents - Summation of All Releases
 Unit: 2
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

TYPE OF EFFLUENT	UNITS	QUARTER 3	QUARTER 4	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE	CURIES	8.86E+00	1.10E+01	9.40E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	1.11E+00	1.38E+00	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. RADIOIODINES				

1. TOTAL IODINE-131	CURIES	0.00E+00	1.76E-07	8.80E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	0.00E+00	2.21E-08	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. PARTICULATES				

1. PARTICULATES (HALF-LIVES > 8 DAYS)	CURIES	1.96E-07	2.76E-07	7.00E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	2.47E-08	3.47E-08	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

4. GROSS ALPHA RADIOACTIVITY	CURIES	6.56E-08	7.01E-08	

D. TRITIUM				

1. TOTAL RELEASE	CURIES	4.99E+00	4.93E+00	5.30E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	6.27E-01	6.21E-01	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

* Applicable limits are expressed in terms of dose. See Tables 2-4A, 2-4B, 2-5A, and 2-5B of this report.

TABLE 2-1C
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Gaseous Effluents - Summation of All Releases
Unit: Site
Starting : 1-Jan-1996 Ending : 30-Jun-1996

TYPE OF EFFLUENT	UNITS	QUARTER 1	QUARTER 2	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE	CURIES	1.35E+01	1.50E+01	9.40E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	1.72E+00	1.91E+00	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. RADIOIODINES				

1. TOTAL IODINE-131	CURIES	4.41E-06	6.42E-07	8.80E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	5.61E-07	8.16E-08	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. PARTICULATES				

1. PARTICULATES (HALF-LIVES > 8 DAYS)	CURIES	3.31E-08	6.21E-06	7.00E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	4.21E-09	7.90E-07	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

4. GROSS ALPHA RADIOACTIVITY	CURIES	3.22E-07	7.14E-07	

D. TRITIUM				

1. TOTAL RELEASE	CURIES	1.21E+01	1.34E+01	5.30E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	1.54E+00	1.70E+00	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

* Applicable limits are expressed in terms of dose. See Tables 2-4A, 2-4B, 2-5A, and 2-5B of this report.

TABLE 2-1C
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
Gaseous Effluents - Summation of All Releases
Unit: Site
Starting : 1-Jul-1996 Ending : 31-Dec-1996

TYPE OF EFFLUENT	UNITS	QUARTER 3	QUARTER 4	EST. TOT ERROR %

A. FISSION & ACTIVATION PRODUCTS				

1. TOTAL RELEASE	CURIES	1.99E+01	2.01E+01	9.40E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	2.50E+00	2.53E+00	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

B. RADIOIODINES				

1. TOTAL IODINE-131	CURIES	1.08E-07	1.25E-06	8.80E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	1.36E-08	1.57E-07	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

C. PARTICULATES				

1. PARTICULATES (HALF-LIVES>8 DAYS)	CURIES	3.92E-06	6.40E-07	7.00E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	4.94E-07	8.05E-08	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

4. GROSS ALPHA RADIOACTIVITY	CURIES	7.99E-07	9.54E-08	

D. TRITIUM				

1. TOTAL RELEASE	CURIES	1.21E+01	1.19E+01	5.30E+01

2. AVERAGE RELEASE RATE FOR PERIOD	uCi/Sec	1.52E+00	1.49E+00	

3. PERCENT OF APPLICABLE LIMIT	%	*	*	

* Applicable limits are expressed in terms of dose. See Tables 2-4A, 2-4B, 2-5A, and 2-5B of this report.

3.5.2 Gaseous Effluents - Mixed Mode Releases

The summaries of all gaseous effluent mixed mode releases (includes listing by nuclide) are contained in the following tables :

Unit 1 1996 Mixed Mode Summary : Table 2-2A
Unit 2 1996 Mixed Mode Summary : Table 2-2B
Site 1996 Mixed Mode Summary : Table 2-2C

TABLE 2-2A*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Gaseous Effluents-Mixed-Mode Level Releases
 Unit: 1
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
FISSION GASES					
AR-41	CURIES	7.78E+00	7.71E+00	0.00E+00	7.52E-03
KR-85M	CURIES	0.00E+00	0.00E+00	0.00E+00	2.34E-03
XE-135	CURIES	5.09E-02	5.59E-01	0.00E+00	3.07E-02
XE-133	CURIES	0.00E+00	2.01E-01	0.00E+00	4.33E-02
TOTAL FOR PERIOD	CURIES	7.83E+00	8.47E+00	0.00E+00	8.38E-02
IODINES					
I-133	CURIES	5.36E-05	2.58E-05	0.00E+00	0.00E+00
I-131	CURIES	4.41E-06	6.42E-07	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	5.80E-05	2.65E-05	0.00E+00	0.00E+00
PARTICULATES					
SR-89	CURIES	0.00E+00	2.95E-07	0.00E+00	0.00E+00
SR-90	CURIES	0.00E+00	7.12E-08	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	0.00E+00	3.66E-07	0.00E+00	0.00E+00
H-3	CURIES	6.85E+00	5.98E+00	0.00E+00	0.00E+00
G-ALPHA	CURIES	2.12E-07	3.96E-07	0.00E+00	0.00E+00

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

TABLE 2-2A*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Gaseous Effluents-Mixed-Mode Level Releases
 Unit: 1
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
FISSION GASES					
AR-41	CURIES	7.51E+00	9.06E+00	0.00E+00	0.00E+00
XE-135	CURIES	3.49E+00	7.50E-02	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	1.10E+01	9.14E+00	0.00E+00	0.00E+00
IODINES					
I-133	CURIES	1.72E-06	1.66E-06	0.00E+00	0.00E+00
I-131	CURIES	1.08E-07	1.07E-06	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	1.83E-06	2.73E-06	0.00E+00	0.00E+00
PARTICULATES					
SR-89	CURIES	6.64E-11	7.39E-08	0.00E+00	0.00E+00
TE-125M	CURIES	3.73E-06	0.00E+00	0.00E+00	0.00E+00
SR-90	CURIES	3.43E-10	4.44E-16	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	3.73E-06	7.39E-08	0.00E+00	0.00E+00
H-3	CURIES	7.09E+00	6.92E+00	0.00E+00	0.00E+00
G-ALPHA	CURIES	7.34E-07	2.53E-08	0.00E+00	0.00E+00

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

TABLE 2-2B*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Gaseous Effluents-Mixed-Mode Level Releases
 Unit: 2
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
FISSION GASES					
AR-41	CURIES	5.69E+00	6.42E+00	0.00E+00	0.00E+00
XE-133	CURIES	0.00E+00	6.91E-02	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	5.69E+00	6.49E+00	0.00E+00	0.00E+00
IODINES					
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATES					
SR-89	CURIES	0.00E+00	4.97E-06	0.00E+00	0.00E+00
CO-58	CURIES	3.31E-08	0.00E+00	0.00E+00	0.00E+00
SR-90	CURIES	0.00E+00	8.70E-07	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	3.31E-08	5.84E-06	0.00E+00	0.00E+00
H-3	CURIES	5.24E+00	7.26E+00	0.00E+00	0.00E+00
G-ALPHA	CURIES	1.10E-07	3.17E-07	0.00E+00	0.00E+00

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

TABLE 2-2B*

Joseph M. Farley Nuclear Plant

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996

Gaseous Effluents-Mixed-Mode Level Releases

Unit: 2

Starting : 1-Jul-1996 Ending : 31-Dec-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
FISSION GASES					
AR-41	CURIES	8.86E+00	1.10E+01	0.00E+00	0.00E+00
XE-135	CURIES	0.00E+00	0.00E+00	0.00E+00	6.42E-04
XE-133	CURIES	0.00E+00	0.00E+00	0.00E+00	1.48E-02
TOTAL FOR PERIOD	CURIES	8.86E+00	1.10E+01	0.00E+00	1.55E-02
IODINES					
I-131	CURIES	0.00E+00	1.76E-07	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	0.00E+00	1.76E-07	0.00E+00	0.00E+00
PARTICULATES					
SR-89	CURIES	1.67E-07	2.67E-07	0.00E+00	0.00E+00
CO-58	CURIES	0.00E+00	0.00E+00	0.00E+00	7.80E-09
SR-90	CURIES	2.93E-08	3.68E-10	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	1.96E-07	2.68E-07	0.00E+00	7.80E-09
H-3	CURIES	4.99E+00	4.93E+00	0.00E+00	0.00E+00
G-ALPHA	CURIES	6.56E-08	7.01E-08	0.00E+00	0.00E+00

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

TABLE 2-2C*

Joseph M. Farley Nuclear Plant

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996

Gaseous Effluents-Mixed-Mode Level Releases

Unit: Site

Starting : 1-Jan-1996 Ending : 30-Jun-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
FISSION GASES					
AR-41	CURIES	1.35E+01	1.41E+01	0.00E+00	7.52E-03
KR-85M	CURIES	0.00E+00	0.00E+00	0.00E+00	2.34E-03
XE-135	CURIES	5.09E-02	5.59E-01	0.00E+00	3.07E-02
XE-133	CURIES	0.00E+00	2.71E-01	0.00E+00	4.33E-02
TOTAL FOR PERIOD	CURIES	1.35E+01	1.50E+01	0.00E+00	8.38E-02
IODINES					
I-133	CURIES	5.36E-05	2.58E-05	0.00E+00	0.00E+00
I-131	CURIES	4.41E-06	6.42E-07	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	5.80E-05	2.65E-05	0.00E+00	0.00E+00
PARTICULATES					
SR-89	CURIES	0.00E+00	5.27E-06	0.00E+00	0.00E+00
CO-58	CURIES	3.31E-08	0.00E+00	0.00E+00	0.00E+00
SR-90	CURIES	0.00E+00	9.41E-07	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	3.31E-08	6.21E-06	0.00E+00	0.00E+00
H-3	CURIES	1.21E+01	1.32E+01	0.00E+00	0.00E+00
G-ALPHA	CURIES	3.22E-07	7.14E-07	0.00E+00	0.00E+00

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

TABLE 2-2C*

Joseph M. Farley Nuclear Plant

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996

Gaseous Effluents-Mixed-Mode Level Releases

Unit: Site

Starting : 1-Jul-1996 Ending : 31-Dec-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4

FISSION GASES

AR-41	CURIES	1.64E+01	2.00E+01	0.00E+00	0.00E+00
XE-135	CURIES	3.49E+00	7.50E-02	0.00E+00	6.42E-04
XE-133	CURIES	0.00E+00	0.00E+00	0.00E+00	1.48E-02
TOTAL FOR PERIOD	CURIES	1.99E+01	2.01E+01	0.00E+00	1.55E-02

IODINES

I-133	CURIES	1.72E-06	1.66E-06	0.00E+00	0.00E+00
I-131	CURIES	1.08E-07	1.25E-06	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	1.83E-06	2.91E-06	0.00E+00	0.00E+00

PARTICULATES

SR-89	CURIES	1.67E-07	3.41E-07	0.00E+00	0.00E+00
TE-125M	CURIES	3.73E-06	0.00E+00	0.00E+00	0.00E+00
CO-58	CURIES	0.00E+00	0.00E+00	0.00E+00	7.80E-09
SR-90	CURIES	2.96E-08	3.68E-10	0.00E+00	0.00E+00
TOTAL FOR PERIOD	CURIES	3.92E-06	3.42E-07	0.00E+00	7.80E-09

H-3	CURIES	1.21E+01	1.18E+01	0.00E+00	0.00E+00
G-ALPHA	CURIES	7.99E-07	9.54E-08	0.00E+00	0.00E+00

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

3.5.3 Gaseous Effluents - Ground Mode Releases

The summaries of all gaseous effluent ground mode releases (includes listing by nuclide) are contained in the following tables :

Unit 1 1996 Ground Mode Summary : Table 2-3A
Unit 2 1996 Ground Mode Summary : Table 2-3B
Site 1996 Ground Mode Summary : Table 2-3C

TABLE 2-3A*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Gaseous Effluents-Ground Level Releases
 Unit: 1
 Starting : 1-Jan-1996 Ending : 30-Jun-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
FISSION GASES					
XE-135	CURIES	0.00E+00	0.00E+00	0.00E+00	2.32E-04
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	2.32E-04
IODINES					
I-133	CURIES	0.00E+00	0.00E+00	0.00E+00	6.28E-04
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	6.28E-04
PARTICULATES					
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
H-3	CURIES	1.13E-04	1.15E-03	7.80E-05	1.27E-01

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

TABLE 2-3A*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Gaseous Effluents-Ground Level Releases
 Unit: 1
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
FISSION GASES					
XE-135	CURIES	0.00E+00	0.00E+00	0.00E+00	8.18E-09
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	8.18E-09
IODINES					
I-133	CURIES	0.00E+00	0.00E+00	9.10E-08	1.87E-06
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	9.10E-08	1.87E-06
PARTICULATES					
RU-106	CURIES	0.00E+00	0.00E+00	0.00E+00	1.45E-07
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	1.45E-07
H-3	CURIES	1.18E-03	6.07E-04	2.30E-05	1.42E-04

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

TABLE 2-3B*

Joseph M. Farley Nuclear Plant

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996

Gaseous Effluents-Ground Level Releases

Unit: 2

Starting : 1-Jan-1996 Ending : 30-Jun-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
FISSION GASES					
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
IODINES					
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATES					
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
H-3	CURIES	2.52E-03	8.93E-04	0.00E+00	0.00E+00

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

TABLE 2-3B*
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 Gaseous Effluents-Ground Level Releases
 Unit: 2
 Starting : 1-Jul-1996 Ending : 31-Dec-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
FISSION GASES					
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
IODINES					
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
PARTICULATES					
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
H-3	CURIES	4.78E-04	5.21E-04	0.00E+00	0.00E+00

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

TABLE 2-3C*

Joseph M. Farley Nuclear Plant

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996

Gaseous Effluents-Ground Level Releases

Unit: Site

Starting : 1-Jan-1996 Ending : 30-Jun-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 1	QUARTER 2	QUARTER 1	QUARTER 2
FISSION GASES					
XE-135	CURIES	0.00E+00	0.00E+00	0.00E+00	2.32E-04
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	2.32E-04
IODINES					
I-133	CURIES	0.00E+00	0.00E+00	0.00E+00	6.28E-04
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	6.28E-04
PARTICULATES					
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	0.00E+00
H-3	CURIES	2.63E-03	2.04E-03	7.80E-05	1.27E-01

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

TABLE 2-3C*

Joseph M. Farley Nuclear Plant

ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996

Gaseous Effluents-Ground Level Releases

Unit: Site

Starting : 1-Jul-1996 Ending : 31-Dec-1996

		CONTINUOUS MODE		BATCH MODE	
NUCLIDES RELEASED	UNIT	QUARTER 3	QUARTER 4	QUARTER 3	QUARTER 4
FISSION GASES					
XE-135	CURIES	0.00E+00	0.00E+00	0.00E+00	8.18E-09
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	8.18E-09
IODINES					
I-133	CURIES	0.00E+00	0.00E+00	9.10E-08	1.87E-06
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	9.10E-08	1.87E-06
PARTICULATES					
RU-106	CURIES	0.00E+00	0.00E+00	0.00E+00	1.45E-07
TOTAL FOR PERIOD	CURIES	0.00E+00	0.00E+00	0.00E+00	1.45E-07
H-3	CURIES	1.66E-03	1.13E-03	2.30E-05	1.42E-04

* Zeroes in this table indicate that no radioactivity was present at detectable levels. See Table 2-7 for typical minimum detectable concentrations.

3.6 Radiological Impact

The air doses and organ doses due to gaseous effluents for Units 1 and 2 are provided in the following tables in order to show conformance with the limits of ODCM 3.1.3 and ODCM 3.1.4 :

Unit 1 1996 Air Doses	:	Table 2-4A
Unit 2 1996 Air Doses	:	Table 2-4B
Unit 1 1996 Organ Doses	:	Table 2-5A
Unit 2 1996 Organ Doses	:	Table 2-5B

TABLE 2-4A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
AIR DOSES DUE TO GASEOUS RELEASES

Unit: 1

Starting: 01-Jan-1996

Ending: 30-Jun-1996

Cumulative Doses per Quarter

Type of Radi- ation	ODCM Limit	Units	Quarter 1	% of ODCM Limit	Quarter 2	% of ODCM Limit
Gamma	5.0	mrads	2.48E-03	4.96E-02	2.50E-03	5.00E-02
Beta	10.0	mrads	8.78E-04	8.78E-03	9.26E-04	9.26E-03

Cumulative Doses per Year

Type of Radi- ation	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Gamma	10.0	mrads	4.98E-03	4.98E-02
Beta	20.0	mrads	1.80E-03	9.02E-03

TABLE 2-4A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
AIR DOSES DUE TO GASEOUS RELEASES

Unit: 1

Starting: 01-Jul-1996

Ending: 31-Dec-1996

Cumulative Doses per Quarter

Type of Radi- ation	ODCM Limit	Units	Quarter 3	% of ODCM Limit	Quarter 4	% of ODCM Limit
Gamma	5.0	mrads	2.62E-03	5.24E-02	2.89E-03	5.78E-02
Beta	10.0	mrads	1.14E-03	1.14E-02	1.02E-03	1.02E-02

Cumulative Doses per Year

Type of Radi- ation	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Gamma	10.0	mrads	1.05E-02	1.05E-01
Beta	20.0	mrads	3.97E-03	1.98E-02

TABLE 2-4B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
AIR DOSES DUE TO GASEOUS RELEASES

Unit: 2

Starting: 01-Jan-1996

Ending: 30-Jun-1996

Cumulative Doses per Quarter

Type of Radi- ation	ODCM Limit	Units	Quarter 1	% of ODCM Limit	Quarter 2	% of ODCM Limit
Gamma	5.0	mrads	1.81E-03	3.62E-02	2.04E-03	4.09E-02
Beta	10.0	mrads	6.39E-04	6.39E-03	7.23E-04	7.23E-03

Cumulative Doses per Year

Type of Radi- ation	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Gamma	10.0	mrads	3.86E-03	3.86E-02
Beta	20.0	mrads	1.36E-03	6.81E-03

TABLE 2-4B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
AIR DOSES DUE TO GASEOUS RELEASES

Unit: 2

Starting: 01-Jul-1996

Ending: 31-Dec-1996

Cumulative Doses per Quarter

Type of Radi- ation	ODCM Limit	Units	Quarter 3	% of ODCM Limit	Quarter 4	% of ODCM Limit
Gamma	5.0	mrad	2.82E-03	5.64E-02	3.49E-03	6.98E-02
Beta	10.0	mrad	9.95E-04	9.95E-03	1.23E-03	1.23E-02

Cumulative Doses per Year

Type of Radi- ation	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Gamma	10.0	mrad	1.02E-02	1.02E-01
Beta	20.0	mrad	3.59E-03	1.79E-02

TABLE 2-5A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSES TO A MEMBER OF THE PUBLIC DUE TO RADIOIODINES, TRITIUM,
AND PARTICULATES IN GASEOUS RELEASES

Unit: 1

Starting: 01-Jan-1996

Ending: 30-Jun-1996

Cumulative Doses per Quarter

Organ	ODCM Limit	Unit	Quarter 1	% of ODCM Limit	Quarter 2	% of ODCM Limit
Bone	7.5	mrem	3.94E-07	5.25E-06	4.61E-05	6.15E-04
Liver	7.5	mrem	9.36E-04	1.25E-02	1.01E-03	1.35E-02
TBody	7.5	mrem	9.35E-04	1.25E-02	1.02E-03	1.36E-02
Thyroid	7.5	mrem	1.03E-03	1.38E-02	2.13E-03	2.84E-02
Kidney	7.5	mrem	9.36E-04	1.25E-02	1.02E-03	1.36E-02
Lung	7.5	mrem	9.35E-04	1.25E-02	1.01E-03	1.34E-02
GILLI	5	mrem	9.35E-04	1.25E-02	1.01E-03	1.35E-02

Cumulative Doses per Year

Organ	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Bone	15.0	mrem	4.65E-05	3.10E-04
Liver	15.0	mrem	1.95E-03	1.30E-02
TBody	15.0	mrem	1.96E-03	1.30E-02
Thyroid	15.0	mrem	3.16E-03	2.11E-02
Kidney	15.0	mrem	1.95E-03	1.30E-02
Lung	15.0	mrem	1.94E-03	1.30E-02
GILLI	15.0	mrem	1.95E-03	1.30E-02

TABLE 2-5A
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSES TO A MEMBER OF THE PUBLIC DUE TO RADIOIODINES, TRITIUM,
AND PARTICULATES IN GASEOUS RELEASES

Unit: 1

Starting: 01-Jul-1996

Ending: 31-Dec-1996

Cumulative Doses per Quarter

Type of Radi- ation	ODCM Limit	Units	Quarter 3	% of ODCM Limit	Quarter 4	% of ODCM Limit
Bone	7.5	mrem	1.59E-06	2.13E-05	1.72E-06	2.29E-05
Liver	7.5	mrem	9.70E-04	1.29E-02	9.46E-04	1.26E-02
TBody	7.5	mrem	9.70E-04	1.29E-02	9.46E-04	1.26E-02
Thyroid	7.5	mrem	9.73E-04	1.30E-02	9.69E-04	1.29E-02
Kidney	7.5	mrem	9.70E-04	1.29E-02	9.47E-04	1.26E-02
Lung	7.5	mrem	9.70E-04	1.29E-02	9.46E-04	1.26E-02
GILLI	7.5	mrem	9.71E-04	1.29E-02	9.56E-04	1.27E-02

Cumulative Doses per Year

Type of Radi- ation	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Bone	15.0	mrem	4.98E-05	3.32E-04
Liver	15.0	mrem	3.87E-03	2.58E-02
TBody	15.0	mrem	3.87E-03	2.58E-02
Thyroid	15.0	mrem	5.10E-03	3.40E-02
Kidney	15.0	mrem	3.87E-03	2.58E-02
Lung	15.0	mrem	3.86E-03	2.57E-02
GILLI	15.0	mrem	3.87E-03	2.58E-02

TABLE 2-5B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSES TO A MEMBER OF THE PUBLIC DUE TO RADIOIODINES, TRITIUM,
AND PARTICULATES IN GASEOUS RELEASES
Unit: 2

Starting: 01-Jan-1996

Ending: 30-Jun-1996

Cumulative Doses per Quarter

Organ	ODCM Limit	Unit	Quarter 1	% of ODCM Limit	Quarter 2	% of ODCM Limit
Bone	7.5	mrem	4.17E-09	5.56E-08	4.25E-04	5.66E-03
Liver	7.5	mrem	7.19E-04	9.58E-03	9.93E-04	1.32E-02
TBody	7.5	mrem	7.19E-04	9.58E-03	1.09E-03	1.45E-02
Thyroid	7.5	mrem	7.19E-04	9.58E-03	9.93E-04	1.32E-02
Kidney	7.5	mrem	7.19E-04	9.58E-03	9.93E-04	1.32E-02
Lung	7.5	mrem	7.19E-04	9.58E-03	9.94E-04	1.32E-02
GILLI	7.5	mrem	7.19E-04	9.58E-03	1.00E-03	1.33E-02

Cumulative Doses per Year

Organ	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Bone	15.0	mrem	4.25E-04	2.83E-03
Liver	15.0	mrem	1.71E-03	1.14E-02
TBody	15.0	mrem	1.81E-03	1.20E-02
Thyroid	15.0	mrem	1.71E-03	1.14E-02
Kidney	15.0	mrem	1.71E-03	1.14E-02
Lung	15.0	mrem	1.71E-03	1.14E-02
GILLI	15.0	mrem	1.72E-03	1.15E-02

TABLE 2-5B
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSES TO A MEMBER OF THE PUBLIC DUE TO RADIOIODINES, TRITIUM,
AND PARTICULATES IN GASEOUS RELEASES
Unit: 2

Starting: 01-Jul-1996

Ending: 31-Dec-1996

Cumulative Doses per Quarter

Organ	ODCM Limit	Unit	Quarter 3	% of ODCM Limit	Quarter 4	% of ODCM Limit
Bone	7.5	mrem	1.43E-05	1.90E-04	4.82E-06	6.43E-05
Liver	7.5	mrem	6.81E-04	9.08E-03	6.74E-04	8.99E-03
TBody	7.5	mrem	6.85E-04	9.13E-03	6.75E-04	9.00E-03
Thyroid	7.5	mrem	6.81E-04	9.08E-03	6.77E-04	9.03E-03
Kidney	7.5	mrem	6.81E-04	9.08E-03	6.74E-04	8.99E-03
Lung	7.5	mrem	6.81E-04	9.09E-03	6.74E-04	8.99E-03
GILLI	7.5	mrem	6.82E-04	9.09E-03	6.74E-04	8.99E-03

Cumulative Doses per Year

Organ	ODCM Limit	Units	Year to Ending Date	% of ODCM Limit
Bone	15.0	mrem	4.44E-04	2.96E-03
Liver	15.0	mrem	3.07E-03	2.04E-02
TBody	15.0	mrem	3.16E-03	2.11E-02
Thyroid	15.0	mrem	3.07E-03	2.05E-02
Kidney	15.0	mrem	3.07E-03	2.04E-02
Lung	15.0	mrem	3.07E-03	2.05E-02
GILLI	15.0	mrem	3.08E-03	2.05E-02

TABLE 2-7
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
TYPICAL GASEOUS MDC'S ACHIEVED ON COUNTING SYSTEM

Nuclide	MDC (uCi/ML)
MN-54	3.21E-15
CO-58	1.53E-14
FE-59	7.96E-15
CO-60	1.95E-14
ZN-65	2.34E-14
MO-99	1.81E-13
CS-134	1.41E-14
CS-137	7.83E-15
CE-141	6.96E-15
CE-144	3.47E-14
KR-87	8.18E-07
KR-88	3.94E-08
XE-133	4.30E-08
XE-133M	4.82E-08
XE-135	1.78E-08
XE-138	1.99E-07
I-131	9.67E-15
I-133	1.80E-13

4.0 SOLID WASTE

This section contains information regarding the types and quantities of solid radioactive waste shipped offsite during 1996 as required in ODCM 7.2.2.4. This information is presented in Table 3.

The error involved in determining the contents of solid radwaste shipments is estimated to be less than + or - 15%.

TABLE 3
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS
 Starting: 01-Jan-1996 Ending: 30-Jun-1996

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL
 (not irradiated fuel)

1. Type of Waste.	UNITS	6-Months
	3	
a. Spent resins, Filter sludges, evaporator bottoms, etc.	m Ci*	5.200E-01 1.944E+01
	3	
b. Dry compressible waste, contaminated equipment, etc.	m Ci*	6.03E+00 5.14E+00
	3	
c. Irradiated components, control rods, etc.	m Ci*	None None
	3	
d. Other (describe)	m Ci*	None None

* Measured and/or estimated by correlations in accordance
 with 10CFR61.55.

TABLE 3
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS
Starting: 01-Jan-1996 Ending: 30-Jun-1996

(continued)

2. Estimate of major nuclide composition.

a. ZN-65	19.6%
NI-63	18.4%
CO-58	18.3%
CS-137	13.6%
CO-60	8.3%
CS-134	6.3%
C-14	6.3%
FE-55	6.0%
MN-54	3.5%

b. CO-58	51.5%
FE-55	19.5%
CR-51	8.2%
CO-60	4.8%
NI-63	4.0%
NB-95	3.7%
H-3	2.8%
ZR-95	2.1%
MN-54	1.6%

3. Solid Waste Disposition

Number of Shipments	Mode of Transportation	Destination
35	Highway	Chem-Nuclear Systems, Inc. Barnwell, South Carolina.

TABLE 3
 Joseph M. Farley Nuclear Plant
 ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS
 Starting: 01-Jan-1996 Ending: 30-Jun-1996

(continued)

4. Type of Container(1a)	Type of Container(1b)
Strong Tight Containers.	Strong Tight Containers.
5. Solidification Agent(1a)	Solidification Agent(1b)
All items shipped dewatered.	None

B. IRRADIATED FUEL SHIPMENTS (Disposition)

Number of Shipments	Mode of Transportation	Destination
None	N/A	N/A

TABLE 3
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS
Starting: 01-Jul-1996 Ending: 31-Dec-1996

A. SOLID WASTE SHIPPED OFFSITE FOR BURIAL OR DISPOSAL
(not irradiated fuel)

1. Type of Waste.	UNITS	6-Months
	3	
a. Spent resins, Filter sludges, evaporator bottoms, etc.	m Ci*	6.360E+00 3.433E+02
	3	
b. Dry compressible waste, contaminated equipment, etc.	m Ci*	8.700E+00 1.590E+00
	3	
c. Irradiated components, control rods, etc.	m Ci*	None None
	3	
d. Other (describe)	m Ci*	None None

* Measured and/or estimated by correlations in accordance
with 10CFR61.55.

(continued)

a. NI-63	39.6%
FE-55	30.6%
CO-60	18.6%
MN-54	3.4%
CO-58	1.7%
CS-137	1.4%

Number of Shipments	Mode of Transportation	Destination
33	Highway	Chem-Nuclear Systems, Inc. Barnwell, South Carolina.

Strong Tight Containers.

None

86

5.0 ONSITE DOSES TO MEMBERS OF THE PUBLIC

Current FNP effluent controls as established by ODCM 6.1 do not require assessment of the radiation doses from radioactive liquid and gaseous effluents to MEMBERS OF THE PUBLIC due to their activities inside the SITE BOUNDARY (ODCM Figure 10-1). However, this assessment has been performed for 1996 using the methods described in ODCM 6.2 and is included in this section as Table 4-1.

TABLE 4-1
Joseph M. Farley Nuclear Plant
ANNUAL RADICACTIVE EFFLUENT RELEASE REPORT - 1996
DOSE TO A MEMBER OF THE PUBLIC
DUE TO ACTIVITIES INSIDE THE SITE BOUNDARY
Unit: Site

Starting: 01-Jan-1996

Ending: 30-Jun-1996

Page: 1

Location Name	VISITOR LOCATION 1 (VIS.CENTER)
Distance (kilometers)	3.06E-01
Sector	WSW
Occupancy Factor	1.37E-03 (1.20E+01 hr/yr)
Age Group	CHILD

Ground Level Releases:

Noble Gas X/Q (sec/m3)	1.04E-04
Particulate X/Q (sec/m3)	1.04E-04
Particulate D/Q (m-2)	4.80E-07

Mixed Mode Releases:

Noble Gas X/Q (sec/m3)	8.80E-06
Particulate X/Q (sec/m3)	8.80E-06
Particulate D/Q (m-2)	6.20E-08

Elevated Releases:

Noble Gas X/Q (sec/m3)	N/A
Particulate X/Q (sec/m3)	N/A
Particulate D/Q (m-2)	N/A

	Units	Quarter 1	Quarter 2	Quarters 1 and 2	Year to Ending Date
Bone	mrem	4.64E-05	4.84E-05	9.48E-05	9.48E-05
Liver	mrem	5.17E-05	5.47E-05	1.06E-04	1.06E-04
TBody	mrem	5.17E-05	5.46E-05	1.06E-04	1.06E-04
Thyroid	mrem	5.18E-05	5.56E-05	1.17E-04	1.17E-04
Kidney	mrem	5.17E-05	5.47E-05	1.06E-04	1.06E-04
Lung	mrem	5.17E-05	5.46E-05	1.06E-04	1.06E-04
GI-LLI	mrem	5.17E-05	5.46E-05	1.06E-04	1.06E-04

TABLE 4-1
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSE TO A MEMBER OF THE PUBLIC
DUE TO ACTIVITIES INSIDE THE SITE BOUNDARY
Unit: Site

Starting: 01-Jan-1996

Ending: 30-Jun-1996

Page: 2

Location Name	VISITOR LOCATION 2 (SW POND)	
Distance (kilometers)	9.66E-01	
Sector	SSW	
Occupancy Factor	7.53E-03	(6.60E+01 hr/yr)
Age Group	CHILD	

Ground Level Releases:	
Noble Gas X/Q (sec/m3)	4.74E-05
Particulate X/Q (sec/m3)	4.74E-05
Particulate D/Q (m-2)	1.31E-07

Mixed Mode Releases:	
Noble Gas X/Q (sec/m3)	9.75E-07
Particulate X/Q (sec/m3)	9.75E-07
Particulate D/Q (m-2)	2.78E-08

Elevated Releases:	
Noble Gas X/Q (sec/m3)	N/A
Particulate X/Q (sec/m3)	N/A
Particulate D/Q (m-2)	N/A

	Units	Quarter 1	Quarter 2	Quarters 1 and 2	Year to Ending Date
Bone	mrem	2.83E-05	2.96E-05	5.79E-05	5.79E-05
Liver	mrem	3.15E-05	3.47E-05	6.62E-05	6.62E-05
TBody	mrem	3.15E-05	3.46E-05	6.61E-05	6.61E-05
Thyroid	mrem	3.16E-05	6.19E-05	9.35E-05	9.35E-05
Kidney	mrem	3.15E-05	3.48E-05	6.63E-05	6.63E-05
Lung	mrem	3.15E-05	3.45E-05	6.61E-05	6.61E-05
GI-LLI	mrem	3.15E-05	3.46E-05	6.61E-05	6.61E-05

TABLE 4-1
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSE TO A MEMBER OF THE PUBLIC
DUE TO ACTIVITIES INSIDE THE SITE BOUNDARY
Unit: Site

Starting: 01-Jan-1996

Ending: 30-Jun-1996

Page: 3

Location Name	VISITOR LOCATION 3 (RW DISCH.)	
Distance (kilometers)	1.64E+00	
Sector	SE	
Occupancy Factor	1.14E-02	(9.99E+01 hr/yr)
Age Group	CHILD	

Ground Level Releases:

Noble Gas X/Q (sec/m3)	1.63E-05
Particulate X/Q (sec/m3)	1.63E-05
Particulate D/Q (m-2)	4.55E-08

Mixed Mode Releases:

Noble Gas X/Q (sec/m3)	7.05E-07
Particulate X/Q (sec/m3)	7.05E-07
Particulate D/Q (m-2)	1.39E-08

Elevated Releases:

Noble Gas X/Q (sec/m3)	N/A
Particulate X/Q (sec/m3)	N/A
Particulate D/Q (m-2)	N/A

		Units	Quarter 1	Quarter 2	Quarters 1 and 2	Year to Ending Date
Bone	mrem		3.09E-05	3.23E-05	6.32E-05	6.32E-05
Liver	mrem		3.45E-05	3.69E-05	7.14E-05	7.14E-05
TBody	mrem		3.45E-05	3.69E-05	7.14E-05	7.14E-05
Thyroid	mrem		3.46E-05	5.11E-05	8.57E-05	8.57E-05
Kidney	mrem		3.45E-05	3.70E-05	7.15E-05	7.15E-05
Lung	mrem		3.45E-05	3.68E-05	7.13E-05	7.13E-05
GI-LLI	mrem		3.45E-05	3.69E-05	7.13E-05	7.13E-05

TABLE 4-1
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSE TO A MEMBER OF THE PUBLIC
DUE TO ACTIVITIES INSIDE THE SITE BOUNDARY
Unit: Site

Starting: 01-Jul-1996

Ending: 31-Dec-1996

Page: 1

Location Name	VISITOR LOCATION 1 (VIS.CENTER)	
Distance (kilometers)	3.06E-01	
Sector	WSW	
Occupancy Factor	1.37E-03	(1.20E+01 hr/yr)
Age Group	CHILD	

Ground Level Releases:

Noble Gas X/Q (sec/m3)	1.04E-04
Particulate X/Q (sec/m3)	1.04E-04
Particulate D/Q (m-2)	4.80E-07

Mixed Mode Releases:

Noble Gas X/Q (sec/m3)	8.80E-06
Particulate X/Q (sec/m3)	8.80E-06
Particulate D/Q (m-2)	6.20E-08

Elevated Releases:

Noble Gas X/Q (sec/m3)	N/A
Particulate X/Q (sec/m3)	N/A
Particulate D/Q (m-2)	N/A

	Units	Quarter 3	Quarter 4	Quarters 3 and 4	Year to Ending Date
Bone	mrem	5.75E-05	6.70E-05	1.25E-04	2.19E-04
Liver	mrem	6.26E-05	7.21E-05	1.35E-04	2.41E-04
TBody	mrem	6.26E-05	7.21E-05	1.35E-04	2.41E-04
Thyroid	mrem	6.26E-05	7.21E-05	1.35E-04	2.52E-04
Kidney	mrem	6.26E-05	7.21E-05	1.35E-04	2.41E-04
Lung	mrem	6.26E-05	7.21E-05	1.35E-04	2.41E-04
GI-LLI	mrem	6.26E-05	7.21E-05	1.35E-04	2.41E-04

TABLE 4-1
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSE TO A MEMBER OF THE PUBLIC
DUE TO ACTIVITIES INSIDE THE SITE BOUNDARY
Unit: Site

Starting: 01-Jul-1996

Ending: 31-Dec-1996

Page: 2

Location Name	VISITOR LOCATION 2 (SW POND)	
Distance (kilometers)	9.66E-01	
Sector	SSW	
Occupancy Factor	7.53E-03	(6.60E+01 hr/yr)
Age Group	CHILD	

Ground Level Releases:

Noble Gas X/Q (sec/m3)	4.74E-05
Particulate X/Q (sec/m3)	4.74E-05
Particulate D/Q (m-2)	1.31E-07

Mixed Mode Releases:

Noble Gas X/Q (sec/m3)	9.75E-07
Particulate X/Q (sec/m3)	9.75E-07
Particulate D/Q (m-2)	2.78E-08

Elevated Releases:

Noble Gas X/Q (sec/m3)	N/A
Particulate X/Q (sec/m3)	N/A
Particulate D/Q (m-2)	N/A

	Units	Quarter 3	Quarter 4	Quarters 3 and 4	Year to Ending Date
Bone	mrem	3.50E-05	4.08E-05	7.58E-05	1.34E-04
Liver	mrem	3.81E-05	4.39E-05	8.20E-05	1.48E-04
TBody	mrem	3.81E-05	4.39E-05	8.20E-05	1.48E-04
Thyroid	mrem	3.81E-05	4.40E-05	8.21E-05	1.76E-04
Kidney	mrem	3.81E-05	4.39E-05	8.20E-05	1.48E-04
Lung	mrem	3.81E-05	4.39E-05	8.21E-05	1.48E-04
GI-LLI	mrem	3.81E-05	4.39E-05	8.20E-05	1.48E-04

TABLE 4-1
Joseph M. Farley Nuclear Plant
ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT - 1996
DOSE TO A MEMBER OF THE PUBLIC
DUE TO ACTIVITIES INSIDE THE SITE BOUNDARY
Unit: Site

Starting: 01-Jul-1996

Ending: 31-Dec-1996

Page: 3

Location Name	VISITOR LOCATION 3 (RW DISCH.)	
Distance (kilometers)	1.64E+00	
Sector	SE	
Occupancy Factor	1.14E-02	(9.99E+01 hr/yr)
Age Group	CHILD	

Ground Level Releases:

Noble Gas X/Q (sec/m3)	1.63E-05
Particulate X/Q (sec/m3)	1.63E-05
Particulate D/Q (m-2)	4.55E-08

Mixed Mode Releases:

Noble Gas X/Q (sec/m3)	7.05E-07
Particulate X/Q (sec/m3)	7.05E-07
Particulate D/Q (m-2)	1.39E-08

Elevated Releases:

Noble Gas X/Q (sec/m3)	N/A
Particulate X/Q (sec/m3)	N/A
Particulate D/Q (m-2)	N/A

		Units	Quarter 3	Quarter 4	Quarters 3 and 4	Year to Ending Date
Bone	mrem		3.83E-05	4.47E-05	8.30E-05	1.46E-04
Liver	mrem		4.17E-05	4.81E-05	8.98E-05	1.61E-04
TBody	mrem		4.17E-05	4.81E-05	8.98E-05	1.61E-04
Thyroid	mrem		4.17E-05	4.81E-05	8.98E-05	1.76E-04
Kidney	mrem		4.17E-05	4.81E-05	8.98E-05	1.61E-04
Lung	mrem		4.17E-05	4.81E-05	8.98E-05	1.61E-04
GI-LLI	mrem		4.17E-05	4.81E-05	8.98E-05	1.61E-04

6.0 MISCELLANEOUS

This section contains several items which are only required to be reported under certain conditions. These include radiation dose assessments to show conformance with 40CFR190 (if required by ODCM 5.1.2), licensee initiated changes to the ODCM within the last year, deviations in the Radioactive Effluent Control Program within the last year pursuant to ODCM 7.2.2.6, major changes to the liquid or gaseous radwaste treatment systems as required by ODCM 2.1.5 and 3.1.6, and any changes to the solid radwaste treatment system pursuant to the Process Control Program (PCP).

6.1 Total Dose From Uranium Fuel Cycle

In accordance with Technical Specification 6.8.3.e(x), the dose or dose commitment to any MEMBER OF THE PUBLIC over a calendar year, due to releases of radioactivity and to radiation from uranium fuel cycle sources, shall be limited to less than or equal to 25 mrem to the total body or to any organ, except the thyroid, which shall be limited to less than or equal to 75 mrem (as stated in ODCM 5.1).

With the calculated doses from the release of radioactive materials in liquid or gaseous effluents exceeding twice the limits of ODCM 2.1.3, 3.1.3, or 3.1.4, calculations shall be made according to ODCM 5.2 methods to determine whether the above (ODCM 5.1) limits have been exceeded (as stated in ODCM 5.1.2).

Since none of the ODCM 2.1.3, 3.1.3, or 3.1.4 limits were exceeded during 1996, no calculations were required.

6.2 Licensee Initiated Changes to the ODCM

There was one revision to the ODCM during 1996. The revision corrected a typographical error and deleted the reference to the Environmental Protection Agency (EPA) cross-check program. A copy of the revision is included as an attachment to this annual report.

6.3 Program Deviations

This section contains any deviations from the composite sampling or MDC requirements included in ODCM Tables 2-3 and 3-3.

There was a deviation from liquid composite sampling requirements on Unit 1 and Unit 2 during the first half of 1996. The April Waste Monitor Tank and Steam Generator Blowdown composites for both Units were inadvertently discarded prior to the SR-89, SR-90, and FE-55 analyses being performed. This deviation is documented in Chemistry Incident Report # 0-96-034.

An NRC Notice of Violation (50-348,364-96-10-05) was issued which stated that "as of August 12, 1996, the licensee failed to have an adequate procedure to maintain iron 55 (Fe-55) and strontium (Sr)-89, and Sr-90 concentrations in solution for composite samples collected and stored to assure representative liquid effluent stream measurements." As part of the corrective action, FNP committed, in part, that "A more detailed study will be completed to quantify the affect of non-preservation of affected samples. The results of this study will be documented. This information will also be included in appropriate reports."

The detailed study showed that there were no significant differences between the non-preserved and preserved samples for steam generator blowdown samples. The samples for the waste monitor tanks showed that preserved samples had higher isotopic concentrations for Fe-55 and Sr-89 than non-preserved samples. The concentration of Fe-55 was 7.74 times higher in the preserved samples than the non-preserved samples. The concentration of Sr-89 was 2.74 times higher in the preserved samples than the non-preserved samples. The data for Sr-90 would not support determining a bias. In the effect on dose evaluation, the bias for Sr-89 was used for Sr-90.

The effects (presented in terms of the "Historical Maximum Dose as Reported in Previous RG1.21 Reports After Including Bias from Non-preservation of Samples [Max.Conservative Theoretical Dose] (% of ODCM Limit)") on the quarterly and annual doses (calculated on the basis of the historical maximum effluent concentrations) were as follows:

	Historical Maximum Dose as Reported in Previous RG1.21 Reports (% of ODCM Limit)	Historical Maximum Dose as Reported in Previous RG1.21 Reports After Including Bias from Non- preservation of Samples [Max.Conservative Theoretical Dose] (% of ODCM Limit)
Total Body, Annual	11.37%	14.70%
Organ, Annual	5.68%	11.90%
Total Body, Quarterly	9.33%	13.27%
Organ, Quarterly	7.60%	14.96%

Therefore, it was concluded that historical doses reported in the Radioactive Effluent Release Reports have been understated slightly for Fe-55, Sr-89, and Sr-90 due to non-preservation of samples. However, a conservative bounding calculation shows that the doses remain well within the limits of the Offsite Dose Calculation Manual.

6.4 Major Changes to the Radwaste Treatment Systems

There were no major changes to the Radwaste Treatment Systems during 1996.

ATTACHMENT

1996 ODCM REVISION