

PIPE & VALVE
CONSOLIDATED
SUPPLY, INC.

Nuclear Regulatory Commission
Mr. Charles Hehl
799 Roosevelt Road
Glen Ellyn, IL 60137

Phone: 219/255-9667

March 4, 1986

Sir:

Per our conversation of today, this letter will confirm notification to you that a possible problem may exist with materials furnished by us to I & M Electric for the D.C. Cook Plant and Consumers Power Co. for the Midland Plant under 10-CFR-Part 21 as follows.

Today, March 4, 1986, we (Consolidated Pipe & Valve Supply Co. Inc.) were notified that Mr. Fred Hawley, president, Mr. Gary Edward Fleming, vice president, Mr. Neil Halloran, shipping foreman, all of GOLDEN GATE FORGE & FLANGE, INC., located at Hunters Point, San Francisco, California have been indicted and charged in Federal Court on conspiracy and making criminal false statements in connection with falsified test certifications (Mill Test Reports).

We have attached a list of all orders for which materials were purchased by us from the aforementioned company.

If we can be of any further assistance to you in investigating this matter, please feel free to contact our office at any time.

Sincerely,

Bernard S. Blanda

Bernard S. Blanda
Nuclear Procurement & Sales

Enclosures:

8603140334 860304
PDR ADOCK 05000315
S PDR

MAR 7 1986

The following orders are for material supplied to I & M ELECTRIC for the D.C. COOK PLANT

P.O. #	ORDER DATE	CONS W.O. #	INVOICE	SHPD DATE	QTY.	SIZE	DESCRIPTION	ASTM	GRADE	HEAT#
82C-30517	2-11-82	AEP-DCC-2211	D20620	2-18-1982	2	3"x1 1/2"	150# Reducing Slip On Flg	A-182	F304	A38
31739-042-2X	3-16-82	AEP-DCC-2316	E00444	4-12-82	5	3/4"	150# R.F. Blind Flg	A-182	F-304	A39
31739-042-2X	3-16-82	AEP-DCC-2316	E00444	4-12-82	4	3"	150# R.F. Blind Flg	A-182	F-304	A-39
40616-040-2X	11-29-82	AEP-DCC-21129	E04868	1-10-83	5	1"	150# R.F. Blind Flg	A-182	F-304	A-45
38862-042-2X	10-5-82	AEP-DCC-21005	E03494	10-28-82	5	3"	150# R.F. Blind FLg	A-182	F-304	A-45
36215-040-2X	7-22-82	AEP-DCC-2722	E02632	8-19-82	9	2"	150# R.F. Blind Flg	A-182	F-304	A-43
36215-040-2X	7-22-82	AEP-DCC-2722	E02632	8-19-82	4	4"	150# R.F. Blind Flg	A-182	F-304	A-43
38063-040-3X	9-21-83	AEP-DCC-3921	E09229	11-10-83	12	2"	150# XH Bore R.F. Socket Weld Flg	A-182	F-304	A-54
40513-042-3X	11-23-83	AEP-DCC-31122	E10342	1-9-84	5	3"	150# R.F. Blind Flg	A-182	F-304	A-58
13511-821-3X	1-5-84	AFP-DCC-4105	E10721	1-25-84	3	1 1/2"	1500# Sch 160 Bore R.F. Weld Neck Flg	A-182	F-316	C-47
72087-040-4X	4-2-84	AEP-DCC-4328	E12201	4-23-84	2	4"	600# Sch 80 Bore R.F. Weld Neck Flg	A-182	F-304	A-62
34708-040-4X	5-21-84	AEP-DCC-4521	E12885	6-20-84	8	4"	150# Std Bore R.F. Weld Neck Flg	A-182	F-304	A-66
35052-040-4X	6-5-84	AEP-DCC-4605	E13761	8-1-84	4	3"	600# R.F. Blind Flg	A-182	F-304	A-66

P.O. #	ORDER DATE	CONS W.O. #	INVOICE	SHPD DATE	QTY.	SIZE	DESCRIPTION	ASTM	GRADE	HEAT#
36444-042-4X	7-2-84	AEP-DCC-4702	E 13762	8-1-84	4	3/4"	1500# R.F. Blind Flg.	A-182	F-304	A-70
39329-042-4X	9-11-84	AEP-DCC-4911	E 15309	10-18-84	12	1/2"	150# Sch. 80 Bore R.F. Socket Weld Flg.	A-182	F-304	A-74
43342-040-4X	12-12-84	AEP-DCC-41212	E 16874	1-23-85	4	3"	150# R.F. Blind Flg.	A-182	F-304	A-78
30763-042-5X	2-5-85	AEP-DCC-5205	E 17569	2-27-85	8	6"	150# Std. Bore R.F. Weld Neck Flg.	A-182	F-304	A-81
00041-041-5X	2-12-85	AEP-DCC-5212	E 18012	3-27-85	2	1"	150# Std. Bore R.F. Weld Neck Flg.	A-182	F-304	A-82
00041-041-5X	2-12-85	AEP-DCC-5212	E 18012	3-27-85	2	1"	150# R.F. Blind Flg.	A-182	F-304	A-82
01507-821-5X (includes revision 1 issued 3-29-85)	3-20-85	AEP-DCC-5320	E 18271	4-10-85	10	1 1/2"	1500# Sch. 160 Bore R.F. Weld Neck Flg.	A-182	F-304	A-85
82C-34110	4-3-85	AEP-DCC-5403	E 18028	4-12-85	1 pr	4"	1500# Sch 120 Bore Weld Neck Orifice Flg.	A-182	F-316	J-143
34078-042-5X	4-23-85	AEP-DCC-5423	E 19646	7-18-85	3	3/4"	150# Std. Bore R.F. Socket Weld Flg.	A-182	F-304	A-84
34078-042-5X	4-23-85	AEP-DCC-5423	E 19646	7-18-85	3	1"	150# Std. Bore R.F. Socket Weld Flg.	A-182	F-304	A-84
35799-040-5X	6-5-85	AEP-DCC-5605	E 19927	7-30-85	5	1"	150# R.F. Blind Flg.	A-182	F-304	A-82
35799-040-5X	6-5-85	AEP-DCC-5605	E 19927	7-30-85	4	1"	1500# R.F. Blind Flg.	A-182	F-304	A-82
38099-040-5X	7-3-85	AEP-DCC-5703	E 19928	7.30-85	5	3"	150# R.F. Blind Flg.	A-182	F-304	A-82

P.O. #	ORDER DATE	CONS W.O. #	INVOICE	SHPD DATE	QTY.	SIZE	DESCRIPTION	ASTM	GRADE	HEAT#
39790-042-5X	8-8-85	AEP-DCC-5808	E 21083	9-23-85	4	2"	600# R.F. Blind Flg.	A-182	F-304	A-90
41824-042-5X	9-18-85	AEP-DCC-5918	E 21814	11-5-85	8	3"	150# Std. Bore R.F. Weld Neck Flg.	A-182	F-304	A-90
44326-042-5X	11-5-85	AEP-DCC-51105	E 22801	12-17-85	4	1"	150# Std. Bore R.F. Socket Weld Flg.	A-182	F-304	A-92

The following order is for material supplied to Consumers Power Corporation for Midland Plant

P.O. #	ORDER DATE	CONS W.O. #	INVOICE	SHPD DATE	QTY.	SIZE	DESCRIPTION	ASME	GRADE	HEAT#
5012-0837-QA	5-17-84	CPC-MP-4517	E 12912	6-28-84	6	3"	1500# Sch 160 Bore Section III-Class I R.F. Weld Neck Orifice Flanges	SA-182	F-316	C-50