



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 1000
ARLINGTON, TEXAS 76011

March 17, 1982

*Investigator to be assigned
3/21/82
NIS*

Docket: STN 50-482

MEMORANDUM FOR: K. V. Seyfrit, Acting Director, Enforcement & Investigation Staff

THRU: *W.C.* W. C. Seidle, Chief, Reactor Project Branch 2

FROM: R. E. Hall, Chief, Reactor Project Section C

SUBJECT: ALLEGATION - WOLF CREEK

At 9:30 a.m. on March 15, 1982, a telephone allegation was received from Individual A, who identified _____ as having been previously employed as _____

_____ alleged that during the period of about June to late fall of 1980 the following had occurred:

- Cable tray supports which were supposed to have been fabricated from A-36 steel were, in fact, fabricated from other unknown steel due to a shortage of A-36 material. The shop engineer (Individual B) was aware of the substitution.
- During fabrication of tubular supports, 1/8" rod was used instead of the 3/32" rod specified.
- At the direction of Individual B, tubular steel supports were reworked in the fab shop without proper documentation and QC inspection.

Individual A indicated that Individuals C and D were two welders who could support _____ allegations. Individual A was terminated from the site in July _____ following a disagreement with Individual B.

R. E. Hall, Chief
Reactor Project Section C

cc: J. T. Collins
J. E. Gagliardo
T. E. Vandel

8512160442 851107
PDR FOIA
BROSIUS84-291 PDR

6.7C
7(0)

S-4