

October 8, 1985

Docket No. 50-334

Mr. J. J. Carey, Vice President
Duquesne Light Company
Nuclear Group
Post Office Box 4
Shippingport, PA 15077

DISTRIBUTION

Docket File

NRC PDR
Local PDR
ORB#1 Reading
H. Thompson
OELD
E. Jordan

B. Grimes
J. Partlow
P. Tam
C. Parrish
ACRS (10)
Gray File

Dear Mr. Carey:

SUBJECT: ISSUANCE OF SAFETY EVALUATION ON SALEM ATWS ITEM 4.2.1
AND 4.2.2 (LICENSING ACTION 53114)

By letter dated June 17, 1985 you responded to open items in our Preliminary Safety Evaluation dated April 24, 1985. The subject of items 4.2.1 and 4.2.2 has to do with preventive maintenance for reactor trip breakers.

We have reviewed your June 17, 1985 submittal and conclude that the information justifies your proposed 18-month trip breaker maintenance frequency. Details may be found in the enclosed Safety Evaluation. In addition, we have stated in the Preliminary SE that your position on Item 4.2.2 is acceptable; the portion of that Preliminary SE that pertains to Item 4.22 is hereby incorporated into this SE by reference.

This completes our work on the subject issues. Please feel free to contact your Project Manager, Mr. J. Tam, if you have any questions.

Sincerely,

/s/SVarga

Steve A. Varga, Chief
Operating Reactors Branch #1
Division of Licensing

Enclosure:
As Stated

cc: w/enclosure
See next page

ORB31:DL
CParrish:kb
10/8/85

ORB#1:DL
PTam
10/8/85

BOYORB#1:DL
SVarga
10/8/85

8510310083 851008
PDR ADOCK 05000334
P PDR

Mr. J. J. Carey
Duquesne Light Company

cc:

Mr. W. S. Lacey
Station Superintendent
Duquesne Light Company
Beaver Valley Power Station
Post Office Box 4
Shippingport, Pennsylvania 15007

Mr. K. Grada, Superintendent
of Licensing and Compliance
Duquesne Light Company
Post Office Box 4
Shippingport, Pennsylvania 15077

Mr. John A. Levin
Public Utility Commission
Post Office Box 3265
Harrisburg, Pennsylvania 17120

Gerald Charnoff, Esquire
Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, DC 20036

Karin Carter, Esquire
Special Assistant Attorney General
Bureau of Administrative Enforcement
5th Floor, Executive House
Harrisburg, Pennsylvania 17120

Marvin Fein
Utility Counsel
City of Pittsburgh
313 City-County Building
Pittsburg, Pennsylvania 15219

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 298
Shippingport, Pennsylvania 15077

Department of Environmental Resources
ATTN: Director, Office of
Radiological Health
Post Office Box 2063
Harrisburg, Pennsylvania 17105

Beaver Valley 1 Power Station

Mr. Thomas J. Czerpah
Mayor of the Burrough of
Shippingport
Post Office Box 26
Shippingport, Pennsylvania 15077

Pennsylvania Power Company
Ray E. Sempler
One E. Washington Street
New Castle, Pennsylvania 16103

Ohio Environmental Protection Agency
Division of Planning
Environmental Assessment Section
Post Office Box 1049
Columbus, Ohio 43216

Office of the Governor
State of West Virginia
Charleston, West Virginia 25305

Charles A. Thomas, Esquire
Thomas and Thomas
212 Locust Street
Box 999
Harrisburg, Pennsylvania 17108

Irwin A. Popowsky, Esquire
Office of Consumer Advocate
1425 Strawberry Square
Harrisburg, Pennsylvania 17120

Governor's Office of State Planning
and Development
ATTN: Coordinator, Pennsylvania
State Clearinghouse
Post Office Box 1323
Harrisburg, Pennsylvania 17120

Mr. Jess T. Shumate, Commissioner
State of West Virginia Department
of Labor
1900 Washington Street, East
Charleston, West Virginia 25305

cc:

David K. Heydinger, M.D.
State Director of Health
State Department of Health
1800 Washington Street, East
Charleston, West Virginia 25305

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406

Mr. Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P.O. Box 2063
Harrisburg, Pennsylvania 17120