

TABLE II  
U S NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT  
CONFIRMATORY MEASUREMENTS PROGRAM  
FACILITY: LASALLE  
FOR THE 1 QUARTER OF 1985

SAMPLE	ISOTOPE	-----NRC-----		-----LICENSEE-----		---LICENSEE:NRC---		
		RESULT	ERROR	RESULT	ERROR	RATIO	RES	T
L WASTE	BETA	5.4E-08	8.0E-09	<1.1E-07	0.0E-01	2.0E 00	6.8E 00	A
	H-3	2.0E-07	3.0E-07	<4.0E-07	0.0E-01	2.0E 00	6.7E-01	N
	SR-89	3.0E-09	8.0E-09	1.5E-07	8.0E-09	4.9E 01	3.7E-01	N
	SR-90	4.0E-09	4.0E-09	<1.8E-09	0.0E-01	4.5E-01	1.0E 00	N

T TEST RESULTS:  
A=AGREEMENT  
D=DISAGREEMENT  
\*=CRITERIA RELAXED  
N=NO COMPARISON