

Appendix

NOTICE OF VIOLATION

University of Michigan

Docket No. 50-2

As a result of the inspection conducted on October 2-4, 1985, and in accordance with the General Policy and Procedures for NRC Enforcement Actions, (10 CFR Part 2, Appendix C), the following violation was identified:

1. 10 CFR 20.303(a) states no licensee shall discharge licensed material into a sanitary sewerage system unless it is readily soluble or dispersible in water.

Contrary to the above, on numerous occasions during 1985, licensed material that was not readily soluble or dispersible was released from the Ford Nuclear Reactor/Phoenix Memorial Laboratory (FNR/PML) to the sanitary sewer.

This is a Severity Level IV violation (Supplement IV).

2. Technical Specifications 6.4.8 states radiation protection procedures, reviewed and approved by the Safety Review Committee, will be in effect and followed. Health Physics Procedure 207, Effluent Activity Calculation Procedure, Section 2.3 states effluent reports will be prepared on a quarterly basis by the health physics staff.

Contrary to the above, no effluent reports for the fourth quarter 1984, and first and second quarters 1985 were prepared.

This is a Severity Level IV violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

10-25-85  
Dated

W.D. Shafer  
W. D. Shafer, Chief  
Emergency Preparedness and  
Radiological Protection Branch

8510310293 851025  
PDR ADOCK 05000002  
Q PDR