

ENCLOSURE 1

NOTICE OF VIOLATION

Duke Power Company  
McGuire Nuclear Station

Docket Nos. 50-369 & 50-370  
License Nos. NPF-9 & NPF-17

The following violations were identified during an inspection conducted on August 21 - September 20, 1985. The Severity levels are assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

1. Technical Specification 3.8.1.1 states that with one diesel generator inoperable, all systems, subsystems, trains, components and devices that depend upon the remaining operable diesel generator as a source of emergency power must also be operable for that train to be operable and states that if two trains are inoperable for two hours, the unit must be in at least hot standby within the next six hours and cold shutdown within the following 30 hours.

Technical Specification 3.4.3 requires for a pressurizer to be operable, that at least two groups of pressurizer heaters be operable each having a capacity of at least 150 KW.

Contrary to the above, on September 11, 1985, two trains of pressurizer heaters with their required emergency power supplies were not available from 9:50 a.m. until 7:33 p.m. on September 11, 1985.

This is a Severity Level IV violation (Supplement I) applicable to Unit 1.

2. Technical Specification 6.8.1 requires that current written approved procedures be established implemented and maintained covering shift relief, turnover and maintenance of minimum shift complement.

Contrary to the above, on September 6, 1985, at 3:00 p.m., none of the Senior Reactor Operators (SRO) designated on the shift supervisor's turnover checklist as being required to be in the control room at the time were present. A non-designated SRO was present in the control room.

This is a Severity Level IV violation (Supplement I), applicable to Units 1 and 2.

Date: OCT 21 1985

8511040256 851021  
PDR ADOCK 05000369  
Q PDR