

TEXAS UTILITIES GENERATING CO. CPSES	INSTRUCTION NUMBER	REVISION	ISSUE DATE	PAGE
	QI-QP-11.4-22	3	AUG 07 1984	1 of 2
QC SURVEILLANCE OF PROTECTIVE COATINGS UNIQUE IDENTIFICATION NUMBER TRANSFER	PREPARED BY: <u>MP Bizu</u>		<u>8/7/84</u> DATE	
	APPROVED BY: <u>[Signature]</u>		<u>8-7-84</u> DATE	
	APPROVED BY: <u>[Signature]</u>		<u>8-7-84</u> DATE	
1.0	<u>REFERENCES</u>			
1-A	QI-QP-11.4-1, "Inspection of Steel Substrate Surface Preparation and Primer Application"			
1-B	CP-QP-18.0, "Inspection Reports"			
2.0	<u>GENERAL</u>			
	This instruction provides the QC Inspector with instructions for surveillance of transfer of Protective Coating Unique Identification Number.			
3.0	<u>INSTRUCTION</u>			
3.1	<u>SURVEILLANCE</u>			
	<p>The purpose of this procedure is to ensure that QP numbers applied per Reference 1-A are transferred prior to subdivisions of the coated piece. QC Inspectors assigned by the Unit 2 QC Supervisor shall perform surveillance of QP number transfer. The frequency of this inspection shall be established by the Unit 2 QC Supervisor but shall not be less than once per week.</p> <p><u>NOTE:</u> This transfer is not required when the subdivided piece is not intended for use in the reactor building.</p>			
3.2	<u>DOCUMENTATION</u>			
	The results of the surveillance shall be documented on Attachment 1 and processed in accordance with Reference 1-B.			

CONTROLLED COPY
 CONTROL No. PC-1005

8511040441 851016
 PDR FOIA
 GARDE85-59 PDR

