

Monsanto

C O M P A N Y

800 N. Lindbergh Boulevard
St. Louis, Missouri 63166
(314) WYdown 3-1000

January 28, 1966

U. S. Atomic Energy Commission
Div. of Licensing & Regulation
Isotopes Branch
Washington 25, D.C.

Attn. Mr. Robert Brinkman

Dear Mr. Brinkman:

Attached is our application for Byproduct Material License to specifically perform the following functions:-

1. Receive, possess and return to the supplier the Americium 241 contained in the fire detection devices manufactured pursuant to Pyrotronics, Inc., License (GL-133) (1-64).
2. Install such devices on our premises.
3. Perform the service specified in 10 CFR 30.21 (c) (4) (111).
4. Adjust sensitivity, test electrically, clean and perform approved emergency procedures in order to maintain devices in proper operating condition.

The materials for each individual engineered system, including the fire detection devices containing Americium 241, are usually shipped by Pyrotronics, on our order, to their local representative. In some instances, for convenience, the materials will be shipped to us. In all cases, however, Pyrotronics maintains the records of the materials furnished and reports such transfers pursuant to 10 CFR 30.32 (e) (1) directly to the Director, Division of Licensing & Regulations, each quarter. Therefore, no reporting of this type will be required by the applicant.

DUPLICATED
FOR DIV. OF COMPLIANCE

9702260427 970106
PDR FOIA
NEITZEL96-314 PDR




Pyrotronics labels the fire detection devices containing source material in accordance with the terms and conditions of their License GL-133 (1-64).

We will make no alterations or modifications in the devices or the labels. Therefore, no additional labeling will be required.

Sincerely,

Monsanto Company


L. C. Weger
Safety Manager

Encl:-

