

The Light company

Houston Lighting & Power P.O. Box 1700 Houston, Texas 77001 (713) 228-9211

October 31, 1985
ST-HL-AE-1475
File No.: G 9.17

Mr. George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

South Texas Project
Units 1 & 2
Docket Nos. STN 50-498, STN 50-499
Response to DSER Open Items
Loss of Voltage Setpoints/Diesel Generator Testing

Dear Mr. Knighton:

The attachments enclosed provide STP's response to Draft Safety Evaluation Report (DSER) items.


The item numbers listed below correspond to those assigned on STP's internal list of items for completion which includes open and confirmatory DSER items, STP FSAR open items and open NRC questions. This list was given to your Mr. N. Prasad Kadambi on October 8, 1985 by our Mr. M. E. Powell.

The items which are attached to this letter are:

<u>Attachment</u>	<u>Item No.*</u>	<u>Subject</u>
1	D 8.3-2	Section 8.3.1 Loss of Voltage Setpoints
2	D 8.3-5	Section 8.3.1 Diesel Generator Starting

If you should have any questions on this matter, please contact Mr. Mark A. McBurnett at (512)972-8530.

Very truly yours,


M. R. Wisenburg
Manager, Nuclear Licensing

8511050048 851031
PDR ADDCK 05000498
E PDR

MAM/bjf

Attachment: See Above

* Legend

D - DSER Open Item

F - FSAR Open Item

C - DSER Confirmatory Item

Q - FSAR Question Response Item

S8/NRC1/c

13001
11

Houston Lighting & Power Company

cc:

Hugh L. Thompson, Jr., Director
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Robert D. Martin
Regional Administrator, Region IV
Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

N. Prasad Kadambi, Project Manager
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, MD 20814

Claude E. Johnson
Senior Resident Inspector/STP
c/o U.S. Nuclear Regulatory Commission
P.O. Box 910
Bay City, TX 77414

M.D. Schwarz, Jr., Esquire
Baker & Botts
One Shell Plaza
Houston, TX 77002

J.R. Newman, Esquire
Newman & Holtzinger, P.C.
1615 L Street, N.W.
Washington, DC 20555

Director, Office of Inspection
and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

E.R. Brooks/R.L. Range
Central Power & Light Company
P.O. Box 2121
Corpus Christi, TX 78403

H.L. Peterson/G. Pokorny
City of Austin
P.O. Box 1088
Austin, TX 78767

J.B. Poston/A. vonRosenberg
City Public Service Board
P.O. Box 1771
San Antonio, TX 78296

ST-HL-AE-1475
File No.: G 9.17
Page 2

Brian E. Berwick, Esquire
Assistant Attorney General for
the State of Texas
P.O. Box 12548, Capitol Station
Austin, TX 78711

Lanny A. Sinkin
3022 Porter Street, N.W. #304
Washington, DC 20555

Oreste R. Pirfo, Esquire
Hearing Attorney
Office of the Executive Legal Director
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Charles Bechhoefer, Esquire
Chairman, Atomic Safety &
Licensing Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dr. James C. Lamb, III
313 Woodhaven Road
Chapel Hill, NC 27514

Judge Frederick J. Shon
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Ray Goldstein, Esquire
1001 Vaughn Building
807 Brazos
Austin, TX 78701

Citizens for Equitable Utilities, Inc.
c/o Ms. Peggy Buchorn
Route 1, Box 1684
Brazoria, TX 77422

Docketing & Service Section
Office of the Secretary
U.S. Nuclear Regulatory Commission
Washington, DC 20555
(3 copies)

*Advisory Committee on Reactor Safeguards
U.S. Nuclear Regulatory Commission
1717 H Street
Washington, DC 20555

DSER Open Item 8.3-2

Voltage time delay setpoints for both loss of voltage and degraded voltage scheme relays will be selected when analysis of the onsite distribution system voltages is completed. These will be in Technical Specifications.

Response

These parameters are identified in the STPEGS Technical Specifications submitted June 17, 1985 as "later" (in Specification 3/4.3.2). HL&P plans to provide these parameters when they are available. HL&P considers this item to be confirmatory.

DSER Open Item 8.3-5

Submit the results of start and load tests, full load and margin test and load acceptance test after prolonged no load operation of the DG. (8.3.1)

Response

Currently
This test is scheduled to be completed in mid 1986. The requested results will be provided at that time.