



John C. Brons
Senior Vice President
Nuclear Generation

November 1, 1985
JPN-85-79

Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch No. 2
Division of Licensing

Subject: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
Withdrawal of Proposed Change to Technical
Specifications regarding Reactor Building Closed
Loop Cooling Water (RBCLCW) System Containment
Isolation Valves (JPTS-83-17)

References: 1. NYPA letter, J. P. Bayne to D. B. Vassallo,
dated November 10, 1983 (JPN-83-94).
2. NYPA letter, J. C. Brons to D. B. Vassallo,
dated July 10, 1985 (JPN-85-56).

Dear Sir:

Via References 1 and 2, the Authority submitted proposed change to the FitzPatrick Technical Specifications regarding the installation of Reactor Building Closed Loop Cooling Water (RBCLCW) System containment isolation valves. Specifically, this amendment request changed Table 3.7-1 entitled "Process Piping Penetrating Primary Containment" on page 204, to add nine new remote manual containment isolation valves. These new valves were added to the FitzPatrick plant to comply with the requirements of General Design Criteria No. 57 of Appendix A to 10 CFR 50 and the FitzPatrick Final Safety Analysis Report.


The Authority hereby withdraws this amendment application. The Authority is in the final phases of preparing an amendment application that will revise and update Table 3.7-1. This proposed change will not only incorporate the changes described in Reference 1, but several other changes necessary to bring the table up to date. This technical specification change will be submitted to the NRC by January 15, 1986.

8511050053 851101
PDR ADOCK 05000333
P PDR

Acc
1/10

If you have any questions, please contact Mr. J. A. Gray, Jr. of my staff.

Very truly yours,


John C. Brons
Senior Vice President
Nuclear Generation

cc: Office of the Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, NY 13093

Mr. J. D. Dunkleberger
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2, Empire State Plaza
Albany, New York 12223