



CHARLES CENTER • P. O. BOX 1475 • BALTIMORE, MARYLAND 21203

ARTHUR E. LUNDVALL, JR.  
VICE PRESIDENT  
SUPPLY

December 16, 1985

U. S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Washington, D. C. 20555

ATTENTION: Mr. Edward J. Butcher, Jr., Chief  
Operating Reactors Branch #3  
Division of Licensing

SUBJECT: Calvert Cliffs Nuclear Power Plant  
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318  
Withdrawal of Request for Amendment

REFERENCES: (a) Letter from Mr. A. E. Lundvall, Jr. to Mr. J. R. Miller, dated  
October 12, 1984, Request for Amendment

Gentlemen:

The Baltimore Gas and Electric Company hereby withdraws two proposed changes contained in Reference (a), which would have permitted an out-of-service duration of seven days for any diesel generator and eliminated the phrase STAGGERED TEST BASIS from the Surveillance Requirements. The allowed outage time for diesel generators is currently 72 hours but we originally requested an extension of seven days for Action Statements 3.8.1.1.b, c, and e in Reference (a). We had also asked for the STAGGERED TEST BASIS phrase to be eliminated from Surveillance Requirement 4.8.1.1.2.a.

It is our understanding that the NRC staff believes additional justification for the proposed changes discussed above is needed and that the NRC currently has studies in progress that could affect a decision with respect to the above items. Accordingly, we will resubmit the proposed changes at a later date with additional justification and/or modification.

8512240053 851216  
PDR ADOCK 05000317  
P PDR

Acc'd  
1/0

ADD

Mr. Edward J. Butcher, Jr.  
December 16, 1985  
Page 2

Should you have further questions regarding this matter, we would be pleased to discuss them with you.

Very truly yours,

A handwritten signature in cursive script, reading "Arthur E. Lundvall, Jr.", followed by a small flourish.

Arthur E. Lundvall, Jr.  
Vice President - Supply

AEL/SRC/dlm

cc: D. A. Brune, Esquire  
G. F. Trowbridge, Esquire  
D. H. Jaffe, NRC  
T. Foley, NRC  
T. Magette, DNR