

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-85-74 Date: 10/31/85

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: Diablo Canyon Unit 1  
San Luis Obispo County, California  
Docket No. 50-275

Emergency Classification  
\_\_\_ Notification of Unusual Event  
\_\_\_ Alert  
\_\_\_ Site Area Emergency  
\_\_\_ General Emergency  
XX Not Applicable

SUBJECT: CONDENSER TUBE LEAK

On October 30, 1985, due to a condenser tube leak, Diablo Canyon Unit 1 reduced power and achieved Mode 2 ( 5% rated thermal power) at 11:18 am. At 9:04 pm (PST), on October 30, 1985, Diablo Canyon Unit 1 achieved Mode 3 (hot standby), and continued to cooldown to Mode 5 (cold shutdown). Plans are under way to drain and refill the steam generators with a planned outage of three days. The condenser tube leak was severe enough to go through the inline demineralizers causing high conductivity levels in the steam generators. Condenser tube leak location has not yet been determined.

The licensee notified the media October 31 through their daily status summary.

This information is current as of 9:00 am (PST) on October 31, 1985.

CONTACT: D. Pereira  
FTS 463-3788

M. Mendonca  
(805) 595-2352

DISTRIBUTION

H St. <u>1:17</u>	MNBB <u>1:15</u>	Phillips <u>12:28</u>	E/W <u>12:40</u>	Willste <u>12:42</u>	Air Rights <u>1:19</u>	Mail:
Chairman Pallidino	EDO	NRR	IE	NMSS		ADM:DMB
Comm. Zech	PA		OIA	RES		DOT:Trans Only
Comm. Bernthal	MPA		AEOD			
Comm. Roberts	ELD					
Comm. Asselstine						
SECY		Regions: <u>RI-1:40, RII-</u>			<u>RIII-1:58, RIV-2:00</u>	
ACRS		INPO <u>2:12</u>	NSAC <u>2:10</u>			
CA		Licensee: <u>3:45</u>				
PDR		(Reactor Licensees)				
		Resident Inspector <u>3:55</u>				
				REGION V: FORM 211		
				(Revised 3/14/83)		

8511050261 851031  
PDR I&E  
PNO-V-85-074 PDR

IE-34

01