

Georgia Power Company  
333 Piedmont Avenue  
Atlanta, Georgia 30308  
Telephone 404 526-6526

Mailing Address:  
Post Office Box 4545  
Atlanta, Georgia 30302

L. T. Gucwa  
Manager Nuclear Engineering  
and Chief Nuclear Engineer



NED-84-376  
0050y

December 18, 1985

Director of Nuclear Reactor Regulation  
Attention: Mr. D. Muller, Project Director  
BWR Project Directorate No. 2  
Division of Boiling Water Reactor Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

NRC DOCKETS 50-366  
OPERATING LICENSES NPF-5  
EDWIN I. HATCH NUCLEAR PLANT UNIT 2  
BUILDING SETTLEMENT

Gentlemen:

The following information replaces the information contained in our submittal of December 7, 1983, as supplemented by our letter of May 4, 1985. Based on data from a survey conducted during July 1985, the values for the total settlement of the Control Building, the Intake Structure, and Unit 1 Reactor Building are 59%, 65%, and 70%, respectively, of allowable settlement. Through the analysis, we have concluded that the allowable settlement values in the Technical Specifications are more restrictive than the FSAR in that the Technical Specifications allow a smaller amount of settlement than the FSAR.

We would be pleased to meet with you to discuss any questions which you might have at any time during your review of our submittals at our mutual convenience. If you have further questions, please contact this office.

Very truly yours,

L. T. Gucwa

MJB/lc

xc: H. C. Nix, Jr.  
J. N. Grace (NRC- Region II)  
Senior Resident Inspector

8512240151 851218  
PDR ADOCK 05000321  
P PDR

A001  
1/0