

TEXAS UTILITIES GENERATING CO CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	1 of 27

NONDESTRUCTIVE EXAMINATION PERSONNEL TRAINING, QUALIFICATION AND CERTIFICATION	PREPARED BY: <u>DR Dodson</u>	<u>2-3-84</u> DATE
	APPROVED BY: <u>CT [Signature]</u> <u>JLG [Signature]</u>	<u>2/3/84</u> DATE

1.0 REFERENCES

1-A American Society for Nondestructive Testing, SNT-TC-1A, 1980

2.0 GENERAL

2.1 PURPOSE

This procedure defines the personnel training, qualification and certification requirements implemented at CPSES to meet the intent of Reference 1-A.

2.2 SCOPE

This procedure applies to personnel performing nondestructive examinations (NDE) or providing technical support of NDE at CPSES. The requirements contained herein are not applicable to personnel under the jurisdiction of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section III, Division I, NX-8000.

2.3 DEFINITIONS

2.3.1 Nondestructive Examination

A method of examining materials for the detection of discontinuities without impairing the usefulness of the material.

2.3.2 Qualification

Skill, training and experience required for personnel to properly perform the duties of a specific job.

CONTROLLED COPY
CONTROL NO. M-002

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	2 of 27

2.3.3 Certification

Documented testimony by the Site NDE Level III to the acceptability of the qualifications of personnel.

2.3.4 Levels of Certification

There are three levels of certification in each method or discipline:

- a. Level I
- b. Level II
- c. Level III

2.4 GENERAL REQUIREMENTS

2.4.1 Certification

Personnel performing NDE shall be trained, qualified and certified in accordance with this procedure.

NDE personnel currently certified at CPSES are considered certified until the expiration of their current certification. Recertification shall be in accordance with this instruction.

Level III personnel certified to equivalent programs may be certified by the TUGCO QA Supervisor without re-examination, providing:

- a. The TUGCO QA Supervisor has reviewed and accepted the program under which the individual was certified as being equivalent to this program;
- b. The individuals previous certification was by examination; and
- c. The certification and supporting documents are placed in the employees certification file.

The effective period of certification for all certifications issued in accordance with this instruction shall be three years. Certification of qualification shall be documented on Attachment 1. Certifications may be revoked/suspended by the Site NDE Level III when reason exists to question the individual's ability to perform NDE satisfactorily.

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 9 1964	3 of 27

2.4.2 Qualifications

Three levels of certification are specified for personnel who perform NDE in accordance with approved CPSES procedures or instructions. Education, training and experience requirements for each level of certification are prescribed in this instruction. Personnel may be qualified and certified to perform examinations of limited scope at each respective level of certification.

The number of hours of training and the amount of work time experience required for inspection personnel who perform only one operation of an examination method that consists of more than one operation, or perform examinations of limited scope may be less than that specified, as approved by the Site NDE Level III.

Personnel holding limited certifications perform only those operations allowed within the restricted scope of the certification. When performance of an examination requires operations beyond the scope of the limited certification, personnel qualified to perform those operations shall be utilized.

Certification limitations are documented on Attachment 1.

2.4.3 Prior Experience or Training

Previous training and/or work experience may be used to partially or fully satisfy the qualification requirements prescribed in this procedure, when documented and approved by the Site NDE Level III.

2.4.4 Examinations

Candidates for certification are given examinations covering the general, specific and practical aspects of the method. Examinations are prepared and approved by the Site NDE Level III and administered by the Site NDE Level III or his designee.

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 3 1984	4 of 27

2.4.5 Grading of Examinations

A minimum composite grade of 80 percent is required for qualification of Level I and Level II personnel. In addition, individual passing grades for the general, specific and practical examinations are 70 percent or greater. Test objects used in the practical examination contain known indications, and at least 90 percent of the known indications must be found during the practical examination. For Level III, a composite grade of 80 percent is required, and individual passing grades for the basic, method and specific are 80 percent or greater.

Failure by a candidate to meet the above required grades will result in denial of certification.

2.4.6 Grading Factor

A percentile weight factor is applied to the raw scores of the various examinations, i.e., general, specific and practical. These factors are as follows:

Level I and II:

General	0.3
Specific	0.3
Practical	0.4

Level III:

Basic	0.3
Method	0.3
Specific	0.4

2.4.7 Re-examination

Personnel failing to attain the required grades must wait at least 30 days or show evidence of having received suitable additional training as determined by the Site NDE Level III before re-examination.

Personnel who fail two consecutive examinations for the same certification, are not eligible for certification in that method.

2.4.8 Recertification

NDE personnel are recertified at least once every three years in accordance with one of the following criteria:

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 3 1984	5 of 27

a. Re-examination in the practical aspects of the method using a grade factor of 1.0; or

b. Re-examination in the general, specific and practical aspects of the method using the grade factors listed in 2.4.6.

QC Supervisors shall notify the Site NDE Level III of NDE personnel under their supervision having interrupted service exceeding six months. NDE personnel having interrupted service exceeding six months shall be recertified as described in 2.4.8 a.

2.4.9 Termination and Reinstatement

All certifications are automatically revoked when personnel terminate employment at CPSES.

The certification of employees terminated and re-hired within six months may be reinstated without additional testing, if approved by the Site NDE Level III, or by the TUGCO QA Supervisor for Level III personnel.

New employees may be recertified to a former level of certification, granted by a previous employer based on an examination in accordance with this instruction provided all of the following conditions are met to the satisfaction of the Site NDE Level III:

- a. The new employee has proof of prior certification and such documentation is placed in his certification file;
- b. The new employee's number of hours of training and work time experience are verified, and meet the requirements of Attachment 2;
- c. The new employee was working in the capacity to which he has been certified within six months of his termination; and
- d. The new employee is being recertified within six months of his termination.

3.0 INSTRUCTION

3.1 GENERAL

Prior to performing inspections or examinations, inspection personnel must satisfactorily complete the applicable

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	6 of 27

requirements of this procedure and be certified as either Level I, II, or III.

3.2 EDUCATION, TRAINING AND EXPERIENCE

Personnel considered for certification are required to have sufficient education, training and experience to ensure understanding of the principles and procedures of those areas of responsibility in which they are being considered for certification. Education and experience requirements are prescribed on Attachment 2.

3.3 INDOCTRINATION

The following are minimum indoctrination and training requirements for inspection personnel. Indoctrination requirements shall normally be satisfied within the first sixty days of employment, and shall be documented on Attachment 3.

Personnel satisfying documented technical training requirements may be assigned to inspection or testing functions prior to completion of the QA indoctrination requirements.

a. 10CFR50, Appendix B; ANSI N45.2

The method of presentation of this material will be by reading/study assignment, informal discussions, seminars or other appropriate means. An oral checkout covering ANSI N45.2 and the 18 Criteria will be given by the responsible supervisor who shall, upon satisfactory completion, so note by signing the General Training Outline (Figure 1).

b. Industry Standards

Inspection personnel should become familiar with prepared standards (ANSI, IEEE, ASME, etc.) applicable to assigned duties. The method of presentation may be through study, formal seminars, or other appropriate means. Supplemental exposure is acquired by daily association with these standards. The familiarization is a continuing process and as such requires no formal checkout.

c. 10CFR50.55(e) and 10CFR 21

The method of presentation will be by assigned reading, study and/or training sessions. Upon completion and

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	7 of 27

understanding of the basic requirements as they relate to job duties and responsibilities, the individual shall so note by signing the Training Outline. Formal or informal training sessions shall emphasize the need for prompt reporting of product deficiencies or failures to the TUGCO Site QA Supervisor.

3.4 RESPONSIBILITY

3.4.1 Trainee

In the process of being qualified and certified to at least Level I, an individual is considered a Trainee. A Trainee works along with a certified individual and does not conduct independently any test, interpret any results of a test, or write a report of test results.

3.4.2 Level I

A Level I individual shall be qualified to properly perform specific calibrations, specific tests and specific evaluations according to written instructions and to record the results. He shall receive the necessary guidance or supervision from a certified Level II or III individual.

3.4.3 Level II

A Level II individual shall be qualified to set up and calibrate equipment and to interpret and evaluate results with respect to applicable codes, standards and specifications. He shall be familiar with the scope and limitations of the method and shall exercise assigned responsibility for on-the-job training and guidance of Trainees and Level I personnel. He shall be able to prepare written instructions and to organize and report nondestructive testing investigations.

3.4.4 Level III

An NDE Level III shall be responsible for establishing techniques; interpreting codes, standards and specifications; and designating the particular test method and technique to be used. He shall be responsible for the complete operation he is qualified for and assigned to, and shall be capable of evaluating results in terms of existing codes, standards and specifications. He shall have sufficient practical background in applicable techniques to assist the design engineer in establishing acceptance criteria where none are otherwise available. He shall have general familiarity with

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	8 of 27

other commonly used methods. He shall be responsible for the training and examination of Level I and Level II personnel for certification.

3.5 LEVEL I AND II EXAMINATIONS

Each candidate for Level I and II certification is given a three-part examination covering the general, specific and practical aspects of examination.

All three parts of the examination are administered by the Site NDE Level III or his designee.

The written general and specific examinations are administered without access to reference material (closed book) except for reference material specifically approved and deemed necessary by the Site NDE Level III.

3.5.1 General Examination

General examinations shall cover the basic test principles relative to the applicable method.

The designated number of questions is as follows:

<u>TEST METHOD</u>	<u>LEVEL I QUESTIONS</u>	<u>LEVEL II QUESTIONS</u>
Magnetic Particle	30	30
Ultrasonics	40	40
Liquid Penetrant	30	30
Leak Testing (Bubble Test Vacuum Box)	20	20

3.5.2 Specific Examination

Specific examinations shall cover the equipment, operating procedures, examination techniques, project specifications or codes and acceptance criteria in the project examination procedures or instructions.

The designated number of questions is as follows:

<u>TEST METHOD</u>	<u>LEVEL I QUESTIONS</u>	<u>LEVEL II QUESTIONS</u>
Magnetic Particle	20	15
Ultrasonics	20	20
Liquid Penetrant	20	15
Leak Testing (Bubble Test Vacuum Box)	15	15

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	9 of 27

3.5.3 Practical Examination

Proficiency shall be demonstrated in selecting and performing the applicable nondestructive examinations and evaluating the results obtained on one or more samples containing known indications, approved by the Site NDE Level III.

At least 90 percent of the known indications must be detected.

At least ten different checkpoints requiring an understanding of test variables and QA Procedure or Instruction procedural requirements shall be included in the practical examination.

The description of the specimen, the examination procedure including checkpoints, and results of the examination shall be documented.

NOTE: The designated number of questions for test methods of limited scope may be less than that specified when approved by the Site NDE Level III, (eg, UTDT.)

3.6 LEVEL III CERTIFICATION REQUIREMENTS

The TUGCO QA Supervisor is responsible for examining and certifying the Site NDE Level III in accordance with this procedure.

3.6.1 Level III Education and Experience Requirements

Individuals being considered for NDE Level III in any one method must meet one of the following educational and/or experience requirements:

- a. Graduate of a four-year accredited engineering or science college or university with a degree in Engineering or Science plus one year's experience in an assignment comparable to that of a Level II in the applicable test method;
- b. Completion with a passing grade of at least two years of engineering or science study at an accredited university, college or technical school plus two years experience as a certified Level II in the applicable test method; or

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	10 of 27

- c. Four years experience as a certified Level II in the applicable testing method.

3.6.2 Level III Examinations

The Level III examination consists of the following:

- a. Basic Examination (Required only once when more than one method of examination is taken).

Twenty (20) questions relating to understanding the SNT-TC-1A document.

Fifteen (15) questions relative to applicable materials, fabrications, and product technology.

Fifteen (15) questions which are selected from or are similar to published Level II questions for other appropriate NDT methods.

- b. Method Examination (for each method).

Thirty questions relating to fundamentals and principles, which are selected from or are similar to published ASNT Level III questions for each method, and

Fifteen (15) questions relating to application and establishment of techniques and procedures which are selected from or are similar to the published ASNT Level III questions for each method, and

Twenty (20) questions relating to capability for interpreting codes, standards, and specifications relating to the method.

- c. Specific Examination (for each method).

Twenty (20) questions relating to specifications, equipment, techniques, and procedures applicable to the employer's product(s) and methods employed, and to the administration of the employer's written practice.

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	11 of 27

3.7 VISION REQUIREMENTS

3.7.1 Near Distance Visual Acuity

Each candidate for certification in inspection methods to Level I, II or III shall be examined for near distance visual acuity and color perception on an annual basis.

The examination is given to assure natural or corrected near distance acuity in at least one eye such that the candidate is capable of reading a minimum of Jaeger Number 1 letters on a standard Jaeger Test, at a distance of not less than 12 inches (30.5 cm). The ability to perceive an ortho-rater minimum of 8 is also acceptable. Similar tests may be used if approved by the Site NDE Level III.

3.7.2 Color Perception

Individuals shall be capable of distinguishing and differentiating contrast between colors, as evidenced by correctly identifying at least 10 out of the first 11 plates of the Ishihara Color Perception Eye Examination.

Personnel failing to correctly identify at least 10 of the first 11 plates shall be given a practical examination approved by the Site NDE Level III using colors which the individual can expect to encounter in his specific assignment. The results of the practical eye examination shall be documented on the eye examination form.

The personnel training files of each certified individual shall contain a copy of the completed eye examination form.

3.8 TRAINING PROGRAM

Training programs for each NDE method are developed by cognizant Quality Engineers and approved by the Site NDE Level III.

Training programs shall be presented by instructors designated by the Site NDE Level III, (Attachment 4) using lesson plans approved by the Site NDE Level III. Records of attendance at classroom training shall be documented on Training Records (Attachment 5) and maintained in the individual's personnel training and certification file.

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	12 of 27

3.8.1 Reference Material

Reference material used as sources of information for the training programs shall be approved by the Site NDE Level III.

3.9 CERTIFICATION RECORDS REQUIREMENTS

3.9.1 Certification Documentation

Written certification is provided in accordance with Attachment 1. The following items shall be documented on the personnel certification record, as applicable:

- a. Name and Social Security Number;
- b. Level of certification and test method;
- c. Highest level of education completed;
- d. Training received;
- e. Date of eye examination;
- f. Total accredited work time experience;
- g. Certification exam numbers, date completed and scores;
- h. Percentile weight assigned to each examination;
- i. Composite grade of all examinations;
- j. Remarks or comments on above areas;
- k. Date of certification or recertification;
- l. Date of certification expiration; and
- m. Signature of certifying authority;

Training and Certification Files

Personnel training and certification files shall contain the following documentation, as applicable;

- a. Certification Record(s) (Attachment 1);
- b. A summary of Education and/or work Experience (Attachment 6) developed from documented verification letters;

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	13 of 27

- c. QA/QC Personnel Training History Form (Attachment 7);
- d. Visual Acuity Examination (Attachment 8);
- e. NDE Work Time Experience Statements with On the Job Training Log (Attachment 9);
- f. Required Reading List(s) (Attachment 10);
- g. Examination Answer Sheets (Attachment 11), for current certifications;
- h. A Resume, prepared in the format of Attachment 12;
- i. Evidence of prior certification(s); and
- j. Evidence of prior training pertinent to qualifications;
- k. Copies of instructor designation letters (Attachment 4).

3.9.2 DOCUMENTATION FILING

Documentation shall be maintained by the QA Training Coordinator. Files shall not be removed from the controlled area without the concurrence of the QA Training Coordinator.

SUBCONTRACTED NDE PERSONNEL

Subcontracted NDE personnel, including the NDE Level III are certified by the subcontractor in accordance with written procedures which comply with Reference 1-A and have been approved by the TUGCO QA Supervisor.

The Subcontractor's personnel qualifications shall be reviewed by the TUGCO QA Supervisor to verify compliance with the Subcontractors written practice. The Subcontractors NDE Level III shall be authorized by the TUGCO QA Supervisor to act for TUGCO. Approval of the written procedure and personnel qualifications shall be documented by memo to the subcontracted agency by the TUGCO QA Supervisor. Copies of these records shall be retained.

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 0 1964	14 of 27

ATTACHMENT 1

TEXAS UTILITIES GENERATING COMPANY

P. O. BOX 1000 - GLEN ROSE, TEXAS 75040

QUALITY ASSURANCE DEPARTMENT

CERTIFICATION RECORD

Project: CPSES Job No. 35-1195 Page of

NAME: SOCIAL SECURITY NO.:
CERTIFICATION: INITIAL RECERT

QUALIFICATION SUMMARY

EDUCATION:

HIGHEST LEVEL OF EDUCATION COMPLETED:
(SEE PERSONNEL EDUCATION AND EXPERIENCE SUMMARY)

TRAINING COMPLETED: (AS APPLICABLE)

TRAINING SUBJECT TOTAL HOURS COMPLETED
(SEE QA/QC PERSONNEL TRAINING HISTORY)

VISION EXAMINATION: (AS APPLICABLE)

CURRENT VISION EXAMINATION VERIFIED SATISFACTORY AT THE TIME OF CERTIFICATION
VISION EXAMINATION DATE

WORK TIME EXPERIENCE: (AS APPLICABLE)

TOTAL ACCREDITED WTE: YRS. NOS.

SEE PERSONNEL EDUCATION AND EXPERIENCE SUMMARY

CERTIFICATION EXAM DATE: (AS APPLICABLE)

	EXAM NO.	DATE COMPLETED	RAW SCORE	WEIGHT	WEIGHTED GRADE
GENERAL					
SPECIFIC					
PRACTICAL					

COMPOSITE GRADE

REMARKS:

TYPE AND LEVEL OF CERTIFICATION:

LIMITATIONS:

THIS IS TO CERTIFY THAT THE ABOVE NAMED INDIVIDUAL HAS SATISFIED THE QUALIFICATION REQUIREMENTS FOR THE CERTIFICATION STATED ABOVE AS DEFINED BY CP-QP- AND IS CERTIFIED TO PERFORM BASED UPON

TYPICAL

CERTIFICATION DATE

EXPIRATION DATE

CERTIFIED BY: DATE

Signature SITE HQE LEVEL III

ATTACHMENT 2

TEXAS UTILITIES GENERATING COMPANY

P. O. BOX 1000 CLEBURNE, TEXAS 76033

TRAINING AND EXPERIENCE

REQUIRED TRAINING (HOURS)

	RADIOGRAPHY		LIQUID PENETRANT		MAGNETIC PARTICLE		LEAK TESTING BUBBLE TEST		ULTRASONIC	
	Level I	Level II	Level I	Level II	Level I	Level II	Level I	Level II	Level I	Level II
Completion of a two year engineering or science degree at a university, college, or technical trade school	12	40	4	4	8	4	2	2	24	40
High School graduation diploma or equivalent	20	40	4	8	12	8	2	4	40	40
Grammar school graduate or demonstrated proficiency or additional training	80	100	12	16	24	16	2	4	40	80

WORK TIME EXPERIENCE

All education levels as listed above	3		9		1		2		1		3		2		3		9	
	mo	no	mo	no	mo	no	mo	no	mo	no	mo	no	hr.	hrs	mo	no	mo	no

- NOTE: 1. For level II certification, the experience shall consist of time at level I. If a person is being qualified directly to level II with no time at level I, the required experience shall consist of the sum of the times required for level I and level II as a trainee and the hours of training required for level I and level II in total shall apply.
2. Credit for experience may be gained simultaneously in two or more disciplines. The candidate must spend at least 25% of his work time in each discipline for which experience is being claimed.
3. Training requirements may be satisfied by the course described in General Requirements of this Instruction.
4. This training may be satisfied through directed instruction under the supervision of the site NDE level III.
5. Documented training time, in the applicable NDE method, may be credited to the candidate's training requirements for certification if approved upon evaluation by the site NDE level III.

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	16 of 27

ATTACHMENT 3

TEXAS UTILITIES GENERATING COMPANY

P. O. BOX 1000 - CLEWIS, TEXAS 79009

COMANCHE PEAK STEAM ELECTRIC STATION

GENERAL TRAINING OUTLINE

TO BE COMPLETED BY: _____
(60 Days After Employment)

NAME: _____

DOCUMENT:

SIGNATURE/DATE

1. Final Safety Analysis Report
Chapter(s) _____
2. Title 10 Code of Federal Regulations,
Part 50, Appendix B and ANSI N45.2
3. NRC Regulatory Guides (As Assigned)
4. Industry Standards (As Assigned)
5. QA/QC Procedures and Instructions
(As Assigned)
6. Title 19 Code of Federal Regulations,
Part 21 and 10CFR50.55e
7. Other applicable Documents as listed
below:

TYPICAL

VERIFIED BY _____ DATE _____

OUTLINE APPROVED BY: _____ DATE: _____

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	17 of 27

ATTACHMENT 4

TEXAS UTILITIES GENERATING COMPANY

OFFICE MEMORANDUM

To: _____ Glen Rose, Texas

Subject: _____ INSTRUCTOR DESIGNATION

IM #

TO:

DATE:

FROM:

The following named individual is authorized to conduct formal classroom training

in: _____

based upon _____

NAME: _____

SSN#: _____

TYPICAL

Site NDE Level III _____

cc: Personnel Training File

20 of 27

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 5 1984	21 of 27

ATTACHMENT 8

TEXAS UTILITIES GENERATING COMPANY
P. O. BOX 1000 GLEN ROSE, TEXAS 75043

VISUAL ACUITY EXAMINATION	Project
	Department

Name

Social Security No.

HAS RECEIVED THE FOLLOWING EYE EXAMINATIONS.

1. NEAR VISION ACUITY USING THE J-1 SCALE
OF A SNELLEN/JAEGER NEAR VISION ACUITY
TEST CARD.

☐ UNCORRECTED ☐ PASSED
☐ CORRECTED ☐ FAILED

2. DISTANT VISION ACUITY USING A SNELLEN
DISTANT VISION SCALE FOR 20/30 OR
BETTER, IN AT LEAST ONE EYE.

☐ UNCORRECTED ☐ PASSED
☐ CORRECTED ☐ FAILED

3. COLOR PERCEPTION TEST USING THE ISHISARA
COLOR VISION TEST, OR ITS EQUIVALENT.

NUMBER OF PLATES TESTED _____
NUMBER OF PLATES CORRECTLY READ _____

TYPICAL

Examiner/Title Date

Training Coordinator Date

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	22 of 27

ATTACHMENT 9

INTEROFFICE MEMO

TO: QA TRAINING COORDINATOR DATE:

FROM:

SUBJECT: CPSES, Job 35-1195
Documentation of NDE Work-time Experience

TYPICAL

_____, has
(Name) (Social Security No.)
completed _____ months work-time experience in _____
(NDE Method)
during the period of _____ to _____
(Month and Year) (Month and Year)
at _____
(Sponsor and Location)

I further attest to the fact that this candidate for certification spent at least 25 percent of actual work-time during this period in this NDE method and that performance was satisfactory.

The above statement is true and correct to the best of my knowledge. Any misrepresentation of the above facts may be grounds for my dismissal.

Signature - Immediate Supervisor

Title

Signature - Candidate

cc: Personnel Training and Certification File

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1984	23 of 27

ATTACHMENT 9 (CONT.)

NAME _____

BADGE # _____

- * Certified Inspector must be Certified to at least Level II in the Discipline for which he is Administering O.J.T.

O.J.T. LOG

INDICATE BELOW O.J.T. TRAINING HOURS AND INSPECTION METHODS

[illegible]

TYPICAL

NOTE: Evidence of P.I.T. hours shall be indicated by the Certified Instructor and Trainee signatures in the appropriate blocks above.

SUPERVISOR APPROVAL _____ DATE _____

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 8 1997	25 of 27

ATTACHMENT 11

TEXAS UTILITIES GENERATING COMPANY

P. O. BOX 1000 GLEN ROSE, TEXAS 75043

CERTIFICATION EXAMINATION ANSWER SHEET

PROJECT: _____ PAGE ____ OF ____

NAME _____ S/S NO. _____

DATE _____ TEST NO. _____ PERCENTAGE SCORE _____

1. ABCDEF	14. ABCDEF	27. ABCDEF	40. ABCDEF
2. ABCDEF	15. ABCDEF	28. ABCDEF	41. ABCDEF
3. ABCDEF	16. ABCDEF	29. ABCDEF	42. ABCDEF
4. ABCDEF	17. ABCDEF	30. ABCDEF	43. ABCDEF
5. ABCDEF	18. ABCDEF	31. ABCDEF	44. ABCDEF
6. ABCDEF	19. ABCDEF	32. ABCDEF	45. ABCDEF
7. ABCDEF	20. ABCDEF	33. ABCDEF	46. ABCDEF
8. ABCDEF	21. ABCDEF	34. ABCDEF	47. ABCDEF
9. ABCDEF	22. ABCDEF	35. ABCDEF	48. ABCDEF
10. ABCDEF	23. ABCDEF	36. ABCDEF	49. ABCDEF
11. ABCDEF	24. ABCDEF	37. ABCDEF	50. ABCDEF
12. ABCDEF	25. ABCDEF	38. ABCDEF	
13. ABCDEF	26. ABCDEF	39. ABCDEF	

TYPICAL

EXAMINER

DATE

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP-2.4	4	FEB 3 1984	26 of 27

ATTACHMENT 12

NAME

TITLE

TYPICAL

SUMMARY OF EXPERIENCE

PROJECT TYPES

PERSONAL DATA

Date of Birth _____
Place of Birth _____
Marital Status _____

ACTIVITIES (PROJECT)

EDUCATION

High School/Date Graduated _____
College/Degree/Dates Attended _____

LANGUAGE PROFICIENCIES

REGISTRATIONS

RESIDENT FOREIGN EXPERIENCE

EMPLOYMENT HISTORY

Company _____ Since _____ years
Company _____
Company _____ years

Social Security No. _____ Date _____

TEXAS UTILITIES GENERATING CO. CPSES	PROCEDURE NUMBER	REVISION	ISSUE DATE	PAGE
	CP-QP 2.4	4	FEB 3 1984	27 of 27

ATTACHMENT 12 (CONT.)

NAME
TITLE

DETAILED PROFESSIONAL EXPERIENCE

Company & Dates

Title

Responsibilities

Company & Dates

Title

Responsibilities

Company & Dates

Title

Responsibilities

Company & Dates

Title

Responsibilities

TYPICAL