

October 9, 1985

DMB 616

Docket No. 50-312

Mr. Ronald J. Rodriguez
Assistant General Manager, Nuclear
Sacramento Municipal Utility District
6201 S Street
P. O. Box 15830
Sacramento, California 95813

DISTRIBUTION

Docket File
NRC PDR
L PDR
ORB#4 Rdg
HThompson
OELD
EJordan
BGrimes
JPartlow
ACRS-10

RIgram
SMiner
Gray File
EBrach
Hornstein
WPaulson
GEdison

Dear Mr. Rodriguez:

SUBJECT: RANCHO SECO NUCLEAR GENERATING STATION RESPONSE TO GENERIC
LETTER 83-28, ITEMS 3.1.3 AND 3.2.3

We have completed our review of the information you provided in response to Generic Letter 83-28, Items 3.1.3 and 3.2.3. Generic Letter 83-28 addressed safety issues which were raised following two ATWS events at the Salem Nuclear Power Plant. Licensees were requested to review and identify post-maintenance test requirements included in Technical Specifications which could be demonstrated to degrade rather than enhance safety. The Rancho Seco response, dated May 23, 1985, concluded that there were no post-maintenance testing requirements which degraded safety.

We contracted EG&G Idaho, Inc. to review the responses to Generic Letter 83-28, Items 3.1.3 and 3.2.3. Based on this review, we have concluded that the licensee's response is acceptable and that there are no post-maintenance testing requirements at Rancho Seco which degrade safety. The contractor's Technical Evaluation Report (TER) and our Safety Evaluation Report (SER) are enclosed for your information.

Sincerely,

ORIGINAL SIGNED BY
JOHN F. STOLZ

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

Enclosures:

1. Technical Evaluation Report
2. Safety Evaluation Report

cc w/enclosures:
See next page

ORB#4:DL
SMiner
10/9/85

ORB#4:DL
GKalman
10/9/85

ORB#4:DL
JStolz
10/9/85

8511070273 851009
PDR ADOCK 05000312
P PDR

Mr. R. J. Rodriguez
Sacramento Municipal Utility District

Rancho Seco Nuclear Generating
Station

cc:

Mr. David S. Kaplan, Secretary
and General Counsel
Sacramento Municipal Utility
District
6201 S Street
P. O. Box 15830
Sacramento, California 95813

Sacramento County
Board of Supervisors
827 7th Street, Room 424
Sacramento, California 95814

Ms. Helen Hubbard
P. O. Box 63
Sunol, California 94586

Thomas Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N.W.
Washington, D.C. 20036

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 220, 7910 Woodmont Avenue
Bethesda, Maryland 20814

Resident Inspector/Rancho Seco
c/o U. S. N. R. C.
14410 Twin Cities Road
Herald, California 95638

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

Director
Energy Facilities Siting Division
Energy Resources Conservation &
Development Commission
1516 - 9th Street
Sacramento, California 95814

Mr. Joseph O. Ward, Chief
Radiological Health Branch
State Department of Health Services
714 P Street, Office Building #8
Sacramento, California 95814