



Carolina Power & Light Company

85 DEC 17 P 3: 52

Brunswick Steam Electric Plant

P. O. Box 10429

Southport, NC 28461-0429

December 10, 1985

FILE: B09-13510C

SERIAL: BSEP/85-2054

Dr. J. Nelson Grace, Administrator
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street NW
Atlanta, GA 30323

BRUNSWICK STEAM ELECTRIC PLANT UNIT 1

DOCKET NO. 50-325

LICENSE NO. DPR-71

SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8 AND
PURSUANT TO TECHNICAL SPECIFICATION 6.9.2 (1-SR-85-010)

Dear Dr. Grace:

During power operation of Units 1 and 2, a Unit 1 designated fire barrier LCO was initiated on November 18, 1985, for a fire door in the units' common emergency ac Diesel Generator (D/G) Building.

The subject fire door, No. 107, is located at fire barrier penetration seal No. DG-2-172B on the 23-foot elevation of the building. Door No. 107 is an access interface between the respective rooms of D/G Nos. 2 and 3. The LCO was initiated due to the inability of the door to properly close as a result of excessive differential pressure conditions at the door. On November 25, 1985, the specified seven-day time frame of the LCO was exceeded. Until resolution of the excessive differential pressure condition affecting fire doors is complete, appropriate LCOs and fire watches will be maintained as required.

Very truly yours,

C. R. Dietz, General Manager
Brunswick Steam Electric Plant

RMP/mbh

Enclosure

cc: NRC Document Control Desk

8512270222 851210
PDR ADOCK 05000325
S PDR

IE 17