

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Richard A. Muench
Vice President Engineering

February 28, 1997

ET 97-0019

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Reference: 1) Letter ET 96-0075, dated December 3, 1996, from
R. A. Muench, WCNOG, to the USNRC
2) NRC Letter, dated January 21, 1997, from James C.
Stone, USNRC, to Neil S. Carns, WCNOG
Subject: Docket No. 50-482: Withdrawal of Proposed Technical
Specification Change

Gentlemen:

In Reference 1 the Wolf Creek Nuclear Operating Corporation (WCNOG) transmitted an application for amendment to Facility Operating License No. NPF-42 for Wolf Creek Generating Station (WCGS) requesting to change an engineered safety features actuation system instrumentation Action Statement in the Wolf Creek Generating Station Technical Specifications. In Reference 2 the NRC requested additional information to support the review of WCNOG's request. WCNOG hereby requests the withdrawal of the application for amendment transmitted by Reference 1.

WCNOG has reevaluated the proposed Technical Specification Change and determined that the request should be withdrawn. This decision is based on our determination that WCNOG is able to procedurally comply with the current action statement (Action 16) for Item 7.b., RWST Level - Low-Low Coincident with Safety Injection, in Technical Specification Table 3.3-3, Engineered Safety Features Actuation System Instrumentation. Therefore, changing to Action 28, as requested by Reference 1, is not required.

1/0
A001

9703070166 970228
PDR ADDCK 05000482
P PDR


070075



ET 97-0019
Page 2 of 2

If you have any questions concerning this matter, please contact me at (316) 364-8831, extension 4034, or Mr. Richard D. Flannigan, at extension 4500.

Very truly yours,



Richard A. Muench

RAM/jad

cc: V. L. Cooper (KDHE)
J. E. Dyer (NRC)
W. D. Johnson (NRC)
J. F. Ringwald (NRC)
J. C. Stone (NRC)