



Nuclear Construction Division
Robinson Plaza, Building 2, Suite 210
Pittsburgh, PA 15205

2NRC-5-150
(412) 787-5141
(412) 923-1960

Telecopy (412) 787-2629
December 20, 1985

United States Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Mr. Hugh L. Thompson, Jr., Director
Division of Licensing
Office of Nuclear Reactor Regulation

SUBJECT: Beaver Valley Power Station - Unit No. 2
Docket No. 50-412
Steam Generator Level Control

REFERENCES: a) NRC letter dated November 22, 1985, from Mr. H. Thompson to Mr. J. Carey
b) NRC letter dated June 25, 1985, from Mr. Victor Nerses, "Meeting Summary of May 9, 1985, Backfit Meeting on Steam Generator Fourth Channel"
c) NRC letter dated November 25, 1985, from Mr. D. Crutchfield to Mr. Hugh Thompson, "Monthly Status Report on Plant Specific Backfitting Activities - October 1985"


Gentlemen:

In Reference (a), the NRC requested that the Beaver Valley Power Station Unit No. 2 (BVPS-2) Final Safety Analysis Report (FSAR) be revised to eliminate the inconsistency of representing the steam generator high level trip system as part of the Emergency Safety Features (ESF) Actuation System. Duquesne Light Company has reviewed the BVPS-2 FSAR and has now determined that only one change is needed. Table 15.0-6 in the FSAR will be revised to refer to the steam generator high level trip function as a non-required actuation function. The use of the high steam generator level is not required for protection but is used only as a convenient ending point for the analysis in Section 15.1.2 of the FSAR. This revision is expected to be incorporated in Amendment No. 11 to the BVPS-2 FSAR, which is scheduled to be issued in January, 1986.

This information should allow you to complete your additional review of applicability to 10CFR50.55(a)(h) in accordance with References (a), (b), and (c).

DUQUESNE LIGHT COMPANY

By


J. J. Carey
Vice President

GLB/wjs

cc: Mr. B. K. Singh, Project Manager
Mr. G. Walton, NRC Resident Inspector

8512310106 851220
PDR ADOCK 05000412
A PDR

AD - J. Knight (ltr only)
EB (BALLARD)
EICS (ROSA)
PSB (GAMMILL)
RSB (BERLINGER)
FOB (BENAROYA)

13001
1/10

Add: