



**SMUD**

SACRAMENTO MUNICIPAL UTILITY DISTRICT ☐ 6201 S Street, P.O. Box 15830, Sacramento CA 95852-1830, (916) 452-3211  
AN ELECTRIC SYSTEM SERVING THE HEART OF CALIFORNIA

RJR 85-575

December 26, 1985

J B MARTIN REGIONAL ADMINISTRATOR  
REGION V OFFICE OF INSPECTION AND ENFORCEMENT  
ATTENTION DOCUMENT CONTROL DESK  
U S NUCLEAR REGULATORY COMMISSION  
WASHINGTON DC 20555

DOCKET NO. 50-312  
LICENSE NO. DPR-54  
SPECIAL REPORT NUMBER 85-09, SUPPLEMENT 1

In our July 31, 1985 report, we described our concern with the potential personnel hazard created by the opening of the Nuclear Services Electrical Building (NSEB) fire doors during an actuation of the cardox system, and provided our schedules for an interim and long term resolution of this concern. The interim resolution of providing a more secure latching mechanism for the existing doors has been completed as scheduled; however, the long term resolution of replacing the existing NSEB doors with 3-hour fire rated doors with "panic" hardware and flush bolts is not expected to be completed until February 28, 1986. This work was originally scheduled to be completed by December 31, 1985.

The delay in implementing the long term resolution is attributed to the 6-8 weeks delivery time required for the materials and special hardware required to meet the Underwriter's Laboratory (U/L) ratings and 10 CFR 50, Appendix R requirements.

If you have any questions concerning this matter, please contact Ron W. Colombo at the Rancho Seco Nuclear Generating Station Unit No. 1.

DEWEY K. K. LOWE  
GENERAL MANAGER

cc: Director, NRR

8512310196 851226  
PDR ADOCK 05000312  
S PDR

IEG  
1/0