

VIRGINIA POWER COMPANY
NORTH ANNA POWER STATION
MONTHLY OPERATING REPORT

MONTH July YEAR 1985
(Revised 08-23-85)

APPROVED:



STATION MANAGER
for

8511190085 850913
PDR ADOCK 05000338
R PDR

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO.	50-339
UNIT NAME	North Anna 2
DATE	08-05-85
COMPLETED BY	Brenda Garner
TELEPHONE	(703) 894-5151 X2527

REPORT MONTH July

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
85-37	850701	S	NA	H	5	NA	NA	NA	Ramped down to 88% power for load follow. Unit returned to 100% power.
85-38	850702	S	NA	H	5	NA	NA	NA	Ramped down to 68% power for load follow. Unit returned to 100% power.
85-39	850725	F	86.7	A	1	* LER 85-008-00	AB	ISV	Ramped Unit 2 off line for high Reactor Coolant System unidentified leakage. Unit returned to 100% power.

*REVISED

1	2	3	4
F: Forced	Reason:	Method:	Exhibit F - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)
S: Scheduled	A-Equipment Failure (Explain)	1-Manual	
	B-Maintenance or Test	2-Manual Scram.	
	C-Refueling	3-Automatic Scram	
	D-Regulatory Restriction	4-Continuations	
	E-Operator Training & License Examination	5-Load Reduction	
	F-Administrative	9-Other	
	G-Operational Error (Explain)		5
	H-Other (Explain)		Exhibit H - Same Source