

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

IF 22



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

November 21, 1985

Mr. Thomas E. Murley
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-065/03X-1
ER 100450 FILE 841-23
PLAS-131

Docket No. 50-387
License No. NPF-14

Dear Mr. Murley:

Attached please find updated Licensee Event Report No. 82-065/03X-1. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that the Reactor Recirculation Pumps tripped during a plant voltage transient while the reactor was critical. The transient was initiated by flash-over in the electric auxiliary boilers.

T.M. Crimmins, Jr.
Superintendent of Plant-Susquehanna

LAK/pjg

cc: Mr. R.H. Jacobs
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
PO Box 52
Shickshinny, PA 18655

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

11
1E22