

March 10, 1986

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNO-II-86-21

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

FACILITY: Duke Power Company
McGuire Unit 1
Docket No. 50-369
Cornelius, North Carolina

Licensee Emergency Classification:
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 X Not Applicable

SUBJECT: UNSCHEDULED SHUTDOWN GREATER THAN 48 HOURS

McGuire Unit 1 is returning to operation today after having been out of service since 7:04 p.m. (EST) on Friday, March 7, for repairs of a leaking sludge lance cover on a steam generator.

McGuire Unit 2 is operating at 100 percent power.

This PN is issued for information only.

The State of North Carolina has been informed.

Contact: C. Burger, 242-4198

V. L. Brownlee, 242-5583

DISTRIBUTION:

H. Street

Chairman Palladino

Comm. Roberts

Comm. Asselstine

Comm. Bernthal

Comm. Zech

SECY

ACRS

CA

PDR

MNBB

EDO

PA

MPA

ELD

Air Rights

SP

Phillips

NRR

E/W

IE

OIA

AEOD

INPO

NSAC

Willste

NMSS

RES

MAIL:

ADM:DMB

DOT: Trans Only

Applicable State

Regions: RI-10:00, RII-10:21, RIV-10:05, RV-10:20, INPO-10:22

Licensee: 10:30

(Reactor Licensees)

Applicable Resident Site - 10: 98

8603200294 860310
PDR I&E
PNO-II-86-021 PDR

DMB

0/1 IE34