

Docket No.: 50-483

Mr. D. F. Schnell
Vice President - Nuclear
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

MAR 17 1986

Dear Mr. Schnell:

Subject: License Condition 2.c.(3)(a), Callaway Unit 1

License Condition 2.c.(3)(a) to Facility Operating License NPF-30 for Callaway Unit 1 requires the electrical equipment within the scope of 10 CFR 50.49 be environmentally qualified in accordance with the schedule in that rule.

Your environmental qualification programs have previously been reviewed and found acceptable. The results of the staff review are detailed in section 3.11 of the Callaway SER (NUREG-0830).

At the time of the staff review not all equipment within the environmental qualification program was considered fully qualified. Acceptable justification for interim operation was provided for those equipment items not fully qualified. The above condition was included in the Callaway operating license to assure timely completion of qualification within regulatory requirements.

By letter dated November 29, 1985 from N. A. Petrick (SNUPPS) to H. R. Denton (NRC), you stated that all electrical equipment has been environmentally qualified to the provisions of 10 CFR 50.49. A final report detailing your position was submitted on January 17, 1986.

Since the staff has already reviewed and approved the Callaway qualification programs, the notification provided in the above letter with subsequent submission of the final report, is adequate to satisfy the condition imposed on the operating license.

Based on the above, the staff finds that License Condition 2.c.(3)(a) has been fulfilled.

Sincerely,

8603200474 860317
PDR ADOCK 05000483
P PDR

B. J. Youngblood, Director
PWR Project Directorate #4
Division of PWR Licensing-A

cc: See next page

DISTRIBUTION:

<u>Docket File</u>	NSIC	OELD	EJordan
NRC PDR	PWR#4 Rdg	ACRS (10)	
Local PDR	MDuncan	JPartlow	
PRC System	BJYoungblood	EGrimes	

PWR#4/DPWR-A *Pwr*
PO'Connor/mac
03/13/86

PWR#4/DPWR-A
MDuncan
03/13/86

DS/t
PWR#4/DPWR-A
BJYoungblood
03/13/86

Mr. D. F. Schnell
Union Electric Company

Callaway Plant
Unit No. 1

cc:

Mr. Nicholas A. Petrick
Executive Director - SNUPPS
5 Choke Cherry Road
Rockville, Maryland 20850

Gerald Charnoff, Esq.
Thomas A. Baxter, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20036

Mr. J. E. Birk
Assistant to the General Counsel
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

U. S. Nuclear Regulatory Commission
Resident Inspectors Office
RR#1
Steedman, Missouri 65077

Mr. Donald W. Capone, Manager
Nuclear Engineering
Union Electric Company
Post Office Box 149
St. Louis, Missouri 63166

Chris R. Rogers, P.E.
Manager - Electric Department
301 W. High
Post Office Box 360
Jefferson City, Missouri 65102

Regional Administrator
U. S. NRC, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Ronald A. Kucera, Deputy Director
Department of Natural Resources
P. O. Box 176
Jefferson City, Missouri 65102

Mr. Glenn L. Koester
Vice President - Nuclear
Kansas Gas and Electric Company
201 North Market Street
Post Office Box 208
Wichita, Kansas 67201

Lewis C. Green, Esq.
Green, Hennings & Henry
Attorney for Joint Intervenors
314 N. Broadway, Suite 1830
St. Louis, Missouri 65251

Ms. Marjorie Reilly
Energy Chairman of the League of
Women Voters of Univ. City, MO
7065 Pershing Avenue
University City, Missouri 63130

Mr. Donald Bollinger, Member
Missourians for Safe Energy
6267 Delmar Boulevard
University City, Missouri 63130

Mr. Dan I. Bolef, President
Kay Drey, Representative
Board of Directors Coalition
for the Environment
St. Louis Region
6267 Delmar Boulevard
University City, Missouri 63130