



Northeast
Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

May 30, 1997

Docket No. 50-423
B16476

Re: 10CFR 50.73(a)(2)(ii)(B)

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station Unit 3
Licensee Event Report 97-030-00
Submitted Pursuant to 10CFR 50.73(a)(2)(ii)(B)

This letter forwards Licensee Event Report 97-030-00, documenting a condition that was determined at Millstone Unit No. 3 on May 1, 1997. This LER is submitted pursuant to 10CFR 50.73(a)(2)(ii)(B). NNECO's commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. David A. Smith at (860) 437-5840.

Very truly yours,

NORTHEAST NUCLEAR ENERGY
COMPANY

G. D. Hicks
Unit Director, Millstone Unit No. 3

JE221

040025

9706050060 970530
PDR ADOCK 05000423
S PDR



Attachment: 1) NNECO's commitments in response to LER 97-030-00
2) LER 97-030-00

cc: H. J. Miller, Region I Administrator
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3
J. W. Andersen, NRC Project Manager, Millstone Unit No. 3
W. D. Travers, Dr., Director, Special Projects

Docket No. 50-423
B16476

Attachment 1

Millstone Nuclear Power Station, Unit No. 3
NNECO's Commitments
In Response To
(LER 97-030-00)

May 30, 1997

Enclosure
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Please notify the Manager - Nuclear Licensing at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

Number	Commitment	Due
B16476-01	A review of system operational aspects will be performed to determine if the 10 CFR 50 Appendix G limits have been met since startup. Review and evaluation will be completed prior to entering Mode 4. If Appendix G limits are found to have been violated a supplement to this LER will be submitted.	Prior to entry into Mode 4
B16476-02	A Technical Specification change will be submitted to revise the existing pressure and temperature limits and the PORV setpoint curves.	July 1, 1997

Docket No. 50-423
B16476

Attachment 2

Millstone Nuclear Power Station, Unit No. 3
NNECO's Submittal of
(LER 97-030-00)

May 30, 1997