



**Wisconsin  
Electric**  
POWER COMPANY

Point Beach Nuclear Plant  
6610 Nuclear Rd., Two Rivers, WI 54241

(414) 755-2321

NPL 97-0310

May 30, 1997

Document Control Desk  
U.S. NUCLEAR REGULATORY COMMISSION  
Mail Station P1-137  
Washington, D. C. 20555

Ladies/Gentlemen:

DOCKETS 50-266 AND 50-301  
LICENSEE EVENT REPORT 97-013-01  
COMPONENT COOLING WATER SYSTEM NOT  
IN ACCORDANCE WITH PLANT DESIGN BASIS  
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Enclosed is supplemental Licensee Event Report 97-013-01 for Point Beach Nuclear Plant, Units 1 and 2. This report is provided in accordance with 10 CFR 50.73(a)(2)(ii)(B), "Any event or condition that resulted in the nuclear power plant being in a condition that was outside the design basis of the plant." This report replaces LER 97-013-00 in its entirety and describes the identification of the component cooling water system as not being able to be cross-connected as described in Section 9.3 of the PBNP Final Safety Analysis Report (FSAR). This supplement includes an additional similar occurrence not previously reported to the NRC in which credit was taken for the CCW cross-connect function when, based on the cause of this event, the cross-connect valve was actually inoperable. Also included is an updated safety assessment and updated component failure information.

Please contact us if you require additional information.

Sincerely,

D. F. Johnson  
Manager, Regulatory Services & Licensing


Enclosure

cc: NRC Resident Inspector  
NRC Regional Administrator

9706050238 970530  
PDR ADOCK 05000266  
S PDR

040081

A subsidiary of Wisconsin Energy Corporation



1/1  
Jew