

Commonwealth Edison Company
Quad Cities Generating Station
22710 200th Avenue North
Cordova, IL 61242-9740
Tel 809-654-2241



LWP-97-059

May 29, 1997

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 97-003, Revision 00, for Quad Cities Nuclear Power Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(v)(B)(D). The licensee shall report any event or condition that could have prevented the removal of residual heat or mitigated accident consequences.

The following commitments are being made by this letter:

Procedure QCAP 0307-02, "ASME Section XI Repair And Replacement Program Preparation," Attachment A "Section XI Repair/Replacement Program," will be revised to provide clear instructions of when a VT-2 is required. This procedure revision will be completed by 062797. (Engineering).

1/1
Jerr

9706060052 970529
PDR ADOCK 05000254
S PDR




May 29, 1997

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION



L. W. Pearce
Station Manager

LWP/CP/plm

Enclosure

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
M. E. Wagner, Licensing, ComEd
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center