



ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

September 4, 1981



ØCANØ981Ø2

Mr. Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Arkansas Nuclear One - Units 1 & 2
Docket Nos. 50-313 and 50-368
License Nos. DPR-51 and NPF-6
Use of Closed Circuit Television
in the Technical Support Center
(File: 1510.2, 2-1510.4)

Gentlemen:

In our letter to you of January 17, 1980, we presented our proposed concept of Primary and Secondary Technical Support Centers (TSC) for your approval. In this letter we indicated that closed circuit television (CCTV) would be utilized by the TSC to read vital instruments in the control room and this along with the plant computer output would serve as the instrumentation for the TSC. In your letter of April 15, 1980, responding to our letter, you approved the concept of a Primary and Secondary TSC but made no reference to the use of CCTV for TSC instrumentation. Subsequent to our January 17, 1980, proposal the NRC published further guidance on TSC instrumentation. It became evident after reviewing this material that the use of CCTV would no longer meet the requirements for the TSC instrumentation. Therefore, CCTV will not be utilized in the TSC's to monitor plant parameters. Instead the TSC will use CRT displays as described to you in our letter of June 1, 1981.

Very truly yours,

David C. Trimble

David C. Trimble
Manager, Licensing

DCT:DEJ:s1

8109140194 810904
PDR ADOCK 05000313
P PDR

*A001
S.10*