

INDUSTRIAL PRETREATMENT
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant
10 Center Rd.
Perry, Ohio 44081

Permit No.: 1004911
Report Date: 4/14/97
Laboratory: Electro Analytical

Date of Sample: 4/3 to 4/4/97
Sample Location: Sewage Pump Station


Time of sample: 10:15
Name of Sampler: Masters

Laboratory Address: 7118 Industrial Park Blvd.
Mentor, OH 44060

Date of Analysis: 4/4 to 4/11/97
Flow: 33,000 gpd

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	ANALYSIS RESULT
COD	Composite	410.4	4/08/97	180 mg/L
BOD	Composite	405.1	4/09/97	110 mg/L
TSS	Composite	160.2	4/08/97	83 mg/L
Silver	Composite	272.1	4/11/97	<.01 mg/L
Mercury	Composite	245.1	4/10/97	<0.5 ug/L
pH	Grab	150.1	4/04/97	8.3 s.u.
Oil/Grease Gravimetric	Grab	413.1	4/09/97	8.4 mg/L

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.


Signature

6/4/97
Date

Sr. Vice President - Nuclear
Title